

UNCLASSIFIED

DPST-70-433

~~SPECIAL REREVIEW~~
~~Unclassified~~
 FINAL DETERMINATION

~~By Authority of~~
~~H.S. [Signature]~~

Date: Dec. 19, 1980

CLASSIFICATION ~~[Redacted]~~ *Changed*
 BY AUTHORITY OF SR Class
J.M. Bauer Officer 3/30/83
 NAME TITLE DATE

ANALYSIS OF POSTULATED CORE MELTDOWN
 OF AN SRP REACTOR

RECORDS ADMINISTRATION

 R1382860

FINAL REPORT

W.S. DURANT
 R.J. BROWN

TIS FILE
 RECORD COPY

NO LONGER
 CONTAIN S
 UNCLASSIFIED CONTROLLED
 NUCLEAR INFORMATION
 GEORGE C. RODRIGUES
 CLASSIFICATION ANALYST
 OFFICE: SENIOR CLASSIFICATION OFFICER
 (Name and Title)

Date: 2/18/2009
 UNCLASSIFIED
 CONTROLLED NUCLEAR INFORMATION
 NOT FOR PUBLIC DISSEMINATION
 This document contains information that is subject to
 the provisions of Section 148 of the Atomic Energy
 Act, as amended. Unauthorized dissemination provides
 both civil and criminal penalties.

~~Classification Review for
 Declassification but left
 unchanged~~
 11-10-75
 DATE
 74/4/7
 U.S. RECORD CONTROL CENTER
 RG 120.20



Name: [Redacted] Title: S.S. Date: 5/1/77

ISSUED BY

Savannah River Laboratory

Aiken, South Carolina

UNCLASSIFIED
 CONTROLLED NUCLEAR INFORMATION
 NOT FOR PUBLIC DISSEMINATION
 This document contains information that is subject to
 the provisions of Section 148 of the Atomic Energy
 Act, as amended. Unauthorized dissemination provides both
 civil and criminal penalties.

UNCLASSIFIED

UNCLASSIFIED
CONFIDENTIAL

ANALYSIS OF POSTULATED CORE MELTDOWN OF AN SRP REACTOR

FINAL REPORT

by

William S. Durant
Robert J. Brown

October 1970

UNCLASSIFIED
~~CONTROLLED NUCLEAR INFORMATION~~
~~NOT FOR PUBLIC DISSEMINATION~~
This document contains information that is
subject to the provisions of Section 148 of
the Atomic Energy Act, as amended.
Unauthorized dissemination provides both
civil and criminal penalties.

RESTRICTED DATA

E. I. DU PONT DE NEMOURS & COMPANY
SAVANNAH RIVER LABORATORY
AIKEN, S. C. 29801

CONTRACT AT(07-2)-1 WITH THE
UNITED STATES ATOMIC ENERGY COMMISSION

UNCLASSIFIED
CONFIDENTIAL

XXXXXXXXXXXXXXXXXXXX
XXXXXXXXXXXXXXXXXXXX
XXXXXXXXXXXXXXXXXXXX
XXXXXXXXXXXXXXXXXXXX

UNCLASSIFIED

XXXXXXXXXXXXXXXXXXXX
XXXXXXXXXXXXXXXXXXXX
XXXXXXXXXXXXXXXXXXXX
XXXXXXXXXXXXXXXXXXXX

CONTENTS

	<u>Page</u>
List of Figures	7
List of Tables	8
Introduction	9
Summary	9
Discussion	10
Failure to Actuate the Light-Water Addition Systems . . .	14
Description of the Accident	14
Heat Transfer at the -40 ft Level	18
Heat Transfer to the Bottom Reactor Shield	22
Method of Calculation for Heat Removal from Molten Debris	23
Results of Calculations	24
Uranium Metal Charge	30
Uranium-Aluminum Alloy Charge	30
High Flux Charge	32
Effect of Parametric Variations	32
Effect of Air Temperature on Methyl Iodide Formation	33
Effect of Air Temperature on the Activity Confinement System	34
Heat Removal from Potential Water Sources at the -40 ft Level	35
Addition of Light Water after Core Meltdown	37
Mechanisms of Interaction	39
Steam Explosions	39
Metal-Water Reactions	40
Location and Degree of Interaction	46
Below Grade	46
Reactor Tank	49
Above Grade	54

~~SECRET~~

UNCLASSIFIED

XXXXXXXXXXXXXXXXXXXX
XXXXXXXXXXXXXXXXXXXX
XXXXXXXXXXXXXXXXXXXX
XXXXXXXXXXXXXXXXXXXX

CONFIDENTIAL
XXXXXXXXXXXXXXXXXXXX
XXXXXXXXXXXXXXXXXXXX
XXXXXXXXXXXXXXXXXXXX
XXXXXXXXXXXXXXXXXXXX

UNCLASSIFIED CONTENTS (Continued)

	<u>Page</u>
Results of Calculations	56
Subsequent Effects from Core Meltdown	56
Cooling Requirements for Debris	56
Cooling Requirements for Carbon Beds	58
Debris Configuration	60
References	62
Appendix A - LAVA Computer Code	65
Appendix B - LAVA Code Output	87

UNCLASSIFIED

XXXXXXXXXXXXXXXXXXXX
XXXXXXXXXXXXXXXXXXXX
XXXXXXXXXXXXXXXXXXXX
SECRET
XXXXXXXXXXXXXXXXXXXX
XXXXXXXXXXXXXXXXXXXX

CONFIDENTIAL

XXXXXXXXXXXXXXXXXXXX
XXXXXXXXXXXXXXXXXXXX
XXXXXXXXXXXXXXXXXXXX
XXXXXXXXXXXXXXXXXXXX

UNCLASSIFIED
LIST OF FIGURES

<u>Figure</u>		<u>Page</u>
1	Savannah River Plant Reactor Building	11
2	Schematic Cross Section of Reactor Building	12
3	Schematic of Reactor Cooling System	12
4	Savannah River Reactor	13
5	Accident Flowsheet - No Addition of Light Water to Fuel	15
6	Schematic of Bottom Shield of P and L Reactors	16
7	Schematic of Bottom Shield of C Reactor	17
8	LAVA Code Model Before Pipe Collapse	19
9	Phase Diagram for Uranium-Iron	20
10	LAVA Code Model After Pipe Collapse	21
11	Calculated Temperatures Following Meltdown of Full-Reacto Uranium Metal Charge	26
12	Comparison of Calculated Exhaust Air Temperatures for C Reactor and P (or K) Reactor	27
13	Calculated Temperatures Following Meltdown of Full-Reacto Uranium-Aluminum Alloy Charge	28
14	Calculated Temperatures Following Meltdown of High-Flux Charge	29
15	C Reactor Building Floor Plan at -40 ft Level	31
16	Confinement Heat Removal System	36
17	Accident Flowsheet - Light Water Added After Melting	38
18	Effect of Metal Temperature and Composition on Metal-Water Reaction	43
19	Flammability Limits of Hydrogen-Air-Steam Mixtures	45
20	Reactor Plenum Skirt	51
21	Plenum Inlet Roll Anchor	52
22	Actuator Guide Tube Forest	53
23	Savannah River Reactor Room	55
24	Ventilation System for -20 ft and -40 ft Levels	58
25	Process Area Exhaust Air System	59

XXXXXXXXXXXXXXXXXXXX
XXXXXXXXXXXXXXXXXXXX
SECRET
XXXXXXXXXXXXXXXXXXXX
XXXXXXXXXXXXXXXXXXXX

UNCLASSIFIED

CONFIDENTIAL

CONFIDENTIAL
XXXXXXXXXXXXXXXXXXXX
XXXXXXXXXXXXXXXXXXXX
XXXXXXXXXXXXXXXXXXXX
SECRET
XXXXXXXXXXXXXXXXXXXX
XXXXXXXXXXXXXXXXXXXX

UNCLASSIFIED

LIST OF TABLES

<u>Table</u>		<u>Page</u>
I	Modes of Energy Transfer Used in LAVA Computer Program	25
II	Structural Limitations	47



UNCLASSIFIED

XXXXXXXXXXXXXXXXXXXX
SECRET
XXXXXXXXXXXXXXXXXXXX
XXXXXXXXXXXXXXXXXXXX
XXXXXXXXXXXXXXXXXXXX

UNCLASSIFIED

CONFIDENTIAL

XXXXXXXXXXXXXXXXXXXX
XXXXXXXXXXXXXXXXXXXX
XXXXXXXXXXXXXXXXXXXX
XXXXXXXXXXXXXXXXXXXX

INTRODUCTION

An analysis was made to determine the consequences of a postulated accident in which the core of a Savannah River Plant reactor melts down following the loss of coolant. The study was made to determine 1) the potential damage to the reactor building that could impair its integrity for confining activity and 2) the need for additional facilities to prevent the activity confinement system from being overheated by the decay heat in the debris.

A preliminary report on this analysis was issued previously.¹ The sequence of events during and following the loss of coolant has now been studied in more detail, and a computer program has been written and used to investigate transient heating effects. This is the final report of the analysis and presents the conclusions.

SUMMARY

Calculations show that in the event of the postulated complete meltdown of the core of an SRP reactor, the integrity of the confinement system would not be breached either by the penetration of a molten core through the floors and into the earth beneath or by rupture due to explosion (steam or hydrogen). The massive concrete structure housing the reactor facility affords an effective heat sink and is expected to be resistant to the effects of explosions of the magnitude probable for the accident. Heat would be removed by the ventilation system to the atmosphere.

The analysis also shows, however, that a heat removal system would be required to prevent the exhaust air from reaching temperatures in excess of 100°C. Above this temperature significant desorption of iodine from the carbon beds could occur. A system has been designed to cool the debris directly by means of a water spray external to the reactor vessel.

The longer-term effects calculated for a meltdown accident in which the debris is cooled by the proposed confinement heat removal system are as follows. The below-grade areas of C or K reactor building would fill with water in about 20 hours after meltdown; at this time the flow would be stopped. Heating from decay energy would increase the water temperature to about 95°C in about 30 days.

XXXXXXXXXXXXXXXXXXXX
XXXXXXXXXXXXXXXXXXXX
XXXXXXXXXXXXXXXXXXXX
XXXXXXXXXXXXXXXXXXXX

UNCLASSIFIED

CONFIDENTIAL

CONFIDENTIAL

UNCLASSIFIED

XXXXXXXXXXXXXXXXXXXX
XXXXXXXXXXXXXXXXXXXX
SECRET
XXXXXXXXXXXXXXXXXXXX

After 30 days, heat loss through the building structure to the earth would exceed the heat generation, and the pool would begin to cool. No addition of water to the pool would be required. Because of the larger below-grade volume in P reactor building, the maximum water temperature would be less than for C or K.

Forced air cooling of the carbon beds in the filtration-adsorption compartments would be required for about 24 hours after the meltdown, after which time natural draft would maintain the temperature of the beds below 100°C. After about one day, the remaining fission product inventory could be confined within the reactor building and the filtration-adsorption compartments for an extended period of time with no further equipment operation or maintenance.

DISCUSSION

Analyses were made of the consequences of two variations of a loss-of-coolant accident in SRP reactors (Figures 1-4):

1. failure to actuate the light water addition systems
2. addition of light water after core meltdown

Analyses of this type have many conceivable variations. The analyses in the present study are based on engineering judgment of conservative, but logical, sequences of conceivable events.

The first part of the discussion is concerned with heat transfer from the molten core and the sequence of events ending with debris at the -40 ft level if no light water were added. The second part of the discussion is concerned with the consequences of metal-water interaction that might result from the addition of water after the core melted, leading to either steam explosions or chemical reactions. The last part of the discussion deals with the events following a core meltdown in which cooling is provided by a proposed confinement heat removal system.²

UNCLASSIFIED

FO: -

XXXXXXXXXXXXXXXXXXXX
SECRET
XXXXXXXXXXXXXXXXXXXX

CONFIDENTIAL

UNCLASSIFIED CONFIDENTIAL

XXXXXXXXXXXXXXXXXXXX
SECRET
XXXXXXXXXXXXXXXXXXXX
XXXXXXXXXXXXXXXXXXXX
XXXXXXXXXXXXXXXXXXXX




FIG. 1 SAVANNAH RIVER PLANT REACTOR BUILDING

UNCLASSIFIED CONFIDENTIAL

SECRET

UNCLASSIFIED




FIG. 2 SCHEMATIC CROSS SECTION OF REACTOR BUILDING




FIG. 3 SCHEMATIC OF REACTOR COOLING SYSTEM



UNCLASSIFIED

UNCLASSIFIED

CONFIDENTIAL

SECRET




FIG. 4 SAVANNAH RIVER REACTOR

SECRET

UNCLASSIFIED

CONFIDENTIAL

FAILURE TO ACTUATE THE LIGHT-WATER ADDITION SYSTEMS

Description of the Accident

The following sequence of events was used as a basis for calculating heat transfer to the exhaust ventilation air following a loss-of-coolant accident (Figure 5) in which the light water addition systems were not actuated. The postulated accident, representing an extreme case, is a double-ended break in one process water plenum inlet line. Although no significant process line breaks have been experienced at SRP, if one were to occur, it would almost certainly be much smaller than a double-ended break and would cause much less severe consequences. The double-ended break is calculated to be the fastest means of removing D₂O from the reactor system; if a single pipe failed, ~20 seconds would be required to drain all the D₂O from the reactor. The safety rod circuits would be actuated by any of several signals: low plenum pressure, low fuel flow, low blanket gas pressure, low septifoil header pressure, assembly high coolant temperatures, or low D₂O level. Even if the safety circuits failed, the reactor would be shut down by the loss of moderator. Actuation of the emergency core cooling system would then provide continued core cooling and limit core damage.

If the emergency core cooling system were not actuated, nearly adiabatic heating of the assemblies by decay heat would begin upon complete loss of coolant. Less than one minute is required for all of the fuel to melt in a high flux charge, about 2 minutes in a full reactor uranium-aluminum alloy charge, and about 9 minutes in a uranium metal charge. Significant melting in a uranium-aluminum alloy charge, however, could begin in about one minute. During melting, heat transfer to the atmosphere or the reactor structure would be negligible. Molten fuel and aluminum would slump to the bottom of the tank. Heat then would be transferred primarily to the bottom shield (Figures 6 and 7) by conduction and some fuel would solidify on the tank bottom. Radiant and convective heat transfer within the reactor tank is calculated to be negligible.

In K or P reactor, most of the molten mass would flow into the outlet nozzles and into the pumps at the -40 ft level. (Levels within the reactor building are referenced to the floor of the reactor room at the top of the reactor which is designated as the 0 ft level. The -40 ft level is the lowest process level within the building.) In C reactor, the outlet nozzles are 15 inches above the bottom of the reactor tank (Figure 7); thus the molten mass would be retained in the tank until the temperature became sufficiently high to melt through the tank bottom and bottom shield.

UNCLASSIFIED

CONFIDENTIAL

SECRET




FIG. 5 ACCIDENT FLOWSHEET-NO ADDITION OF LIGHT WATER TO FUEL

UNCLASSIFIED

SECRET

CONFIDENTIAL

UNCLASSIFIED

CONFIDENTIAL

XXXXXXXXXXXXXXXXXXXX
XXXXXXXXXXXXXXXXXXXX
XXXXXXXXXXXXXXXXXXXX
XXXXXXXXXXXXXXXXXXXX




FIG. 6 SCHEMATIC OF BOTTOM SHIELD OF P AND K REACTORS

UNCLASSIFIED

CONFIDENTIAL

XXXXXXXXXXXXXXXXXXXX
XXXXXXXXXXXXXXXXXXXX
XXXXXXXXXXXXXXXXXXXX
XXXXXXXXXXXXXXXXXXXX



Heat Transfer at the -40 ft Level

Mechanisms of heat transfer from the molten mass in the pumps and lower process piping for P and K reactors are shown schematically in Figure 8. As the molten fuel flows into the cold piping, sufficient heat would be conducted into the piping to resolidify the fuel in immediate contact with the stainless steel. Consequently, the fuel would not plunge en masse to the lower levels of the process piping system; dissolution of the stainless steel would be negligible as long as the fuel in contact with the piping surface remained solid. Heat conducted through the piping and pumps would be transmitted by thermal radiation to building surfaces and by convection to the air. Heat would also be transmitted from the building surfaces by conduction into the concrete and steel and by convection to the ventilation air. The energy transmission by gamma radiation is included in calculations of heat transfer.

Because heat would not be dissipated from the piping as rapidly as it would be generated, the temperature of the fuel would again increase. When the fuel in contact with the piping remelts, the uranium would dissolve the piping, and the molten "lava" would pour to the floor of the pump rooms. "Lava" refers to the combination of fuel, cladding, other core material, and stainless steel. Uranium forms a eutectic with stainless steel (at about 65 wt % uranium) which melts at about 725°C (Figure 9). The average melting temperature of the lava from a uranium metal charge would be about 1000°C because of the relative amounts of uranium and stainless steel. The lava would spread over the floor until the heat loss into the floor, walls, and air shown in Figure 10 is equal to the decay heat at the melting temperature (1000°C). Significant oxidation of the uranium would not be expected until the debris is deposited on the floor at the -40 ft level because of the relatively small amount of oxygen in the reactor vessel. Oxidation at the -40 ft level is discussed later.

Significant heat transfer to the -40 ft areas would not occur in C reactor until the lava melted through the bottom shield. After this occurred, the mechanisms for heat transfer in all three reactors would be the same.

Surface disruption of the concrete floor and walls would be expected, but gross structural failure would not be likely because the lava would solidify rapidly, thus precluding further motion of the lava and concrete particles on the floor. Also, the massive walls and floor can dissipate a large amount of heat.

XXXXXXXXXXXXXXXXXXXX
XXXXXXXXXXXXXXXXXXXX
XXXXXXXXXXXXXXXXXXXX
XXXXXXXXXXXXXXXXXXXX




FIG. 8 LAVA CODE MODEL BEFORE PIPE COLLAPSE

XXXXXXXXXXXXXXXXXXXX
XXXXXXSECRET
XXXXXXXXXXXXXXXXXXXX
XXXXXXXXXXXXXXXXXXXX

CONFIDENTIAL
 UNCLASSIFIED




FIG. 9 PHASE DIAGRAM FOR URANIUM-IRON³⁶

UNCLASSIFIED

CONFIDENTIAL
 UNCLASSIFIED

UNCLASSIFIED

XXXXXXXXXXXXXXXXXXXX
XXXXXXXXXXXXXXXXXXXX
XXXXXXXXXXXXSECRETXXXX
XXXXXXXXXXXXXXXXXXXX

CONFIDENTIAL




FIG. 10 LAVA CODE MODEL AFTER PIPE COLLAPSE

XXXXXXXXXXXXXXXXXXXX
XXXXXXXXXXXXXXXXXXXX
XXXXXXXXXXXXSECRETXXXX
XXXXXXXXXXXXXXXXXXXX

UNCLASSIFIED

UNCLASSIFIED

CONFIDENTIAL

XXXXXXXXXXXXXXXXXXXX
XXXXXXXXXXXXXXXXXXXX
XXXXXXXXXXXXXXXXXXXX
XXXXXXXXXXXXXXXXXXXX

The bottom shields of the reactors (Figures 6 and 7) are 40 inches thick and are packed with stainless steel Raschig rings in the spaces between the monitor pin sleeves. Deionized light water in an independent cooling loop is provided to cool the shield. Decay heat from fuel remaining in the reactor tank cannot be transferred readily to the exhaust ventilation air; thus, the heat load to the confinement system would be inversely related to the quantity of fuel remaining in the tank.

In K or P reactor, about 93% of the debris from a natural uranium charge is calculated to flow into the reactor effluent piping within 5 minutes after a full core meltdown. The remainder of the fuel would be cooled by natural convection and radiation, and no gross melting of the tank bottom is calculated.

In C reactor, none of the molten fuel would flow into the reactor effluent piping because the nozzles are 15 inches above the tank bottom. The molten fuel would melt through the bottom shield in about 50 minutes if no metal-water reaction occurred. After the tank bottom melts, the shield would be vapor locked if a steam explosion does not occur.

Metal-water interaction in the bottom shield of K or P reactor is possible but not very probable. On the other hand, significant metal-water interaction could occur in the bottom shield of C reactor.

The air temperature inside the reactor vessel approaches the fuel temperature within 5 minutes after losing coolant flow because the annular air gap (Figures 6 and 7) adjacent to the reactor vessel wall provides a very high resistance to heat losses. For a uranium metal charge, the air temperatures inside K or P reactor would approach 1100°C; the air temperature inside C reactor would approach 1430°C before the bottom shield is completely penetrated. Lower temperatures would be expected for other types of charges because of less decay heat than associated with uranium metal charges.

Method of Calculation for Heat Removal from Molten Debris

A computer code, called LAVA, was written to compute the time-dependent heat transfer from the fuel debris after melting is completed and the debris has flowed into the effluent nozzles of the reactor tank. The code calculates:

- the location and physical state of the fuel,
- the temperature of the fuel,

XXXXXXXXXXXXXXXXXXXX
XXXXXXXXXXXXXXXXXXXX
XXXXXXXXXXXXXXXXXXXX
XXXXXXXXXXXXXXXXXXXX

CONFIDENTIAL

UNCLASSIFIED

CONFIDENTIAL
XXXXXXXXXXXXXXXXXXXX
XXXXXXXXXXXXXXXXXXXX
XXXXXXXXXXXXXXXXXXXX
XXXXXXXXXXXXXXXXXXXX
UNCLASSIFIED

- the temperature of the process equipment and nearby building structure, and
- the temperature of the exhaust ventilation air.

Preliminary calculations for a natural uranium charge were presented in Reference 1. Subsequently, refinements to the code have been made to account for thermal energy released from the debris as gamma radiation and for energy added to the debris from oxidation.

The LAVA computer code involves heat balance determinations between the energy released as decay heat and that dissipated from the debris. Two sets of calculations are made depending upon the location of the mass of debris. In the initial determination, molten core material at the melting temperature is assumed to flow into the effluent piping and pumps of the reactor. Because of the large, cold mass of the piping and pumps (~200,000 pounds), most of the debris will freeze. Interaction between the debris and the stainless steel piping is assumed to be negligible during the short time that the debris is solid, thus the piping remains intact. During this interval, the heat balance is made using the LAVA code model illustrated in Figure 8. Modes of energy transfer that are used in the calculations are listed in Table I. Although neglected in this analysis, a large quantity of energy can be removed by existing water sources at the -40 ft level as discussed in a later section (Heat Removal from Potential Water Sources at the -40 ft Level).

After the debris remelts, the uranium will rapidly dissolve the piping, and the mass will fall to the floor. The heat transfer model for this condition is shown in Figure 10. Modes of energy transfer from the debris on the floor are listed in Table I.

Results of Calculations

The results of calculations for three types of reactor charges are presented in Figures 11 through 14.

UNCLASSIFIED
XXXXXXXXXXXXXXXXXXXX
XXXXXXXXXXXXXXXXXXXX
XXXXXXXXXXXXXXXXXXXX
CONFIDENTIAL

XXXXXXXXXXXXXXXXXXXXX
XXXXXXXXXXXXXXXXXXXXX
XXXXXXSECRETXXXXXX
XXXXXXXXXXXXXXXXXXXXX

CONFIDENTIAL

TABLE I

Modes of Energy Transfer Used in LAVA Computer Program

Debris Contained in Piping (see Figure 8)

- Conduction through a solid cylinder with internal heat generation (lava)
- Gamma escape from a solid cylinder (lava)
- Conduction through the wall of a hollow cylinder (S/S pipe)
- Gamma attenuation by the wall of a hollow cylinder (S/S pipe)
- Thermal radiation from a cylinder to completely enclosing surfaces (pipe to the building floor and walls)
- Natural convection from vertical and horizontal surfaces (building floor and walls)
- Gamma attenuation by a slab (debris on concrete walls and floor)
- Transient conduction through a slab (debris on concrete walls and floor)
- Absorption of heat of fusion (lava)

Debris on Floor of Pump Rooms (see Figure 10)

- Conduction through a slab with internal heat generation (debris on floor)
- Gamma escape from a slab (debris on floor)
- Thermal radiation from a plane to partially enclosing surfaces (debris on floor to walls of building)
- Natural convection from vertical and horizontal surfaces (building floor and walls)
- Gamma attenuation by slabs (debris on floor)
- Heat absorbed from oxidation reaction (debris on floor)
- Transient conduction through slabs (concrete walls and floor)
- Absorption of heat of fusion (debris on floor)

XXXXXXXXXXXXXXXXXXXXX
XXXXXXXXXXXXXXXXXXXXX
XXXXXXSECRETXXXXXX
XXXXXXXXXXXXXXXXXXXXX

UNCLASSIFIED
CONFIDENTIAL



UNCLASSIFIED
SECRET

CONFIDENTIAL




FIG. 12 COMPARISON OF CALCULATED EXHAUST AIR TEMPERATURES FOR C REACTOR AND P OR K REACTOR

SECRET

UNCLASSIFIED

CONFIDENTIAL

XXXXXXXXXXXXXXXXXXXX
XXXXXXXXXXXXXXXXXXXX
XXXXXXXXXXXXXXXXXXXX




FIG. 13 CALCULATED TEMPERATURES FOLLOWING MELTDOWN OF FULL-REACTOR URANIUM-ALUMINUM ALLOY CHARGE

UNCLASSIFIED

XXXXXXXXXXXXXXXXXXXX
SECRET
XXXXXXXXXXXXXXXXXXXX

C 6 11 S. 5




FIG. 14 CALCULATED TEMPERATURES FOLLOWING MELTDOWN OF HIGH FLUX CHARGE

XXXXXXXXXXXXXXXXXXXX
SECRET
XXXXXXXXXXXXXXXXXXXX

UNCLASSIFIED

CONFIDENTIAL

UNCLASSIFIED

XXXXXXXXXXXXXXXXXXXX
XXXXXXXXXXXXXXXXXXXX
XXXXXXXXXXXXXXXXXXXX
XXXXXXXXXXXXXXXXXXXX

URANIUM METAL CHARGE

For a full-reactor charge of uranium metal (Figure 11) in P or K reactor, no significant degradation of the confinement system would be expected for at least 30 minutes if an air flow of 128,000 cfm is maintained. At this time, the exhaust air temperature would reach a value at which desorption of iodine from carbon beds that have been in use for an extended time could become significant (about 100°C for 4-year-old carbon).⁵ For newly installed carbon beds, no significant desorption would be expected for at least 3 hours when the air temperature would reach ~220°C. Operation of the exhaust fans, however, is estimated to continue until the air temperature reaches ~250°C, which would occur in about 5 hours at the design air flow of 128,000 cfm (or about 2-1/2 hours if the air flow is 75,000 cfm because of dusty filters or operation of only one fan).

The debris would spread over about 3500 ft² of floor area in about one hour and freeze. The average debris thickness would be about 2-1/4 inches. This area is about 2/3 of the pump room floor area (Figure 15); therefore, most of the debris would not flow into the sumps at the ends of the pump room where heat transfer to the exhaust air would be reduced. Wall surface average temperatures would exceed 500°C in about 5 hours at which time surface spalling would occur, but the walls would remain structurally intact because they are at least 5 feet thick. In C reactor, the air temperature would increase more rapidly than in P or K reactor because the debris would be hotter when melt-through occurred. A peak temperature of ~270°C for the exhaust air was calculated as shown on Figure 12. The difference in peak exhaust air temperature between C reactor and P (or K) reactor is insignificant.

URANIUM-ALUMINUM ALLOY CHARGE

For a full-reactor charge of uranium-aluminum alloy (Figure 13) in P or K reactor, the exhaust air temperature also would reach 100°C in about 30 minutes. However, at a total process area air flow of 128,000 cfm a peak exhaust air temperature of only about 190°C would be reached, which is less than that estimated to cause fan failure or significant desorption from newly installed carbon beds. At 75,000 cfm, the peak temperature of 250°C is marginal for continuous operation of the fans. These maximum air temperatures would occur about 4 hours after the accident, then decrease at a rate of ~2°C per hour for at least the next 12 hours, the extent to which the calculations were carried. Wall surface average temperatures would not exceed about 430°C even at reduced air flow; therefore, significant spalling of the concrete walls would not be expected. The calculated temperatures are lower for an alloy charge than for a

UNCLASSIFIED

CONFIDENTIAL


XXXXXXXXXXXXXXXXXXXX
XXXXXXXXXXXXXXXXXXXX
XXXXXXXXXXXXXXXXXXXX
XXXXXXXXXXXXXXXXXXXX

UNCLASSIFIED

CONFIDENTIAL

XXXXXXXXXXXXXXXXXXXX
SECRET
XXXXXXXXXXXXXXXXXXXX
XXXXXXXXXXXXXXXXXXXX
XXXXXXXXXXXXXXXXXXXX

uranium metal charge because of the higher decay heats caused by ^{239}Np in the latter. About half of the floor area of the pump rooms is calculated to be covered by the fuel debris with an average thickness of about 1 inch before the debris freezes.



UNCLASSIFIED

XXXXXXXXXXXXXXXXXXXX
SECRET
XXXXXXXXXXXXXXXXXXXX
XXXXXXXXXXXXXXXXXXXX

CONFIDENTIAL

~~CONFIDENTIAL~~
UNCLASSIFIED

XXXXXXXXXXXXXXXXXXXX
XXXXXXXXXXXXXXXXXXXX
XXXXXXXXXXXXXXXXXXXX
XXXXXXXXXXXXXXXXXXXX

HIGH FLUX CHARGE

Design performance of the activity confinement system probably would be maintained following a meltdown of a high flux charge because of the lower reactor power (less decay heat), lower inventory of fission products, and smaller mass of materials involved without modifications. At a design ventilation flow of 128,000 cfm, a peak air temperature of about 130°C would be reached in about 4 hours, then decrease at an initial rate of about 2°C per hour (Figure 14). At a reduced flow of 75,000 cfm, the peak temperature would be 165°C. Continuous operation of the exhaust fans would be expected at this temperature. For new activated carbon, desorption of iodine would be insignificant at 165°C. The debris would cover only about 1500 ft², or less than 1/3 of the floor area, with an average thickness of less than 1/2 inch.

The refined analysis of effects with no light water addition confirms the earlier conclusion¹ that some additional means to cool the debris would be necessary to preserve the activity confinement system.

Effect of Parametric Variations

The following parameters in the calculation (LAVA) were varied to determine which were significant:

- mass flow of air through below-grade process areas (10,000 to 90,000 cfm)
- inlet air temperature (10 to 40°C)
- effective area of process piping for heat transfer (1000 to 1560 ft²)
- effective area of concrete walls for heat transfer (20,000 to 40,000 ft²)
- thermal conductivity of concrete (0.5 to 2.0 pcu/(hr)(ft)(°C))
- natural convection heat transfer coefficient (0.122 $\Delta t^{0.333}$ to 0.366 $\Delta t^{0.333}$ pcu/(hr)(ft²)(°C))
- emissivity of both concrete and process piping (0.5 to 0.8),
- reactor power at time of postulated accident (2000 to 3000 MW)

CG 15.5

UNCLASSIFIED

XXXXXXXXXXXXXXXXXXXX
XXXXXXXXXXXXXXXXXXXX
XXXXXXXXXXXXXXXXXXXX
XXXXXXXXXXXXXXXXXXXX
~~CONFIDENTIAL~~

UNCLASSIFIED

XXXXXXXXXXXXXXXXXXXX
SECRET
XXXXXXXXXXXXXXXXXXXX
XXXXXXXXXXXXXXXXXXXX
XXXXXXXXXXXXXXXXXXXX

The reactor power was the only variable to affect significantly the time at which the lava would flow to the floor; at 3000 MW, the time was 15 minutes, and at 2000 MW, the time was 30 minutes. Other parameters affected the time only about one minute.

Maximum exhaust air temperatures were affected noticeably by variations in several of the parameters. One of the most significant effects was the mass flow of air. Temperatures of 530 and 180°C were calculated for mass flows of 10,000 and 90,000 cfm from the below-grade areas, respectively.

A decrease in the inlet air temperature from 40 to 10°C resulted in a decrease in exhaust air temperature from 260 to 235°C. The calculated air temperature increased from about 230 to 290°C when the effective building surface area was increased from 20,000 to 40,000 ft². The thermal conductivity of the concrete walls is also significant. Variations of from 0.5 to 2.0 pcu/(hr)(ft)(°C) decreased the air temperature from 260°C down to 175°C.

The type of fuel in the reactor also affects the exhaust air temperature. More decay heat is generated for a uranium metal charge than for a uranium-aluminum alloy charge because of the decay of ²³⁹Np. The higher melting temperature of uranium metal and the larger fraction of uranium in the molten metal would also cause an earlier penetration of the process piping.

Parameters that had little effect on the air temperature included the emissivity of both the stainless steel piping and the concrete walls, and the effective surface area of the stainless steel piping for heat transfer. The insensitivity of the calculated air temperature as a function of pipe area indicates that the distribution of the fuel among the six outlet systems is relatively unimportant.

Although the convective heat transfer coefficient is significant in determining the air temperature for large surfaces, this coefficient is basically affected only by the air velocity and the temperature difference between the surface and the air. Calculations indicate that the mean velocity of the air in the process areas has an insignificant effect on the coefficient. Therefore, the coefficient would be controlled by the temperature difference between the surface involved and the bulk exhaust air.

Effect of Air Temperature on Methyl Iodide Formation

At high temperatures, the conversion of elemental iodine to methyl iodide increases rapidly. Based on the method in References

UNCLASSIFIED

XXXXXXXXXXXXXXXXXXXX
SECRET
XXXXXXXXXXXXXXXXXXXX
XXXXXXXXXXXXXXXXXXXX

CONFIDENTIAL

6 and 7, the amount of methyl iodide that could be formed during the postulated accident, with no light water addition, is less than 0.1% of the reactor inventory of iodine. This is a factor of 10^3 to 10^4 greater than would be expected if light water were added immediately after the fuel melted. Most of the iodine would be released early in the course of the core meltdown. Therefore, methyl iodide formation would be greatly suppressed because exhaust air temperature would be low.

Effect of Air Temperature on the Activity Confinement System

No deterioration of any component in the activity confinement system would be expected below 150°C .^{6,7} At about 150°C , deterioration of gaskets and adhesive on the moisture separators, particulate filters, and activated carbon beds could begin. Also the binder in the particulate filters could begin to deteriorate. However, the efficiency of the filters would not be affected significantly because:

- Significant deterioration would not occur until after most of the fission products were confined.
- All components of the filters are self-extinguishing.
- The strength of the filter is adequate to resist damage under these accident conditions without binder.
- Underwriters Laboratory tests showed that damage to the filters is negligible below 370°C .

In ignition tests of a full-size prototype of an SRP activated carbon bed, the neoprene gaskets were not significantly damaged by exposure to an air flow of 70 ft/min at 280°C for 35 minutes.

The rate of iodine desorption from activated carbon is a function of temperature, air velocity, iodine loading, bed depth, moisture content, and service history. Experiments at SRL showed that more iodine was desorbed from used carbon than from new carbon. The used carbon had been in service for 45 months and had been regenerated by passing air through the bed at 60°C for 48 hours. To test desorption, air at 140°C was passed through the bed for ~5 hours. The iodine desorbed was ~0.2% for the used carbon but less than 0.001% for the new carbon. The carbon in both experiments was Type 416, a product of Barnebey-Cheney Company. Tests at SRL to measure desorption over a wide range of temperature, iodine loading, service, moisture content, and air flow are part of a continuing program related to capability of the SRP confinement system.

CONFIDENTIAL

UNCLASSIFIED

XXXXXXXXXXXXXXXXXXXX
SECRET
XXXXXXXXXXXXXXXXXXXX
XXXXXXXXXXXXXXXXXXXX
XXXXXXXXXXXXXXXXXXXX

If the exhaust air were ~250°C for a sustained period of time, the exhaust fan motors would approach their rated limit of 90°C. Heat is transferred to the motors primarily by convection from the fan casing; however, compensating cool air is drawn into the rooms through "blast gates" immediately upstream of the fans. Belts used to drive the fans would deteriorate after several hours under these adverse conditions.

At about 340°C, ignition of the activated carbon beds would be expected. This is the measured ignition temperature of new Type 416 carbon in stainless steel at 65 ft/min face velocity. The ignition temperature of Type 416 carbon increases with service.⁸

Heat Removal from Potential Water Sources at the -40 ft Level

Although neglected in the analyses previously described, water would most likely be present at the -40 ft level, which would provide partial cooling of the molten fuel mass. The potential sources include:

- shield cooling water systems,
- D₂O process pump cooling water systems,
- D₂O or H₂O cooling water systems,
- miscellaneous H₂O piping, and
- the proposed confinement heat removal system.²

If a reactor lost its primary coolant and the emergency cooling system failed, the core would melt down. The proposed confinement heat removal system is designed to cool the molten debris that would result from this postulated accident. The design includes two below-grade spray systems, each with a cooling water header with nozzles for spraying water on three reactor effluent lines and on the floor of the monitor-pin room beneath the reactor (see Figure 16). The sprays will be automatically actuated by heat-sensing devices requiring no external power.

The water from the sprays will collect on the floor of the below-grade areas, where it will provide cooling for any fuel that melts through the reactor structure or effluent piping. Thus, the system should perform its function regardless of the accuracy of the analysis of molten fuel behavior and the extent of damage within the reactor building. The system requires no external power or human intervention and, except for the fusible heat sensors, can be easily tested. Its presence will create no significant new reactor hazards.



XXXXXXXXXXXXXXXXXXXX
SECRET
XXXXXXXXXXXXXXXXXXXX
XXXXXXXXXXXXXXXXXXXX

UNCLASSIFIED
CONFIDENTIAL

XXXXXXXXXXXXXXXXXXXX
XXXXXXXXXXXXXXXXXXXX
XXXXXXXXXXXXXXXXXXXX
XXXXXXXXXXXXXXXXXXXX
XXXXXXXXXXXXXXXXXXXX

In addition, the existing reactor-room spray system is available as a supplement to the proposed below-grade spray systems. The reactor-room spray is manually actuated, and this spray water (2000 gpm) will also flow to (and be contained in) the below-grade area of the reactor building.


The occurrence of a major meltdown accident without rupture of several light-water lines is highly improbable because of the proximity of the molten debris to these lines. Failure of either the top or bottom shield would contribute the inventory of the shield cooling system plus a continuous flow of about 30 gpm from the automatic make-up. Failure of the thermal shield coolant system also would be likely at the -40 ft level, because the pumps for this system are located adjacent to the D₂O process pumps. Rupture of the thermal shield would provide the inventory in this system plus 30 gpm make-up flow.

Each of the six D₂O process pumps is equipped with a light-water cooler for the seals with a normal flow of 5 gpm each. The pump rooms are also equipped with water supplies for general purposes such as cleaning. In addition to the water from the ruptured light-water lines, D₂O from the reactor process system would be present in the vicinity of the molten fuel.

Hence, a minimum of about 100 gpm light-water flow plus the inventory would be expected from destruction of the systems listed above. Vaporization of this water could remove about half of the decay heat being generated by the time the debris reaches the floor of the pump rooms and all of the decay heat within 10 hours after the accident. Vaporization of 100 gpm of water would not adversely affect the activity confinement system as indicated by tests under far more stringent conditions.⁶

ADDITION OF LIGHT WATER AFTER CORE MELTDOWN

Because of the potential for steam explosions and chemical reactions if water is added to molten metal, a detailed review and analysis of the consequences of molten metal and water interactions was made. A steam explosion results from the extremely rapid generation of steam associated with rapid contact of molten metal and water. A metal-water reaction is a chemical reaction caused by the interaction of hot metal (usually molten) and steam. This chemical reaction produces heat and hydrogen. The hydrogen could explode or burn, and the heat of reaction would add to the total energy of the system. The sequences of potential metal-water interactions are shown schematically in Figure 17. The consequences of steam explosions and metal-water reactions in the reactor building following a loss-of-coolant accident have been studied and are discussed in detail in the following sections.



XXXXXXXXXXXXXXXXXXXX
XXXXXXXXXXXXXXXXXXXX
XXXXXXXXXXXXXXXXXXXX
XXXXXXXXXXXXXXXXXXXX

MOI




FIG. 17 ACCIDENT FLOWSHEET-LIGHT WATER ADDED AFTER MELTING

UNCLASSIFIED
XXXXXXXXXXXXXXXXXXXX
XXXXXXXXXXXXXXXXXXXX
XXXXSECRETXXXXXX
XXXXXXXXXXXXXXXXXXXX

CONFIDENTIAL

Mechanisms of Interaction

STEAM EXPLOSIONS

Damaging steam explosions caused by molten metal in contact with water have occurred in several industries.^{9,10} The mechanisms and conditions necessary for steam explosions by molten metal falling into a pool of water have been studied by Long,¹¹ Hess and Brondyke,¹² and Brauer.¹³

Long concluded from some 880 experiments that explosive forces are created by the entrapment of a very thin layer of water at the bottom surface of the water pool. An initial explosion disperses the small molten particles throughout the water so that rapid vaporization of the water is possible because of the increased metal surface area.

Long observed that:

- Explosions occurred when the depth of the water was between 3 inches and 10 inches. No explosions occurred with depths between 20 inches and 30 inches probably because the metal was cooled before it reached the bottom of the container. With depths less than 2 inches, the metal was simply blown out of the container. The depth of water necessary to cause an explosion depended slightly on the metal temperature. Lateral dimensions were found to influence the magnitude of the explosion. Explosions in containers 48 inches square were milder than in containers 24 inches square.
- Explosions occurred only when the metal was initially molten.
- Explosions occurred when the metal fell 1-1/2 to 4 ft into water. No explosions occurred when the metal drop was 10 ft, probably because the metal was cooled during the vertical drop.
- Coatings of paint or grease on the container bottom prevented explosions.
- Soluble oils and wetting agents prevented explosions, but sodium chloride seemed to enhance explosions.

Brauer¹³ proposed a mechanism similar to that used by Long except for the method of trapping water. Brauer suggests that water is trapped in the molten metal as it falls through the water, not necessarily trapped under the metal as it strikes the floor.



UNCLASSIFIED
XXXXXXXXXXXXXXXXXXXX
XXXXXXXXXXXXXXXXXXXX
XXXXXXXXXXXXXXXXXXXX
XXXXXXXXXXXXXXXXXXXX
CONFIDENTIAL

~~SECRET~~
UNCLASSIFIED

XXXXXXXXXXXXXXXXXXXXX
XXXXXXXXXXXXXXXXXXXXX
XXXXXXXXXXXXXXXXXXXXX
XXXXXXXXXXXXXXXXXXXXX

Steam explosions caused by high pressure water striking a pool of molten metal have been studied at TRW Systems.¹⁴ Tests were run in which a column of water, supported by a thin diaphragm, was placed above a pool of molten aluminum in a vacuum. The diaphragm was punctured, and the water impacted the molten metal, with the water surface parallel to the metal surface. This caused the initial fragmentation of the metal. Peak pressures of ~3000 psi were measured. In the SRP system, water would fall by gravity from the plenum to the molten fuel in the reactor tank. All the water and fuel would not impact simultaneously with parallel surfaces. Without simultaneous impaction, the water that reaches the molten metal initially would cushion the main impact and produce a much lower disruptive force. Hence, the peak pressure associated with the metal-water interaction would be much less severe than in the TRW controlled tests.


Based on the results of investigations reviewed, some arguments can be made pro and con concerning the probability of steam explosions. In the analyses presented in the following sections, it is assumed that any metal-water interaction with a probability of causing an explosion will cause an explosion. Calculations are made to determine the amount of energy in the molten fuel that could be converted to shock energy. The calculations are based on analyses of the SPERT-ID destructive tests and laboratory shock tube tests.^{14,15} Pressure pulses during the SPERT tests indicate that ~10% of the total thermal energy (sensible heat plus heat of fusion) of the molten metal (above 20°C) could be converted into high pressure steam to produce a shock wave.¹⁴ The SPERT-ID tests involved rapid and extensive in-core melting and vaporization of large amounts of fuel initiated by a prompt increase in power. These conditions would cause higher destructive pressures than in a slower loss-of-coolant accident where molten metal might fall into an open pool of water.¹⁴ Therefore, the 10% energy conversion factor used in the following analysis is considered to be conservative. The energy available for shock wave generation is related to that produced by an equivalent mass of TNT.³⁵ Overpressures are then calculated from the TNT values and compared with estimated shock pressures required for gross failure of various critical areas of the confinement system.

METAL-WATER REACTIONS

Metal-water reactions must be considered from two standpoints: 1) the total energy released to the system, and 2) the possibility and consequence of hydrogen explosions. The explosions may create large shock pressures similar to those caused by steam explosions. The rate and extent of these reactions are as follows with respect to loss of coolant accidents in SRP reactors:

UNCLASSIFIED

XXXXXXXXXXXXXXXXXXXXX
XXXXXXXXXXXXXXXXXXXXX
XXXXXXXXXXXXXXXXXXXXX
XXXXXXXXXXXXXXXXXXXXX



UNCLASSIFIED

XXXXXXXXXXXXXXXXXXXX
XXXXXXXXXXXXXXXXXXXX
XXXXXXXXXXXXXXXXXXXX
XXXXXXXXXXXXXXXXXXXX

Reaction Rate Equations. The reactions of specific concern at SRP are those of molten fuel and cladding with light water.

• Aluminum-Water. At high temperatures aluminum reacts with water according to the following equation:



The heat of reaction is 256 kcal/gram-mole of aluminum (above ~1100°C).

The reaction rate of aluminum and H₂O (steam) can be described by a cubic rate law between 800 and 1300°C and at one atmosphere pressure.

$$W^3 = 4.0 \times 10^9 t [\exp(-73,500/RT)]$$

where

W = metal reacted, mg/cm² of surface area (1 mg Al reacted forms 1.246 ml (STP) H₂)

t = time, min

R = gas constant, 1.987 cal/(mole)(°K)

T = temperature, °K

Within this temperature range, the reaction results in the formation of a protective oxide film. Between 1400 and 1600°C, the oxide film apparently disintegrates¹⁶ and the reaction follows a linear rate law:

$$W = 2.5 \times 10^6 t [\exp(-73,500/RT)]$$

Higgins and Schultz¹⁷ determined experimentally that below about 1170°C metal-water reactions are insignificant.

Above 1750°C, ignition of the aluminum in contact with steam or air can be expected.¹⁸ The aluminum is apparently vaporized and then reacts. The reaction product is a very fine aluminum oxide powder.

• Uranium-Water. At high temperatures, uranium reacts with steam according to the following equation:



XXXXXXXXXXXXXXXXXXXX
XXXXXXXXXXXXXXXXXXXX
XXXXXXXXXXXXXXXXXXXX
XXXXXXXXXXXXXXXXXXXX

UNCLASSIFIED

~~CONFIDENTIAL~~

UNCLASSIFIED
XXXXXXXXXXXXXXXXXXXX
SECRET
XXXXXXXXXXXXXXXXXXXX
XXXXXXXXXXXXXXXXXXXX

The heat of reaction is 142 kcal/gram-mole of uranium. Scott¹⁹ showed experimentally that at about 1200°C, almost all of the solid reaction product would be in the dioxide form. U₃O₈ would be expected only below 300°C.²⁰

Below 400°C, the reaction follows a linear rate, probably because the oxide formed on the surface is nearly colloidal. From 500 to at least 1600°C, the reaction follows a parabolic rate law.

The following equation²¹ was determined for 600 to 1200°C

$$V^2 = 1.95 \times 10^5 t [\exp(-18,600/RT)]$$

where

V = volume of hydrogen generated from the uranium-water reaction, ml(STP)/cm² of reaction area.

Between 1200 and 1600°C the activation energy is 25 to 30 kcal/mole and the reaction follows the equation:

$$V^2 = 8.69 \times 10^6 t [\exp(-30,000/RT)]$$

Rate Limiting Mechanisms. Metal-water reaction rates are controlled both by reaction rate laws discussed in the preceding paragraphs and by rate-limiting mechanisms. During a reactor accident the physical and chemical reactions are complex because of the interactions involved. The total time required for a given amount of the overall process to occur is the sum of the times required for each of the individual processes. The maximum rate that can be approached by the overall process is the rate of the slowest step.²²

Rate limiting mechanisms that affect metal-water reactions are (1) availability of steam, (2) thickness of oxide (reaction product) layer, and (3) the metal surface temperature. The previously discussed reaction rate equations are obtained from tests in which sufficient steam is present near the reacting surface. In the following analysis it is assumed that unlimited steam is available for the reaction. If only limited steam is available, the diffusion of steam to the surface could limit the reaction rate.

The reaction rates, as discussed previously, depend on the temperature at the metal-metal oxide interface and implicitly on the transport rate of the reactants to the reaction site. After a very short reaction time (on the order of milliseconds²³) a metal oxide layer is formed on the surface. After formation of the oxide layer, the reaction proceeds by diffusion of either the oxide ions or metal ions through this layer. The reaction rate

UNCLASSIFIED
~~CONFIDENTIAL~~

XXXXXXXXXXXXXXXXXXXX
SECRET
XXXXXXXXXXXXXXXXXXXX
XXXXXXXXXXXXXXXXXXXX

XXXXXXXXXXXXXXXXXXXXX
XXXXXXXXXXXXXXXXXXXXX
SECRET
XXXXXXXXXXXXXXXXXXXXX
XXXXXXXXXXXXXXXXXXXXX

depends on whether the oxide film adheres to the surface or whether it cracks and spalls off. As shown in Figure 18, after the initial reaction, the reaction rate is probably severely limited by this oxide layer.

Metal-water reactions are significant only at high temperature, generally at temperatures well above the melting point. To sustain a reaction, a high temperature environment must exist over a period of time. Heat generated in the metal by decay heating and by reaction must be greater than the heat losses to maintain the elevated temperature. Excessive water in the system could cool the metal and terminate the reaction.




FIG. 18 EFFECT OF METAL TEMPERATURE AND COMPOSITION ON METAL-WATER REACTION

XXXXXXXXXXXXXXXXXXXXX
XXXXXXXXXXXXXXXXXXXXX
SECRET
XXXXXXXXXXXXXXXXXXXXX
XXXXXXXXXXXXXXXXXXXXX

~~CONFIDENTIAL~~
UNCLASSIFIED

XXXXXXXXXXXXXXXXXXXX
XXXXXXXXXXXXXXXXXXXX
XXXXXXXXXXXXXXXXXXXX
XXXXXXXXXXXXXXXXXXXX

Extent of Metal-Water Reaction. The extent of the reaction (i.e., amount of energy released and hydrogen formed) is dependent upon the metal surface area in addition to the reaction rate as discussed in the preceding section. For significant reaction, the metal must be dispersed such that surface area is large. The breaking up of the molten metal into small fragments could occur following a steam explosion.

Hydrogen Combustion. Combustion of hydrogen generated by chemical reaction between water and molten metal is important for two reasons: burning could increase the temperature of the exhaust ventilation air, and damaging explosions could result. The exothermic heat of reaction is 5.6×10^4 pcu/lb-mole of hydrogen reacted. The molar quantity of hydrogen produced is equal to the steam consumed in the metal-water reaction.

A hydrogen mixture is flammable if the composition is within the "flammability limits". A combustible gas mixture has two limits of flammability, an upper limit and a lower one. Only when the composition is between these limits will the gaseous mixture burn or explode. For hydrogen-air mixtures the flammability range generally is quoted as between 4.1% and 74%, although some variation exists as a function of temperature, pressure, and dilution by a third component, such as steam. The flammability limits of hydrogen-air-steam mixtures are shown in Figure 19.

Exceedingly small energy inputs cause hydrogen ignition, particularly when the mixture is well within the flammability limits. If hydrogen is not ignited from an external source, hydrogen would be ignited when the temperature exceeded the spontaneous ignition temperature. This temperature depends on the concentration of hydrogen and steam.²⁴

In the following sections, hydrogen is assumed to exist in flammable mixtures if there is a possibility of a metal-water reaction. It is also assumed that a source of ignition is present. Because the minimum spontaneous ignition temperature is $\sim 520^\circ\text{C}$,²⁵ it is very unlikely that spontaneous ignition would occur.

Hydrogen Explosion Analysis. Based on the instantaneous combustion model of Moore,^{26,27} a maximum pressure of ~ 80 psig could be developed at the explosion site. An analysis based on the work of Brode²⁸ gave results which agreed well with those of Moore.

The maximum pressure is independent of the volume of the combustible mixture. Even though a large volume of hydrogen would have the same maximum pressure as a smaller volume, the larger volume mixture would cause a larger shock pressure at the wall because the attenuation distance would be less.

UNCLASSIFIED

~~CONFIDENTIAL~~

XXXXXXXXXXXXXXXXXXXX
XXXXXXXXXXXXXXXXXXXX
XXXXXXXXXXXXXXXXXXXX
XXXXXXXXXXXXXXXXXXXX

XXXXXXXXXXXXXXXXXXXXX
XXXXXXXXXXXXXXXXXXXXX
XXXXXXXXXXXXXXXXXXXXX
XXXXXXXXXXXXXXXXXXXXX
UNCLASSIFIED

The instantaneous combustion model was used to calculate hydrogen explosion pressures for ambient pressures near atmospheric for various hydrogen concentrations.²⁷ The calculations greatly overpredict shock pressures, taken from limited available data. All the calculations are based on zero steam content. Experiments and analysis indicate that the presence of steam in the reactor room would reduce the maximum shock pressures.²⁷ Pressures at various distances from the explosion site are predicted by geometric scaling laws.²⁹





FIG. 19 FLAMMABILITY LIMITS OF HYDROGEN-AIR-STEAM MIXTURES



Location and Degree of Interaction

BELOW GRADE

Possible steam explosions from molten metal falling into water below the reactor are calculated not to significantly damage the building structure or confinement system.² Explosions could occur when molten metal melts through the effluent piping and/or the bottom shield, and falls into water on the floor. Potential water sources are discussed in the section Heat Removal from Potential Water Sources at the -40 ft Level above.

The shock pressures in the below-grade areas are calculated assuming that:

- One reactor effluent pipe full of molten metal drops into water.
- The shock reflection from walls and floors is compensated by shock absorption in building equipment such as pipes and pumps.

The calculated energy in the shock wave is 2.5×10^5 pcu. The overpressures associated with this wave are ~140 psig at 15 ft, the approximate distance of the nearest concrete wall (Figure 15), 28 psig at 35 ft, and 14 psig at 50 ft.

Steam explosions could scatter a portion of the molten fuel over the walls and ceiling where no water is available for cooling. Only a slight increase in exhaust air temperature is expected because of the small amount of fuel involved, heat transfer into the concrete, and cooling by the water vapor in the air. The spray mist from the proposed confinement heat removal system will also offer cooling of the scattered fuel.²

The effects of metal-water reaction in the below-grade areas will be less severe than the steam explosions. The molten fuel either will be quenched as it falls in the large quantity of water on the floor or will cause a steam explosion. The molten fuel would be scattered over the walls and ceiling. In the former case, the metal is cooled and the reaction is quickly terminated. Some metal-water reaction is expected following a steam explosion while the metal is still hot, vapor is present in sufficient quantities, and the metal is greatly fragmented. The hydrogen produced in the metal-water reaction could cause an explosion. The explosive energy is calculated to be ~10% of the energy of a below grade steam explosion and the damage would be much less. Baker³² showed that hydrogen cannot be produced at rates sufficient to have the effects of a steam explosion.



Expected shock pressures and the estimated shock pressure to cause gross failure for several critical areas of the activity confinement system that may be damaged by these pressures are summarized in Table II and discussed in the following paragraphs.

TABLE II
Structural Limitations

	Max Expected Shock Pressure, psig ^a	Estimated Shock Pressure for Gross Failure, psig	Is Failure Acceptable? ^b
Discharge canal	~140	~400-900	No
Concrete walls and ceiling in below-grade areas	~140	~400-900	Yes
Concrete slabs above main heat exchangers	~12	~20-100	Marginal
Sheet metal exhaust ducts	~140	~1-2	Yes
Exhaust fan casings	<0.1	~1-2	No
Filter compartments	~0.2	~3	No

- a. These values are the result of improved calculations from DPST-68-546, Reference 2.
- b. If failure occurs, will the activity confinement system function as designed?

Discharge Canal. The wall that separates the discharge canal from the pump rooms would not be breached by a steam explosion. Gross failure or large cracks in the wall could cause major leakage of water from the disassembly basin and subsequent decreased cooling of spent fuel in the basin. Failure of the wall cannot be accepted. However, the maximum estimated shock pressure is ~140 psig at this wall that is reinforced concrete 7-ft thick. Pressures between 400 and 900 psig are estimated to be necessary to produce gross failure of walls that are reinforced concrete 5- to 7-ft-thick (based on data for 10-inch-thick walls³⁰).

In the event of a steam explosion, equipment such as pipes and valves can become missiles. Calculations of penetration distances in reinforced concrete (Reference 31) show that the missiles will not penetrate the disassembly basin wall. For calculational purposes, the missiles are assumed to be long heavy cylinders with ogive-shaped noses and are assumed to strike the

wall with normal incidence for maximum penetration. Actual missiles would probably be rough fragments that would strike the wall obliquely.

Concrete Walls and Ceiling in Below-Grade Areas. The shock pressure at the ceiling of the below-grade areas, approximately 35 ft from the source of the postulated explosion, is 28 psig. The maximum shock pressure at the 5-ft-thick walls of the pump rooms is ~140 psig. The ceiling of the below grade areas is the floor slab of the reactor room. Both shock pressures are less than the 400-900 psig required to cause gross damage. The external building structure will not be damaged because the major structural supports for the building are shielded from the postulated explosion site by the pump-room walls and ceiling.

Concrete Slabs Above Main Heat Exchangers. The concrete slabs that form the roof of the heat exchanger bays would not be displaced by a steam explosion. An estimated shock pressure of ~12 psig would be expected at this location. A pressure of ~20 to 100 psig is required to lift the 4 ft thick slabs which open directly to the atmosphere at ground level. Subatmospheric operation of the confinement system will not be impaired by a shock wave from a steam explosion because the slabs cannot be lifted a sufficient distance from their normal positions to cause improper reseating.

Exhaust Ducts. Some of the sheet metal ducts of the exhaust system in the below grade areas would collapse as a result of a steam explosion. Air ventilation from these areas would be reduced. However, the activity confinement system would not over-heat because of cooling obtained by air from above grade process areas. External ducts, which are reinforced concrete, would not be affected by a steam explosion because of their higher strength and distance from the source of the explosion.

Exhaust Fan Casings. Circulation of building air to the air-cleaning facilities and stack will not be impaired. A calculated pressure of <0.1 psig would be present in the exhaust fan casings because of the tortuous path the shock wave must travel. A shock pressure of ~1 to 2 psig would be required to damage the fan casings.

Filter Compartments. Estimated pressures of ~0.2 psig are expected in the filter compartment equipment. These pressures are well below the ~3 psig required to cause failure of the moisture separators and particulate filters.

REACTOR TANK

Steam explosions could be caused by water contacting molten fuel in the reactor tank if the emergency cooling water system was delayed until after fuel meltdown, but while the molten fuel was still in the reactor tank. Calculations show that possible steam explosions in the reactor tank will not significantly damage the building structure or confinement system. A steam explosion may cause failure of the bottom shield supports and displacement of the bottom shield downward into the pin room (Figure 3). The top shield, plenum, and forest would be moved upward, breaking the plenum skirt and roll anchors (Figures 20, 21, and 22). The plenum inlet lines would restrict the amount of motion. Except for negligible energy released to the reactor room through breaks in the plenum skirt, all the shock energy and the slower pressure buildup would be vented to the below-grade areas because the bottom shield is more likely to be damaged than the plenum. This energy will cause less extensive damage to the below-grade areas than that from a steam explosion occurring below-grade because the energy is directed downward into the pin room and is dissipated in the massive concrete walls and floor.

Instead of calculating shock pressures as was done for steam explosions in the below-grade areas, the energy to deform various reactor components is calculated, and this energy is compared to the total available energy. The assumptions made in this analysis are that:

- The total fuel inventory interacts with water.
- Half of shock energy is available to move and deform the bottom shield.
- Half of the shock energy is available to move and deform the top shield, plenum, and forest.
- 1% of the upward shock energy is transformed into kinetic energy.

The total shock energy, based on the assumptions, is calculated to be 2×10^9 ft-lbs force.

The concrete supporting structure underneath the edge of the bottom shield is estimated to fail at a static internal pressure of ~75 psig.³³ Because the explosion occurs in contact with the tank bottom, shock pressures above 1000 psig are expected in the bottom shield.¹⁴ Even though the structure could withstand dynamic stresses several times the static ultimate stress, this shock pressure would be sufficient to cause failure of the supporting structure. Hence, the bottom shield will come to rest in the pin room and the excess tank pressure will be vented below grade.

About 5×10^6 ft-lbs force of shock energy is transmitted radially to deform the walls of the reactor tank and side thermal shields. Radial deformation would collapse the annular gas spaces. Because of the short time of the pressure pulse, very little water would be vented during the explosion.

The remainder of the shock energy (50% of total shock energy) is transmitted upward through air in the reactor vessel. Conservative calculations based on momentum-energy considerations and analysis by other investigators.^{34, 35} show that 1% of the energy in the upward traveling shock wave is transmitted from the air to the top shield, plenum, and forest in the form of kinetic energy. The other 99% of this shock energy is dissipated by distortion of the reactor upper structure and by reflection of the shock wave downward. Thus, the top components are given a kinetic energy of 10^7 ft-lbs force.

The top shield is given a sudden upward velocity. As soon as upward movement begins, the seal at the edge of the plenum (plenum skirt) is broken (Figure 20) and any pressure behind the shock front is released to the reactor room, if it has not already been released by failure of the bottom shield. Further upward movement breaks the roll anchors (Figure 21). The shield would not jam within the upper section of the tank even though all the roll anchors probably do not fail simultaneously. An analysis showed that, even though jamming is possible from a geometrical standpoint, the necessary unbalance of forces on the top shield for jamming cannot exist.³³ As the plenum-shield-forest system moves upward, it is restrained by the plenum inlet piping. Calculations, conservatively based on having only 3 inlet pipes intact, show that these pipes can absorb up to 2×10^7 ft-lbs force of energy by plastic deformation. The calculations are based on a 7% maximum elongation of the stainless-steel plenum pipes and an average dynamic stress of 50,000 psi.^{34, 35} The total energy in the top components (10^7 ft-lbs force) is less than that required to make the inlet piping fail. Therefore, the upper portion of the reactor would remain intact and no damage would occur above grade. Even if all the shock energy were projected upward (no energy released to the bottom shield), the upper portion of the reactor probably would remain intact and the results would not be changed significantly.

Metal-water reactions in the reactor tank would cause negligible hydrogen burning or explosions. Prior to melting of the cladding, the reaction rate would be very small because of the relatively low temperature as discussed previously. The sequence of events after melting is different for uranium-alloy charges and uranium metal charges as discussed in the following sections.

UNCLASSIFIED

~~CONFIDENTIAL~~

XXXXXXXXXXXXXXXXXXXX
XXXXXXXXXXXXXXXXXXXX
SECRET
XXXXXXXXXXXXXXXXXXXX
XXXXXXXXXXXXXXXXXXXX




FIG. 20 REACTOR PLENUM SKIRT

UNCLASSIFIED

XXXXXXXXXXXXXXXXXXXX
XXXXXXXXXXXXXXXXXXXX
SECRET
XXXXXXXXXXXXXXXXXXXX
XXXXXXXXXXXXXXXXXXXX

~~CONFIDENTIAL~~

XXXXXXXXXXXXXXXXXXXX
XXXXXXXXXXXXXXXXXXXX
XXXXXXXXXXXXXXXXXXXX
XXXXXXXXXXXXXXXXXXXX




FIG. 21 PLENUM INLET ROLL ANCHOR

~~CONFIDENTIAL~~




FIG. 22 ACTUATOR GUIDE TUBE FOREST



XXXXXXXXXXXXXXXXXXXXX
XXXXXXXXXXXXXXXXXXXXX
XXXXXXXXXXXXXXXXXXXXX
XXXXXXXXXXXXXXXXXXXXX


Uranium-Alloy Charges. Above $\sim 660^{\circ}\text{C}$ the cladding and fuel would melt and fall to the bottom of the tank. In P or K reactor it is assumed that no water would be available for cooling, and the molten metal would form a large pool at the bottom. Figure 6 shows the bottom of the tank. The surface area of the molten pool would be insufficient to cause extensive metal-water reaction. In C reactor, a 15-inch depth of water would remain after a loss-of-coolant accident (see Figure 7). The aluminum cladding and fuel would melt at $\sim 660^{\circ}\text{C}$ and fall into the water, forming steam. No significant steam explosions would be expected because of the small amount of cladding involved and because the cladding would fall into the water over an extended period of time. Any explosions would be expected to scatter the molten fuel over the walls of the tank. Even though the surface area could be greatly enhanced, the extent of the reaction would be small because the molten particles would quickly fall back into the water and be quenched.

Uranium Metal Charges. The fuel slugs (~ 8 inches long) in uranium metal charges would be supported by the inner and outer housing tubes after the cladding melted. The housings would be heated primarily by the air in the tank and by conduction from the slugs. The slugs would fall to the bottom of the tank either after melting or after the housings melted. The uranium would not necessarily fall into water, even in C reactor. The uranium above water would be exposed to steam and a metal-water reaction could take place. Hydrogen from the metal-water reaction probably would not burn or explode inside the tank because the low oxygen content and high steam content in the tank would cause the mixture to be outside the limits of flammability (see Figure 19). However, if the hydrogen does explode or burn the resulting shock damage would be insignificant compared to the steam explosions.

ABOVE GRADE

The possibility exists for hydrogen from metal-water reactions in the reactor tank to escape to the reactor room (Figure 23) through breaks in the inlet piping and plenum skirt, and through the vacuum breakers and forest guide tubes. Explosive concentrations probably would exist in a very small volume because of rapid dilution by the ventilation system. The hydrogen explosion analysis is based on the explosion of a combustible mixture of hydrogen 20 ft in diameter on the reactor top. Calculations show that a maximum pressure of ~ 7 psig would be transmitted to the nearest concrete wall. The corresponding pressure in the filter compartments would be < 0.1 psig. These pressures are much less than the pressures necessary to cause damage as shown in Table II.

XXXXXXXXXXXXXXXXXXXXX
XXXXXXXXXXXXXXXXXXXXX
XXXXXXXXXXXXXXXXXXXXX
XXXXXXXXXXXXXXXXXXXXX



XXXXXXXXXXXXXXXXXXXX
XXXXXXXXXXXXXXXXXXXX
SECRET
XXXXXXXXXXXXXXXXXXXX
XXXXXXXXXXXXXXXXXXXX

Hydrogen explosion or steam surging in the reactor room could cause a momentary pressure surge that could result in some leakage of fission products from the building. Leakage would substantially increase at positive pressures of 12 inches of H₂O or more within the reactor room because of venting to the disassembly area. Actual release of fission products would be low because the pressure surge, although probably in excess of 12 inches of H₂O, would last only a few seconds, and because most of the fission products would have been released and drawn into the activity confinement system earlier.




FIG. 23 SAVANNAH RIVER REACTOR ROOM

XXXXXXXXXXXXXXXXXXXX
XXXXXXXXXXXXXXXXXXXX
SECRET
XXXXXXXXXXXXXXXXXXXX
XXXXXXXXXXXXXXXXXXXX



~~CONFIDENTIAL~~

UNCLASSIFIED

XXXXXXXXXXXXXXXXXXXX
XXXXXXXXXXXXXXXXXXXX
XXXXXXSECRETXXXXXXXX
XXXXXXXXXXXXXXXXXXXX

Results of Calculations

Steam explosions occurring in the below-grade areas and the reactor tank were calculated not to damage seriously the activity confinement system. The maximum expected shock pressures caused by a steam explosion in the below-grade areas and the estimated shock pressures required to cause gross failure of various structural components are shown in Table II. The energy from a steam explosion in the reactor tank would be dissipated in the tank and in the below-grade areas. Negligible energy would be released to the reactor room because the reactor upper structure is restrained by the plenum inlet piping. Steam explosions could not occur in the reactor room because of the absence of fuel.

Significant metal-water reactions could occur in the reactor tank. Hydrogen from this reaction could exist in explosive concentrations in the reactor room but the shock pressures from such explosions are not sufficient to cause damage to the activity confinement system. Although metal-water reactions could occur at the -40 ft level, they would be less significant than steam explosions.

SUBSEQUENT EFFECTS FROM CORE MELTDOWN

The preceding sections were concerned primarily with the short-term consequences of a core meltdown. Also vital to an analysis of this type is consideration of the capability to cope with problems which could arise during the ensuing days or weeks after the accident. Potential problems were identified and the subsequent effects were calculated. These problems would be largely associated with cooling water requirements, exhaust ventilation requirements, and water and debris disposition. Several miscellaneous items are also discussed in this section. The following discussion assumes that debris cooling is obtained primarily from the proposed confinement heat removal system.

Cooling Requirements for Debris

As discussed in Reference 2, a controlled volume of water from the proposed confinement heat removal system would be sprayed primarily on the effluent piping from the reactor vessel. Because of the limited surface area of the piping and the inaccessibility of some of the piping within the biological shield surrounding the vessel, total containment of the debris within the piping would be unlikely. However, several advantages are gained by this approach. First, local rather than gross melting of the piping would be more likely which would reduce the volume of lava. This would control the thermal energy available for conversion into shock pressures

~~CONFIDENTIAL~~
UNCLASSIFIED

~~CONFIDENTIAL~~

XXXXXXXXXXXXXXXXXXXX
XXXXXXXXXXXXXXXXXXXX
XXXXXXXXXXXXXXXXXXXX
XXXXXXXXXXXXXXXXXXXX

UNCLASSIFIED

XXXXXXXXXXXXXXXXXXXX
XXXXXXXXXXXXXXXXXXXX
XXXXXXXXXXXXXXXXXXXX
XXXXXXXXXXXXXXXXXXXX

~~CONFIDENTIAL~~

during possible steam explosions. Second, the heat absorbed by the spray would increase the temperature of the water which is reported to reduce the probability of a steam explosion.¹¹ Third, the time at which penetration of the effluent piping occurred would be delayed until a significant depth of water would be on the floor of the -40 ft level, which also could reduce the probability of a steam explosion.¹¹ Rapid flooding could achieve about the same depth at the time of debris penetration, but the smaller flows of the proposed system could be more easily controlled if the system were accidentally actuated. Although calculations show that the SRP confinement system could survive the effects of a steam explosion, reasonable steps to preclude or to reduce the consequences of such an explosion are desirable.

About 20 hours would be required to flood the below-grade areas of the C or K reactor building with the proposed confinement heat removal system. This is based on a flow from the above- and below-grade systems of 6000 gpm and a below-grade building volume of seven million gallons. In P reactor building, the below grade volume is about 13 million gallons; the flooding time for P reactor would be about twice that of the other buildings. After the building fills with water, flow would be stopped.² Even with gravity flow of 800 gpm to the confinement heat removal system, adequate debris cooling would be obtained and complete flooding of the C or K reactor building would be obtained in about one week.

Based on ground water seepage into the building, outleakage would be expected to be small; thus, only a very small fraction of the fission product inventory would penetrate to the surrounding earth. The concrete disassembly basins, which are adjacent to the -40 ft areas and contain over 3 million gallons of water, much of which is 30 ft in depth, experience negligible outleakage.

The average temperature of the water in C or K reactor building at 20 hours after meltdown would be about 40°C for peak summer conditions and about 25°C for winter. Decay heat generation is calculated to exceed heat removal into the ground for about 30 days after the accident. The excess heat would raise the water temperature to about 95°C for C or K reactor in about 30 days; cooling would then begin. In P reactor building, the maximum temperature is calculated to approach about 75°C. The heat loss calculations were based on an overall heat transfer coefficient of 1.0 pcu/(hr)(ft²)(°C) and an effective surface area of 40,000 ft² (approximate nominal area of floor and outer walls of below grade areas). If only half of the estimated heat transfer to the surroundings were obtained, boil-off of about 7 gpm is calculated to occur, decreasing to zero boiling in about one week.

XXXXXXXXXXXXXXXXXXXX
XXXXXXXXXXXXXXXXXXXX
XXXXXXXXXXXXXXXXXXXX
XXXXXXXXXXXXXXXXXXXX

UNCLASSIFIED

~~CONFIDENTIAL~~



~~CONFIDENTIAL~~

UNCLASSIFIED
XXXXXXXXXXXXXXXXXXXX
XXXXXXXXXXSECRETXXXX
XXXXXXXXXXXXXXXXXXXX
XXXXXXXXXXXXXXXXXXXX

Cooling Requirements for Carbon Beds

Operation of at least one of the three exhaust ventilation fans would be required for about 24 hours immediately following the accident to maintain the temperature of the carbon beds below 100°C. After that, sufficient cooling would be obtained by natural draft. Operation of at least one fan for much longer than the minimum requirement would be expected because of redundancies in the system.

The exhaust fans are centrifugal fans that are belt-driven by electric motors. These fans remove the air from the reactor room, purification area, and -20 ft and -40 ft levels, (Figures 24 and 25) through the filtration-adsorption compartments and discharge it into the exhaust stack. During normal operation, two exhaust fans are on-line (in parallel) and a third fan remains on standby. The two operating fans can move the rated flow of 128,000 cfm with a differential pressure of 5.9 inches H₂O. One fan can move 75,000 cfm. The fan suction pressure is normally -4 to -5 inches H₂O. The fan housings have a positive pressure rating of 10 inches H₂O (about 0.4 psig), but gross failure is unlikely at pressures below 1-2 psig.




FIG. 24 VENTILATION SYSTEM FOR -20 FT AND -40 FT LEVELS

~~CONFIDENTIAL~~

UNCLASSIFIED
~~CONFIDENTIAL~~

- 58 -
XXXXXXXXXXXXXXXXXXXX
XXXXXXXXXXSECRETXXXX
XXXXXXXXXXXXXXXXXXXX
XXXXXXXXXXXXXXXXXXXX

~~CONFIDENTIAL~~

XXXXXXXXXXXXXXXXXXXX
XXXXXXXXXXXXXXXXXXXX
SECRET
XXXXXXXXXXXXXXXXXXXX
XXXXXXXXXXXXXXXXXXXX
UNCLASSIFIED




FIG. 25. PROCESS AREA EXHAUST AIR SYSTEM

XXXXXXXXXXXXXXXXXXXX
SECRET
UNCLASSIFIED
XXXXXXXXXXXXXXXXXXXX
XXXXXXXXXXXXXXXXXXXX
~~CONFIDENTIAL~~

~~CONFIDENTIAL~~

XXXXXXXXXXXXXXXXXXXXX
XXXXXXXXXXXXXXXXXXXXX
XXXXXXXXXXXXXXXXXXXXX
XXXXXXXXXXXXXXXXXXXXX

UNCLASSIFIED

Each primary exhaust fan motor has two separate sources of AC power: the electrical distribution systems for the reactor building and the confinement substation. Either power source can be selected as the primary source. The systems are supplied by the area powerhouse (except for C reactor) and outside area powerhouses (D₂O-Production Area and South Carolina Electric and Gas Company). Emergency AC power is also provided to the reactor building distribution system by diesels that start automatically if normal power fails. Automatic switching between normal and emergency power supplies provides reliable power service to the fans.

In addition to the primary motors, each fan is equipped with a backup motor. Two diesel driven generators supply power directly and independently to any two of the backup motors. Power from these sources is used solely for the exhaust fan drive motors, and a 30-day fuel supply is available for the diesels.

Debris Configuration

Although considerable dispersion of the debris would be expected, the consequence of an accumulation of debris in an adverse configuration was examined. If a mound of material formed such that an outer shell of solid debris protected an inner core of liquid, interaction between the molten debris and concrete floor would be possible. Heat removal from a mound, however, would govern its size and shape. For a configuration with a relatively low surface-to-volume ratio, such as a hemisphere, and with a high volumetric heat generation rate, the surface heat flux could be in excess of the capacity to remove the heat by natural convection boiling. As a consequence, the material would tend to slump into a slab geometry with a larger surface-to-volume ratio and a lesser thickness. For C reactor, in which vessel melt-through was calculated to occur in one hour, a maximum slab thickness of about one foot with a surface area of about 250 ft² could be sustained with boiling from the top surface. After about 15 hours, the volumetric heat generation would have decreased enough that the debris would freeze through its entire thickness. In P or K reactor, melt-through would be more rapid than for C; therefore, the maximum thickness that could be sustained would be less. Complete freezing is calculated to occur in about 6 hours. Penetration of a significant depth of concrete floor, which contains granite aggregate, would not be expected over these relatively short time intervals.

In an unmoderated geometry, criticality within the debris regardless of location would not occur. Even a homogenous sphere of core debris under H₂O would not be critical; however, a sub-critical state cannot be guaranteed under all possible combinations.

UNCLASSIFIED

~~CONFIDENTIAL~~

XXXXXXXXXXXXXXXXXXXXX
XXXXXXXXXXXXXXXXXXXXX
XXXXXXXXXXXXXXXXXXXXX
XXXXXXXXXXXXXXXXXXXXX

~~CONFIDENTIAL~~

XXXXXXXXXXXXXXXXXXXX
XXXXXXXXXXXXXXXXXXXX
XXXXXXXXXXXXXXXXXXXX
XXXXXXXXXXXXXXXXXXXX

UNCLASSIFIED

of geometry, concentration, and moderation that could be postulated. Even though criticality is considered highly remote, such an occurrence would be unlikely to contribute significantly to either the energy of the system or the fission product inventory, but would serve to further disperse the debris within the confines of the below grade areas.

It is concluded that after about one day the remaining fission product inventory could be essentially confined within the reactor building and the filtration-adsorption compartments for an extended period of time with no further equipment operation or maintenance. Hence, the addition of further cooling would not be required and building overflow to the 50 million gallon retention basin would be unnecessary.

XXXXXXXXXXXXXXXXXXXX
XXXXXXXXXXXXXXXXXXXX
XXXXXXXXXXXXXXXXXXXX
XXXXXXXXXXXXXXXXXXXX

UNCLASSIFIED

~~CONFIDENTIAL~~



~~CONFIDENTIAL~~
UNCLASSIFIED

XXXXXXXXXXXXXXXXXXXX
XXXXXXXXXXXXXXXXXXXX
XXXXXXXXXXXXXXXXXXXX
XXXXXXXXXXXXXXXXXXXX

REFERENCES

1. W. S. Durant and R. J. Brown. *Analysis of Postulated Core Meltdown of an SRP Reactor*. SRL Report DPST-67-639 (1968) (Secret).
2. R. J. Brown. *Confinement Heat Removal System for the Savannah River Reactors*. SRL Report DPST-68-546 (1968) (Secret).
3. United States Steel Corp., Armco Steel Corp., and Lukens Steel Corp., personal communication (November 13, 1967).
4. P. K. Hilliard. *Oxidation of Uranium in Air at High Temperatures*. USAEC Report HW-58022, General Electric Co., Richland, Wash. (1958).
5. R. C. Milham and L. R. Jones. *Iodine and Noble Gas Retention Studies*. USAEC Report DP-1209, Savannah River Laboratory, E. I. du Pont de Nemours & Co., Aiken, S. C. (1969).
6. W. S. Durant, et al. *Activity Confinement System of the Savannah River Plant Reactors*. SRL Report DPST-66-300 (1966) (Secret).
7. W. S. Durant, et al. *Activity Confinement System of the Savannah River Plant Reactors*. USAEC Report DP-1071, Savannah River Laboratory, E. I. du Pont de Nemours & Co., Aiken, S. C. (1966).
8. R. C. Milham. *High Temperature Adsorbents for Iodine - Progress Report: January 1965-September 1966*. USAEC Report DP-1075, Savannah River Laboratory, E. I. du Pont de Nemours & Co., Aiken, S. C. (1966).
9. *Emergency Core Cooling*. Report of Advisory Task Force on Power Reactor Emergency Cooling. USAEC Division of Technical Information Extension, Oak Ridge, Tenn. (1966).
10. S. G. Lipsett. "Explosions from Molten Materials and Water." *Fire Technology* 2(2), 118 (1966).
11. G. Long. "Explosions of Molten Aluminum in Water - Cause and Prevention." *Metal Progress* 71(5), 107 (1957).
12. P. D. Hess and K. J. Brondyke. "Cause of Molten Aluminum-Water Explosions and Their Prevention." *Metal Progress* 83(4), 93 (1969).

UNCLASSIFIED

~~CONFIDENTIAL~~

XXXXXXXXXXXXXXXXXXXX
XXXXXXXXXXXXXXXXXXXX
XXXXXXXXXXXXXXXXXXXX
XXXXXXXXXXXXXXXXXXXX

XXXXXXXXXXXXXXXXXXXXX
XXXXXXXXXXXXXXXXXXXXX
SECRET
XXXXXXXXXXXXXXXXXXXXX
XXXXXXXXXXXXXXXXXXXXX

- 13. F. E. Brauer, et al. "Metal/Water Explosions." *Nuclear Science and Engineering* 31(3), 551 (1968).
- 14. *Kinetic Studies of Heterogeneous Water Reactors - 1964. Annual Summary Report - 1964.* USAEC Report STL-372-50. TRW Space Technology Laboratories, Inc., Redondo Beach, Calif. (1964).
- 15. *Chemical Engineering Division Semiannual Report.* USAEC Report ANL-6900, pp 270-280, Argonne National Laboratory, Argonne, Ill. (1964).
- 16. W. F. Zelezny. *Metal-Water Reactions: Rates of Reaction of Aluminum and Aluminum-Uranium Alloys with Water Vapor at Elevated Temperatures.* USAEC Report IDO-16629, Phillips Petroleum Company, Idaho Falls, Idaho (1960).
- 17. H. M. Higgins and R. D. Schultz. *The Reaction of Metals with Water and Oxidizing Gases at High Temperatures.* USAEC Report IDO-28000, Aerojet General Corp., Azusa, Calif. (1957).
- 18. R. O. Ivins and R. Koonz. "Study of the Combustion of Aluminum in Water." *Chemical Engineering Division Semiannual Report, July-December 1963.* USAEC Report ANL-6800, pp 338-341, Argonne National Laboratory, Argonne, Ill. (1964).
- 19. A. J. Scott. *Fission Product Release by the High Temperature Uranium-Steam Reaction.* USAEC Report HW-62603, General Electric Co., Richland, Wash. (1959).
- 20. R. K. Hilliard. *Oxidation of Uranium in Air at High Temperatures.* USAEC Report HW-58022, General Electric Co., Richland Wash. (1958).
- 21. R. E. Wilson and C. Barnes. "Isothermal Studies of the Uranium-Steam Reaction by the Volumetric Method." *Chemical Engineering Division Semiannual Report, July-December 1963.* USAEC Report ANL-6800, pp 330-335, Argonne National Laboratory, Argonne, Ill. (1964).
- 22. S. E. Jensen. *Effects of Metal-Water Reactions on the Loss-of-Coolant Accident.* USAEC Report IDO-17168, Phillips Petroleum Co., Idaho Falls, Idaho (1966).
- 23. L. F. Epstein. *Metal-Water Reactions: VII. Reactor Safety Aspects of Metal Water Reactions.* GEAP-3335, General Electric Company, Pleasanton, Calif. (1960).
- 24. J. G. Moore and E. V. Gilby. *A review of the Problems Arriving from the Combustion of Hydrogen in a Water Reactor Containment.* AHSB(S)R101, United Kingdom Atomic Energy Authority, London, England (1966).

XXXXXXXXXXXXXXXXXXXXX
XXXXXXXXXXXXXXXXXXXXX
SECRET
XXXXXXXXXXXXXXXXXXXXX
XXXXXXXXXXXXXXXXXXXXX

UNCLASSIFIED

~~CONFIDENTIAL~~

25. Z. M. Shapiro and T. R. Moffette. *Hydrogen Flammability Data and Application to PWR Loss-of-Coolant Accident*. USAEC Report WAPD-SC-545, Westinghouse Electric Corp., Pittsburg, Pa. (1957).
26. J. G. Moore. "The Formation of Shock Waves from the Combustion of Gaseous Mixtures with Special Consideration of the Sodium-Air Reaction." *Nuclear Engineering and Design* 3, 320 (1966).
27. J. G. Moore and E. V. Gilby. *A Review of the Problems Arising from the Combustion of Hydrogen in a Water Reactor Containment*. AHSB(S)R101, United Kingdom Atomic Energy Authority, London, England (1966).
28. H. L. Brode. "The Numerical Solution of Spherical Blast Waves." *J. Applied Physics* 26(6), 766 (1955).
29. S. Glasstone (ed). *The Effects of Nuclear Weapons*. U. S. Atomic Energy Commission (1962).
30. *Studies in Atomic Defense Engineering*. NAVDOCKS P-290 Department of the Navy, Bureau of Yards and Docks, Washington 25, D. C. (1962).
31. R. C. Gwaltney. *Missile Generation and Protection in Light-Water-Cooled Power Reactor Plants*. USAEC Report ORNL-NSIC-22, Oak Ridge National Laboratory, Oak Ridge, Tenn. (1968).
32. L. Baker. "Metal-Water Reactions." *Nuclear Safety* 7(1), 75 (1965).
33. R. H. Cornwell to J. B. Tinker, J. A. List. *Containment Incident Analysis: Investigation of Main Tank Stresses*. Du Pont Engineering Department Report DPE-2162 (1962) (Secret).
34. J. F. Proctor. "Explosion Containment for Nuclear Reactor Vessels." *Nuclear Safety* 7(4), 459 (1966).
35. R. W. Wise and J. F. Proctor. *Explosion Containment Laws for Nuclear Reactor Vessels*. NOLTR 63-140, United States Naval Ordnance Laboratory, White Oak, Maryland (1965).
36. A. N. Holden. *Physical Metallurgy of Uranium*. Addison-Wesley Publishing Co., Reading, Mass. (1958).

UNCLASSIFIED

~~CONFIDENTIAL~~


~~CONFIDENTIAL~~

UNCLASSIFIED
XXXXXXXXXXXXXXXXXXXX
XXXXXXXXXXXXXXXXXXXX
XXXXXXXXSECRETXXXXX
XXXXXXXXXXXXXXXXXXXX

APPENDIX A
LAVA COMPUTER CODE

XXXXXXXXSECRETXXXXX
XXXXXXXXXXXXXXXXXXXX
XXXXXXXXXXXXXXXXXXXX

UNCLASSIFIED
~~CONFIDENTIAL~~



UNCLASSIFIED

~~CONFIDENTIAL~~

XXXXXXXXXXXXXXXXXXXXX
XXXXXXXXXXXXXXXXXXXXX
XXXXXXXXXXXXXXXXXXXXX
XXXXXXXXXXXXXXXXXXXXX

* T I D Y *

LAVA LAVA

C
C
C
C
C
C
C

LAVA LAVA

AN ANALYSIS OF TRANSIENT HEAT TRANSFER IN THE REACTOR BUILDING
FOLLOWING A DESIGN BASIS ACCIDENT

***** ***** ***** ***** ***** ***** *****

DIMENSION QFU001(999), QRAD(999), QCONV2(999), AFLO(999), QFLOR1(999),
IQESCAP(999)

READ (5,330) TFUEL1,WFUEL,CFUEL,TSYS, AKMET, AMET, WMET, TMET1, XMET, TA
1IR1, TWALL1, EPS1, EPS2, WWALL, CWALL, XWALL, AWALL, AKWALL, CAIR, WAIR, CMET
2, QCONV1, TSYS1, TSYS2, TMET4, TWALL0, TWALL3, COF, PO, AKFUEL, TAIR2, TAIR4,
3FAT, AFLOOR, EPS3, ZAP, ABSFU, ABSMET, DENFU, DENMET, HF, HFMET, TFUELM

C

READ (5,340) NQFU
READ (5,350) {QFU001(I), I=1, NQFU}
READ (5,360) QRAD(1)
READ (5,370) QCONV2(1)
WRITE (6,380)
WRITE (6,390)
WRITE (6,400)
WRITE (6,410) TFUELM
WRITE (6,420) WAIR
WRITE (6,430) TSYS
WRITE (6,440) WFUEL
WRITE (6,450) WMET
WRITE (6,460) AMET
WRITE (6,470) EPS1
WRITE (6,480) EPS2
WRITE (6,490) AWALL
WRITE (6,500) AKWALL
WRITE (6,510) COF
WRITE (6,520) PO
WRITE (6,530)
WRITE (6,540)

C

CALCULATE ENERGY STORED IN FUEL AS FUSION HEAT
HFUS=HF*WFUEL

C

CALCULATE HEAT IN FUEL AT TIME FUEL MELTING BEGINS
QFUEL=WFUEL*CFUEL*(TFUEL1-TSYS)

C

ENTER MASTER-DO LOOP FOR FUEL CONTAINED IN PIPING. UNLESS
OTHERWISE NOTED CALCULATIONS ARE FOR ONE MINUTE INCREMENTS.
TIME 0 INDICATES START OF INCREMENT, 1/2 INDICATES MIDDLE
OF INCREMENT, AND 1 INDICATES END OF INCREMENT

C

DO 160 I=1, NQFU
NTIME=I

C

INITIALIZE SUBROUTINES FOR TRANSIENT CONDUCTION IN CONCRETE

C

A1000
A1001
A1002
A1003
A1004
A1005
A1006
A1007
A1008
A1009
A1010
A1011
A1012
A1013
A1014
A1015
A1016
A1017
A1018
A1019
A1020
A1021
A1022
A1023
A1024
A1025
A1026
A1027
A1028
A1029
A1030
A1031
A1032
A1033
A1034
A1035
A1036
A1037
A1038
A1039
A1040
A1041
A1042
A1043
A1044
A1045
A1046
A1047
A1048
A1049



XXXXXXXXXXXXXXXXXXXXX
XXXXXXXXXXXXXXXXXXXXX
XXXXXXXXXXXXXXXXXXXXX
XXXXXXXXXXXXXXXXXXXXX

UNCLASSIFIED ~~CONFIDENTIAL~~

~~SECRET~~

UNCLASSIFIED

XXXXXXXXXXXXXXXXXXXX
XXXXXXXXXXXXXXXXXXXX
XXXXXXXXXXXXXXXXXXXX

* T I D Y *

LAVA LAVA

C	CALL COND(QWALL1,TWALL1,NTIME,0)	A1050
C	CALL COND(QFLORA,TLAVA5,NTIME,0)	A1051
C	CALL BOND(QWALL1,TWALL1,NTIME,0)	A1052
C		A1053
C	CALCULATE HEAT IN FUEL AT TIME 1 WITH NO HEAT LOSS, EQUATE	A1054
C	HEAT AT TIME 0 TO TIME 1	A1055
C	QFUEL2=QFUEL+(QFU001(I)*PO)	A1056
C	QFUEL=QFUEL2	A1057
C		A1058
C	CALCULATE GAMMA ESCAPE FROM FUEL CONTAINED IN EFFLUENT PIPING	A1059
C	AMU=20.3*ABSFU	A1060
C	CALL GETOUT(AMU,PCC)	A1061
C	TOPIPE=QFU001(I)*PD*(1.0-PCC)*0.5	A1062
C		A1063
C	CALCULATE GAMMA ATTENUATION BY EFFLUENT PIPING	A1064
C	GONE=TOPIPE/EXP(0.57*XMET*61.0)	A1065
C	SOAKED=TOPIPE-GONE	A1066
C		A1067
C	LOOP A	A1068
C		A1069
C	CALCULATE AVERAGE FUEL TEMPERATURE AT TIME 1 WITH NO HEAT LOSS	A1070
C	TFUEL2=(QFUEL/(WFUEL*CFUEL))+TSYS	A1071
C	IF (TFUEL2.GE.TFUELM) GO TO 110	A1072
C		A1073
C	CALCULATE ENERGY STORED AS HEAT OF FUSION, THEN RECALCULATE	A1074
C	FUEL TEMPERATURE AT TIME 1	A1075
C	QAVAIL=WFUEL*CFUEL*(TFUEL2-TSYS)+HFUS	A1076
C	TFUEL2=(QAVAIL/(WFUEL*CFUEL))+TSYS	A1077
C	IF (TFUEL2.LT.TFUELM) GO TO 110	A1078
C	QSENS=WFUEL*CFUEL*(TFUEL2-TSYS)	A1079
C	QFUSE=QAVAIL-QSENS	A1080
C	IF (QFUSE.LE.HFUS) TFUEL2=TFUEL2	A1081
C	IF (QFUSE.LE.HFUS) GO TO 110	A1082
C	HLEFT=QFUSE-HFUS	A1083
C	TFUEL2=(HLEFT/(WFUEL*CFUEL))+TFUEL2	A1084
C		A1085
C	CALCULATE FUEL-PIPE INTERFACE TEMPERATURE	A1086
C	DELT=QFUEL*7.5E-6	A1087
C	TFUEL4=TFUEL2-(DELT/2.0)	A1088
C		A1089
C	CALCULATE HEAT STORED IN PIPE WITH HEAT LOSS DURING 1 TIME	A1090
C	INCREMENT, AVERAGE PIPE TEMPERATURES AT TIMES 1 AND 0	A1091
C	QMET1=((AKMET*((TFUEL1+TFUEL4)/2.0)-TMET1)*AMET/XMET)/60.0)-QCO	A1092
C	INVI-QRAD(I)+SOAKED	A1093
C	TMET2=(QMET1/(WMET*CMET))+TSYS1	A1094
C	TMET3=(TMET2+TSYS1)/2.0	A1095
C		A1096
C	CALCULATE HEAT IN FUEL AND FUEL TEMPERATURE AT TIME 1 WITH	A1097
C	HEAT LOSS	A1098
C	QFUEL3=QFUEL2-QMET1-QCONVI-QRAD(I)-GONE	A1099

~~SECRET~~
UNCLASSIFIED

XXXXXXXXXXXXXXXXXXXX
XXXXXXXXXXXXXXXXXXXX
XXXXXXXXXXXXXXXXXXXX
XXXXXXXXXXXXXXXXXXXX

* T I D Y *

LAVA LAVA

	TFUEL3=(QFUEL3/(WFUEL*CFUEL))+TSYS	A1100
	IF (TFUEL3.GE.TFUELM) GO TO 120	A1101
C		A1102
C	CALCULATE ENERGY STORED AS HEAT OF FUSION, THEN RECALCULATE	A1103
C	FUEL TEMPERATURE AT TIME 1	A1104
	QAVAIL=WFUEL*CFUEL*(TFUEL3-TSYS)+HFUS	A1105
	TFUEL3=(QAVAIL/(WFUEL*CFUEL))+TSYS	A1106
	IF (TFUEL3.LT.TFUELM) GO TO 120	A1107
	QSENS=WFUEL*CFUEL*(TFUELM-TSYS)	A1108
	QFUSE=QAVAIL-QSENS	A1109
	IF (QFUSE.LE.HFUS) TFUEL3=TFUELM	A1110
	IF (TFUEL4.GT.2020.0) GO TO 170	A1111
	IF (QFUSE.LE.HFUS) GO TO 120	A1112
	HLEFT=QFUSE-HFUS	A1113
	TFUEL3=(HLEFT/(WFUEL*CFUEL))+TFUEL3	A1114
120	TMET1=TMET3	A1115
	QFUEL=(QFUEL3+QFUEL)/2.0	A1116
C	TEST FOR GOODNESS OF FUEL TEMPERATURE AT TIME 1. ITERATE TO	A1117
C	LOOP A BASED ON RECALCULATED HEAT IN FUEL IF NECESSARY	A1118
	IF (ABS(TFUEL3-TFUEL2).GT.0.5) GO TO 130	A1119
C		A1120
C	CALCULATE SURFACE TEMPERATURE OF PIPE AND AVERAGE TEMPERATURE	A1121
C	OF AIR AT TIME 1/2	A1122
	TSURF=TMET3-(((TFUEL1+TFUEL4)/2.0)-TMET3)	A1123
	IF (TSURF.LT.TSYS) TSURF=TSYS	A1124
	TAIR2=(TAIR2+TAIR4)/2.0	A1125
C		A1126
C	CALCULATE HEAT LOST FROM PIPE BY NATURAL CONVECTION	A1127
	XX=TSURF-TAIR2	A1128
	QCONV1=(COF*(ABS(XX))**0.333*AMET*(XX))/60.0	A1129
C		A1130
C	CALCULATE HEAT LOST FROM PIPE BY THERMAL RADIATION TO WALLS	A1131
C	AND FLOOR	A1132
	RR=(TSURF+460.0)**4.0	A1133
	RS=(TWALL1+460.0)**4.0	A1134
	QRAD(1)=1.73E-9*EPS1*AMET*(RR-RS)/60.0	A1135
C		A1136
C	CALCULATE HEAT CONTENT AND AVERAGE TEMPERATURE OF PIPE	A1137
C	CONSIDERING CONDUCTION FROM FUEL, GAMMA ATENUATION, CONVECTION	A1138
C	TO AIR AND THERMAL RADIATION TO WALLS AND FLOOR AT TIME 1	A1139
	QMET2=((AKMET*AMET*(((TFUEL1+TFUEL4)/2.0)-TMET1)/XMET)/60.0)-QCONV1	A1140
	1-QRAD(1)+SOAKED	A1141
	QMET2=(QMET2+QMET1)/2.0	A1142
	TMET5=(QMET2/(WMET*CMET))+TSYS1	A1143
	TMET1=(TMET5+TSYS1)/2.0	A1144
C		A1145
C	CALCULATE HEAT CONTENT OF FUEL CONSIDERING HEAT LOST TO PIPE	A1146
C	AND ENVIRONMENT AT TIME 1	A1147
	QFUEL4=QFUEL2-QMET2-QCONV1-QRAD(1)-GONE	A1148
	QFUEL=(QFUEL4+QFUEL)/2	A1149

XXXXXXXXXXXXXXXXXXXX
XXXXXXXXXXXXXXXXXXXX
XXXXXXXXXXXXXXXXXXXX
XXXXXXXXXXXXXXXXXXXX

~~CONFIDENTIAL~~
UNCLASSIFIED
XXXXXXXXXXXXXXXXXXXX
XXXXXXXXXXXXXXXXXXXX
SECRET
XXXXXXXXXXXXXXXXXXXX
XXXXXXXXXXXXXXXXXXXX

FTI D Y *
LAVA LAVA

TEST FOR GOODNESS OF PIPE TEMPERATURE AT TIME I. ITERATE TO
LOOP A BASED ON RECALCULATED HEAT IN FUEL IF NECESSARY
IF (ABS(TMET2-TMET5).GT.2.0) GO TO 100

SUM HEAT TRANSFERRED TO WALLS AND FLOOR BY THERMAL RADIATION
RSUM=0.0
DO 130 J=1,NTIME
RSUM=RSUM+QRAD(J)
CONTINUE

SUM HEAT TRANSFERRED FROM WALLS AND FLOOR BY NATURAL
CONVECTION
CSUM=0.0
DO 140 J=1,NTIME
CSUM=CSUM+QCONV2(J)
CONTINUE

CALCULATE HEAT CONTENT OF WALLS AND FLOOR BASED ON THERMAL
RADIATION TO WALLS AND FLOOR, NATURAL CONVECTION FROM WALLS
AND FLOOR, AND GAMMA RADIATION TO WALLS AND FLOOR AT TIME I
QWALL1=RSUM-CSUM+GONE

CALCULATE SURFACE TEMPERATURE OF WALLS AND FLOOR FROM
TRANSIENT CONDUCTION SUBROUTINE AT TIME I
L=1
CALL COND(QWALL1,TWALLA,NTIME,L)
TWALL2=TWALLA

CALCULATE HEAT TRANSFERRED FROM WALLS AND FLOOR BY NATURAL
CONVECTION
QCONV2(I)=(COF*(ABS((((TWALL2+TWALL3)/2)+TWALLO)/2)-TAIR2))**0.33
13*AWALL*(((TWALL2+TWALL3)/2)+TWALLO)/2)-TAIR2)/60.0

SUM HEAT TRANSFERRED FROM WALLS AND FLOOR BY NATURAL
CONVECTION
CSUM=0.0
DO 150 J=1,NTIME
CSUM=CSUM+QCONV2(J)
CONTINUE

CALCULATE HEAT CONTENT OF WALLS AND FLOOR BASED ON THERMAL
RADIATION TO WALLS AND FLOOR, NATURAL CONVECTION FROM WALLS
AND FLOOR, AND GAMMA RADIATION TO WALLS AND FLOOR AT TIME I
QWALL2=RSUM-CSUM+GONE

CALCULATE SURFACE TEMPERATURE OF WALLS AND FLOOR FROM
TRANSIENT CONDUCTION SUBROUTINE AT TIME I
L=1
CALL COND(QWALL2,TWALLC,NTIME,L)

A1150
A1151
A1152
A1153
A1154
A1155
A1156
A1157
A1158
A1159
A1160
A1161
A1162
A1163
A1164
A1165
A1166
A1167
A1168
A1169
A1170
A1171
A1172
A1173
A1174
A1175
A1176
A1177
A1178
A1179
A1180
A1181
A1182
A1183
A1184
A1185
A1186
A1187
A1188
A1189
A1190
A1191
A1192
A1193
A1194
A1195
A1196
A1197
A1198
A1199

UNCLASSIFIED
XXXXXXXXXXXXXXXXXXXX
XXXXXXXXXXXXXXXXXXXX
SECRET
XXXXXXXXXXXXXXXXXXXX
XXXXXXXXXXXXXXXXXXXX
~~CONFIDENTIAL~~

~~CONFIDENTIAL~~ UNCLASSIFIED

XXXXXXXXXXXXXXXXXXXXX
XXXXXXXXXXXXXXXXXXXXX
SECRET
XXXXXXXXXXXXXXXXXXXXX
XXXXXXXXXXXXXXXXXXXXX

* T I D Y *

LAVA LAVA

TWALL3=TWALLC
TWALL1=(((TWALL2+TWALL3)/2)+TWALL1)/2

A1200
A1201

C TEST FOR GOODNESS OF WALL AND FLOOR TEMPERATURE AT TIME 1.
C ITERATE TO LOOP A IF NECESSARY
C IF (TWALL3-TWALL2.GT.2.0.OR.TWALL2-TWALL3.GT.2.0) GO TO 100

A1202
A1203
A1204
A1205

C CALCULATE HEAT CONTENT AND TEMPERATURE OF AIR AT TIME 1
C QAIR2=QCONV1+QCONV2(I)

A1206
A1207
A1208

C TAIR3=(QAIR2/(WAIR*CAIR))+TSYS
C IF (TAIR3.LT.100.0) TAIR3=100.0
C QAIR2=WAIR*CAIR*(TAIR3-TSYS)

A1209
A1210
A1211
A1212

C TAIR4=(TAIR3+TAIR1)/2.0

A1213
A1214

C TEST FOR GOODNESS OF AIR TEMPERATURE AT TIME 1/2. ITERATE
C TO LOOP A IF NECESSARY

A1215
A1216
A1217

C IF (TAIR4-TAIR2.GT.2.0.OR.TAIR2-TAIR4.GT.2.0) GO TO 100
C WRITE (6,550) NTIME,TFUEL3,TMET3,TWALL3,TAIR3,TSURF,TFUEL4,QFU001
C (I)

A1218
A1219
A1220

C RESTATE VARIABLES FOR SECOND TIME INCREMENT

A1221

TFUEL1=TFUEL4
TAIR1=TAIR3
TSYS1=TMET5
TMET4=TMET3
TWALLO=TWALL3
TWALL1=TWALL3
TSYS2=TWALL3
TMET1=TMET3

A1222
A1223
A1224
A1225
A1226
A1227
A1228
A1229

C IF THE TEMPERATURE OF THE FUEL AT THE FUEL-PIPE INTERFACE
C EXCEEDS THE MELTING POINT OF THE FUEL, THE PIPE IS ASSUMED TO
C COLLAPSE BECAUSE OF INTERACTION OF URANIUM AND STAINLESS
C STEEL

A1230
A1231
A1232
A1233
A1234

C IF (TFUEL4.GT.TFUELMI) GO TO 170
C QRAD(I+1)=QRAD(I)
C QCONV2(I+1)=QCONV2(I)
C CONTINUE

A1235
A1236
A1237
A1238

160 C AT THIS CONDITION THE PIPES COLLAPSE

A1239
A1240

C WRITE (6,560)
C WRITE (6,570)
C WRITE (6,580)

A1241
A1242
A1243
A1244

C CALCULATE HEAT IN LAVA AT TIME OF PIPE COLLAPSE
C QLAVA=WFUEL*CFUEL*(TFUEL3-TSYS)+WMET*CMET*(TMET3-TSYS)

A1245
A1246
A1247
A1248

C A1249

UNCLASSIFIED - 70 -

XXXXXXXXXXXXXXXXXXXXX
SECRET
XXXXXXXXXXXXXXXXXXXXX
XXXXXXXXXXXXXXXXXXXXX

~~CONFIDENTIAL~~

XXXXXXXXXXXXXXXXXXXX
XXXXXXXXXXXXXXXXXXXX
SECRET
XXXXXXXXXXXXXXXXXXXX

UNCLASSIFIED

* T I D Y *

LAVA LAVA

	KKK=NNN	A1300
	IF (KKK.GT.1) AFLO(K)=AFLO(K-1)	A1301
	IF (KKK.GT.1) GO TO 190	A1302
	AFLO(K)=AFLOOR	A1303
C		A1304
C	CALCULATE TEMPERATURE OF LAVA AT TIME 0	A1305
190	TLAVA=(QLAVA/((WFUEL*CFUEL)+(WMET*CMET)))+TSYS	A1306
	IF (TLAVA.GE.ZAP) GO TO 200	A1307
C		A1308
C	CALCULATE ENERGY STORED AS HEAT OF FUSION, THEN RECALCULATE	A1309
C	LAVA TEMPERATURE AT TIME 0	A1310
	QAVAIL=(WFUEL*CFUEL+WMET*CMET)*(TLAVA-TSYS)+HFUSL	A1311
	TLAVA=(QAVAIL/(WFUEL*CFUEL+WMET*CMET))+TSYS	A1312
	IF (TLAVA.LT.ZAP) GO TO 200	A1313
	QSENS=(WFUEL*CFUEL+WMET*CMET)*(TLAVA-TSYS)	A1314
	QFUSE=QAVAIL-QSENS	A1315
	IF (QFUSE.LE.HFUSL) TLAVA=ZAP	A1316
	IF (QFUSE.LE.HFUSL) GO TO 200	A1317
	HLEFT=QFUSE-HFUSL	A1318
	TLAVA=(HLEFT/(WFUEL*CFUEL+WMET*CMET))+TLAVA	A1319
200	QRAC(K)=0.0	A1320
	QFLOR2=0.0	A1321
	QOXIDE=0.0	A1322
	QCONV1=0.0	A1323
	TLAVA4=0.0	A1324
	KKKK=0	A1325
C		A1326
C	CALCULATE THICKNESS OF LAVA ON FLOOR ASSUMING FLOOR COMPLETELY	A1327
C	COVERED	A1328
	THICK=((WFUEL/DENFU)+(WMET/DENMET))/AFLO(K)	A1329
C		A1330
C	CALCULATE GAMMA ESCAPE FROM LAVA	A1331
	BMU=(THICK*30.48/2.0)*ABSMIX	A1332
	CALL ESCAPE(BMU,PC)	A1333
	RETAIN=1.0-((1.0-PC)/2.0)	A1334
C		A1335
C	CALCULATE HEAT IN FUEL WITH CONSIDERATION TO HEAT LOSSES AT	A1336
C	TIME 1	A1337
	QLAVA2=QLAVA+QFU001(KI)*PO*RETAIN-QRAC(K)-QCONV1-QFLOR2+QOXIDE	A1338
	QLAVA=QLAVA2	A1339
C	LOOP B	A1340
210	NNN=KKK+1	A1341
C		A1342
C	CALCULATE TEMPERATURE OF LAVA AT TIME 1	A1343
	TLAVA2=(QLAVA/((WFUEL*CFUEL)+(WMET*CMET)))+TSYS	A1344
	IF (TLAVA2.GE.ZAP) GO TO 220	A1345
C		A1346
C	CALCULATE ENERGY STORED AS HEAT OF FUSION, THEN RECALCULATE	A1347
C	LAVA TEMPERATURE AT TIME 1	A1348
	QAVAIL=(WFUEL*CFUEL+WMET*CMET)*(TLAVA2-TSYS)+HFUSL	A1349



UNCLASSIFIED

~~CONFIDENTIAL~~

XXXXXXXXXXXXXXXXXXXX
XXXXXXXXXXXXXXXXXXXX
SECRET
XXXXXXXXXXXXXXXXXXXX

XXXXXXXXXXXXXXXXXXXX
XXXXXXXXXXXXXXXXXXXX
SECRETXXXXXXXXXXXX
XXXXXXXXXXXXXXXXXXXX

~~CONFIDENTIAL~~
UNCLASSIFIED

* T I D Y *

LAVA LAVA

TLAVA2=(QAVAIL/(WFUEL*CFUEL+WMET*CMET))+TSYS A1350
IF (TLAVA2.LT.ZAP) GO TO 220 A1351
QSENS=(WFUEL*CFUEL+WMET*CMET)*(TLAVA2-TSYS) A1352
QFUSE=QAVAIL-QSENS A1353
IF (QFUSE.LE.HFUSL) TLAVA2=ZAP A1354
IF (QFUSE.LE.HFUSL) GO TO 220 A1355
HLEFT=QFUSE-HFUSL A1356
TLAVA2=(HLEFT/(WFUEL*CFUEL+WMET*CMET))*TLAVA2 A1357
A1358
ESTIMATE FLOOR AREA COVERED BY LAVA A1359
220 AFLO(K)=AFLOOR*(1.0-0.002*KKKK) A1360
IF (AFLO(K).LT.AFLO(K-1)) AFLO(K)=AFLO(K-1) A1361
IF (KKKK.EQ.0) GO TO 230 A1362
IF (TLAVA4.GT.ZAP) GO TO 240 A1363
A1364
CALCULATE SURFACE TEMPERATURE OF LAVA FROM AVERAGE TEMPERATURE A1365
AND GRADIENT THROUGH THICKNESS AT TIME 1 A1366
230 DELT1=QFU001(K)*PO*SQ.0*RETAIN*((WFUEL/DENFU)+(WMET/DENMET))/(2.0* A1367
1AFLO(K)**2.0/(AKFUEL+AKMET) A1368
140 TLAVA4=(TLAVA2+TLAVA)/2.0 A1369
TLAVA5=TLAVA4-(DELT1/2.0) A1370
TAIR2=(TAIR2+TAIR4)/2.0 A1371
YY=TLAVA5-TAIR2 A1372
A1373
CALCULATE HEAT TRANSFERRED FROM LAVA BY NATURAL CONVECTION A1374
QCONV1=(COF*(ABS(YY))**0.333*AFLO(K)*YY)/60.0 A1375
TLAVA5=(TLAVA5-32.0)/1.8 A1376
A1377
CALCULATE HEAT GENERATION IN LAVA FROM SURFACE OXIDATION A1378
TOX1=TLAVA5 A1379
TOX2=TLAVA5 A1380
IF (TOX1.LT.1000.0) TOX1=1000.0 A1381
IF (TOX2.GT.1200.0) TOX2=1200.0 A1382
C1=EXP(0.00346*TOX1-0.79) A1383
C2=(0.00218*TOX2-1.0)*(AFLO(K)/WFUEL)*2.04 A1384
QOXIDE=(AFLO(K)/2.0)*C1*(2.71**C2)*1.8 A1385
TLAVA5=TLAVA5*1.8+32.0 A1386
A1387
CALCULATE HEAT TRANSFERRED FROM LAVA BY THERMAL RADIATION A1388
TR=(TLAVA5+460.0)**4.0 A1389
TS=(TWALL1+460.0)**4.0 A1390
QRAD(K)=1.73E-9*8R*AFLO(K)*(TR-TS)/60.0 A1391
A1392
CALCULATE ENERGY TRANSFERRED FROM LAVA TO FLOOR BY GAMMA A1393
ESCAPE A1394
QESCAP(K)=(QFU001(K)*PO*(1.0-RETAIN))/2.0 A1395
A1396
CALCULATE HEAT TRANSFERRED INTO FLOOR FROM TRANSIENT A1397
CONDUCTION SUBROUTINE A1398
L=2 A1399

XXXXXXXXXXXXXXXXXXXX
SECRETXXXXXXXXXXXX
XXXXXXXXXXXXXXXXXXXX
XXXXXXXXXXXXXXXXXXXX

~~CONFIDENTIAL~~
UNCLASSIFIED

~~CONFIDENTIAL~~

~~CONFIDENTIAL~~
UNCLASSIFIED

XXXXXXXXXXXXXXXXXXXXX
XXXXXXXXXXXXXXXXXXXXX
XXXXXXXXXXXXXXXXXXXXX
XXXXXXXXXXXXXXXXXXXXX

* T I D Y *

LAVA LAVA

```
CALL COND1(QFLORA, TLAVA5, LTIME, L)
QFLOR1(K)=QFLORA
FAT=AFLO(K)/AFLOOR
QFLOR2=(QFLOR1(K)-QFLOR1(K-1))*FAT+QESCAP(K)
IF (KKK.EQ.1) GO TO 260
C
C      CALCULATE HEAT TRANSFERRED INTO FLOOR DURING ONE TIME
C      INCREMENT
N=K-KTIME+1
QFLOR2=0.0
DO 250 M=1, N
  L8=K-M
  L7=K-N+M
  QFLOR2=QFLOR2+(QFLOR1(L8+1)-QFLOR1(L8))*((AFLO(L7)-AFLO(L7-1))/AFLOOR)
250 CONTINUE
C
C      CALCULATE HEAT CONTENT AND TEMPERATURE AT TIME 1 OF LAVA
C      CONSIDERING HEAT LOSSES AND GAINS
260 QLAVA3=QLAVA2-QCONV1-QRAD(K)-QFLOR2+QOXIDE+QESCAP(K)
  TLAVA3=(QLAVA3/((WFUEL*CFUEL)+(WMET*CMET)))+TSYS
  IF (TLAVA3.GE.ZAP) GO TO 270
C
C      CALCULATE ENERGY STORED AS HEAT OF FUSION, THEN RECALCULATE
C      LAVA TEMPERATURE
QAVAIL=(WFUEL*CFUEL+WMET*CMET)*(TLAVA3-TSYS)+HFUSL
TLAVA3=(QAVAIL/(WFUEL*CFUEL+WMET*CMET))+TSYS
IF (TLAVA3.LT.ZAP) GO TO 270
QSENS=(WFUEL*CFUEL+WMET*CMET)*(TLAVA3-TSYS)
QFUSE=QAVAIL-QSENS
IF (QFUSE.LE.HFUSL) TLAVA3=ZAP
IF (QFUSE.LE.HFUSL) GO TO 270
HLEFT=QFUSE-HFUSL
TLAVA3=(HLEFT/(WFUEL*CFUEL+WMET*CMET))+TLAVA3
270 TLAVA6=TLAVA3-(DELT1/2.0)
  IF (AFLO(K).GT.AFLOOR) AFLO(K)=AFLOOR
  QLAVA=QLAVA3
C
C      TEST FOR GOODNESS OF LAVA TEMPERATURE AT TIME 1. ITERATE TO
C      LOOP 8 IF NECESSARY
IF (ABS(TLAVA3-TLAVA2).GT.2.0) GO TO 210
IF (TLAVA6.LT.ZAP) KKKK=K+1
IF (AFLO(K).EQ.AFLO(K-1)) GO TO 280
IF (TLAVA5.LT.ZAP) GO TO 210
C
C      SUM HEAT TRANSFERRED TO WALLS BY THERMAL RADIATION AND GAMMA
C      ESCAPE
280 RSUM=RSUMP8
  DO 290 J=KTIME, K
  RSUM=RSUM+QRAD(J)+QESCAP(J)
```

A1400
A1401
A1402
A1403
A1404
A1405
A1406
A1407
A1408
A1409
A1410
A1411
A1412
A1413
A1414
A1415
A1416
A1417
A1418
A1419
A1420
A1421
A1422
A1423
A1424
A1425
A1426
A1427
A1428
A1429
A1430
A1431
A1432
A1433
A1434
A1435
A1436
A1437
A1438
A1439
A1440
A1441
A1442
A1443
A1444
A1445
A1446
A1447
A1448
A1449

~~CONFIDENTIAL~~
UNCLASSIFIED

- 74 -
XXXXXXXXXXXXXXXXXXXXX
XXXXXXXXXXXXXXXXXXXXX
XXXXXXXXXXXXXXXXXXXXX
XXXXXXXXXXXXXXXXXXXXX

UNCLASSIFIED

~~CONFIDENTIAL~~

XXXXXXXXXXXXXXXXXXXX
XXXXXXXXXXXXXXXXXXXX
XXXXXXXXXXXXXXXXXXXX
XXXXXXXXXXXXXXXXXXXX

* T I D Y *

. LAVA LAVA

90 CONTINUE

A1450

SUM HEAT TRANSFERRED FROM WALLS BY NATURAL CONVECTION

A1451

CSUM=CSUMPB

A1452

DO 300 J=KTIME,K

A1453

CSUM=CSUM+QCONV2(J)

A1454

CONTINUE

A1455

A1456

CALCULATE HEAT CONTENT AND SURFACE TEMPERATURE OF WALLS AT TIME 1

A1457

QWALL1=RSUM-CSUM

A1458

L=1

A1459

CALL BOND(QWALL1,TWALLA,LTIME,L)

A1460

TWALL2=TWALLA

A1461

CALCULATE HEAT TRANSFERRED FROM WALLS BY NATURAL CONVECTION

A1462

QCONV2(K)=(COF*(ABS((((TWALL2+TWALL3)/2.0)+TWALL0)/2.0)-TAIR2))**
10.333*(AWALL-AFLO(K))*((((TWALL2+TWALL3)/2.0)+TWALL0)/2.0)-TAIR2
2)/60.0

A1463

A1464

A1465

A1466

A1467

A1468

A1469

SUM HEAT TRANSFERRED FROM WALLS BY NATURAL CONVECTION

A1470

CSUM=CSUMPB

A1471

DO 310 J=KTIME,K

A1472

CSUM=CSUM+QCONV2(J)

A1473

CONTINUE

A1474

A1475

CALCULATE HEAT CONTENT AND SURFACE TEMPERATURE OF WALLS AT TIME 1/2

A1476

QWALL2=RSUM-CSUM

A1477

L=1

A1478

CALL BOND(QWALL2,TWALLC,LTIME,L)

A1479

TWALL3=TWALLC

A1480

TWALL1=((TWALL2+TWALL3)/2)+TWALL1)/2.0

A1481

A1482

A1483

TEST FOR GOODNESS OF WALL SURFACE TEMPERATURE AT TIME 1.

A1484

ITERATE TO LOOP B IF NECESSARY

A1485

IF (ABS(TWALL3-TWALL2).GT.2.0) GO TO 210

A1486

A1487

CALCULATE HEAT CONTENT AND TEMPERATURE OF AIR AT TIME 1

A1488

QAIR2=QCONV1+QCONV2(K)

A1489

TAIR3=(QAIR2/(WAIR*CAIR))+TSYS

A1490

IF (TAIR3.LT.100.0) TAIR3=100.0

A1491

QAIR2=WAIR*CAIR*(TAIR3-TSYS)

A1492

TAIR4=(TAIR3+TAIR1)/2.0

A1493

A1494

TEST FOR GOODNESS OF AIR TEMPERATURE AT TIME 1/2. ITERATE TO LOOP B IF NECESSARY

A1495

IF (ABS(TAIR4-TAIR2).GT.2.0) GO TO 210

A1496

A1497

A1498

WRITE (6,690) LTIME,TLAVA3,TLAVA6,AFLO(K),TWALL3,TAIR3,QFU001(K),Q

A1499



XXXXXXXXXXXXXXXXXXXX
XXXXXXXXXXXXXXXXXXXX
XXXXXXXXXXXXXXXXXXXX
XXXXXXXXXXXXXXXXXXXX

UNCLASSIFIED

~~CONFIDENTIAL~~

~~CONFIDENTIAL~~

XXXXXXXXXXXXXXXXXXXXX
XXXXXXXXXXXXXXXXXXXXX
XXXXXXXXXXXXXXXXXXXXX
XXXXXXXXXXXXXXXXXXXXX

UNCLASSIFIED

* T I D Y *

LAVA LAVA

1OXIDE,QCONV1,QFLOR2,QRAD(K)

A1500
A1501
A1502
A1503
A1504
A1505
A1506
A1507
A1508
A1509
A1510
A1511
A1512
A1513
A1514
A1515
A1516
A1517
A1518
A1519
A1520
A1521
A1522
A1523
A1524
A1525
A1526
A1527
A1528
A1529
A1530
A1531
A1532
A1533
A1534
A1535
A1536
A1537
A1538
A1539
A1540
A1541
A1542
A1543
A1544
A1545
A1546
A1547
A1548
A1549

C
C

RESTATE VARIABLES FOR SECOND TIME INCREMENT

TWALLO=TWALL3
TWALL1=TWALL3
QRAD(K+1)=QRAD(K)
QCONV2(K+1)=QCONV2(K)
TAIR1=TAIR3

320

CONTINUE
STOP

C

330 FORMAT (7F10.5)
340 FORMAT (I3)
350 FORMAT (7F10.5)
360 FORMAT (F10.5)
370 FORMAT (F10.5)
380 FORMAT (I4)
390 FORMAT (45X,'LAVA - OR THE CREEPING HEAP'///)
400 FORMAT (25X,'INPUT INFORMATION'///)
410 FORMAT (5X,'MELTING TEMPERATURE OF FUEL',3X,F10.1/)
420 FORMAT (5X,'MASS OF AIR FROM -40',24X,F10.1/)
430 FORMAT (5X,'TEMPERATURE OF AMBIENT SYSTEM',14X,F10.1/)
440 FORMAT (5X,'EFFECTIVE MASS OF CORE',22X,F10.1/)
450 FORMAT (5X,'EFFECTIVE MASS OF EFFLUENT PIPING AND PUMPS',1X,F10.1/
1)
460 FORMAT (5X,'EFFECTIVE AREA OF EFFLUENT PIPING AND PUMPS',1X,F10.1/
1)
470 FORMAT (5X,'EMISSIVITY OF EFFLUENT PIPING AND PUMPS',5X,F10.1/)
480 FORMAT (5X,'EMISSIVITY OF CONCRETE WALLS AT -40',9X,F10.1/)
490 FORMAT (5X,'EFFECTIVE SURFACE AREA OF CONCRETE WALLS',4X,F10.1/)
500 FORMAT (5X,'THERMAL CONDUCTIVITY OF CONCRETE',12X,F10.1/)
510 FORMAT (5X,'COEFFICIENT FOR CONVECTION EQUATION',9X,F10.1/)
520 FORMAT (5X,'RELATIVE HEAT GENERATION',20X,F10.1/)
530 FORMAT (25X,'OUTPUT INFORMATION'///)
540 FORMAT (5X,'TIME FUEL TEMP AVG PIPE TEMP CONCRETE WALL
1 TEMP AIR TEMP PIPE SURFACE TEMP INTERFACE TEMP HE
2AT IN'///)
550 FORMAT (3X,I3,5X,F10.1,5X,F10.1,11X,F10.1,8X,F10.1,7X,F10.1,12X,F1
10.1,4X,F10.1/)
560 FORMAT (I4)
570 FORMAT (2X,'AT THIS CONDITION THE PIPE COLLAPSES'///)
580 FORMAT (25X,'INPUT INFORMATION'///)
590 FORMAT (5X,'FLOOR AREA AT -40',27X,F10.1/)
600 FORMAT (5X,'MELTING TEMPERATURE OF LAVA',17X,F10.1/)
610 FORMAT (5X,'LINEAR ABSORPTION COEF OF FUEL',14X,F10.5/)
620 FORMAT (5X,'LINEAR ABSORPTION COEF OF STAINLESS STEEL',3X,F10.5/)
630 FORMAT (5X,'DENSITY OF FUEL',29X,F10.5/)
640 FORMAT (5X,'DENSITY OF STAINLESS STEEL',18X,F10.5/)
650 FORMAT (5X,'MASS OF STEEL IN LAVA',23X,F10.1/)
660 FORMAT (5X,'EMISSIVITY OF DEBRIS',24X,F10.1/)

~~CONFIDENTIAL~~

UNCLASSIFIED

~~CONFIDENTIAL~~

XXXXXXXXXXXXXXXXXXXXX
XXXXXXXXXXXXXXXXXXXXX
XXXXXXXXXXXXXXXXXXXXX
XXXXXXXXXXXXXXXXXXXXX

XXXXXXXXXXXXXXXXXXXX UNCLASSIFIED
XXXXXXXXXXXXXXXXXXXX
SECRET
XXXXXXXXXXXXXXXXXXXX

D Y *

LAVA LAVA

70	FORMAT (25X, 'OUTPUT INFORMATION'//)	A1550
80	FORMAT (3X, 'TIME AVG LAVA TEMP LAVA SURF TEMP LAVA AREA WALL T	A1551
	TEMP AIR TEMP HEAT IN HEAT OXID HEAT CONV HEAT COND HE	A1552
	2AT RAD'//)	A1553
90	FORMAT (3X, I4, 5X, F10.1, 6X, F10.1, F11.1, F11.1, F10.1, 2X, F10.1, 2X, F10.	A1554
	11, 2X, F10.1, 2X, F10.1, F11.1//)	A1555
	END	A1556-

XXXXXXXXXXXXXXXXXXXX
SECRET
XXXXXXXXXXXXXXXXXXXX
XXXXXXXXXXXXXXXXXXXX
XXXXXXXXXXXXXXXXXXXX




UNCLASSIFIED



* T I D Y *

UNSTEADY STATE HEAT TRANSFER INTO WALLS AND FLOOR

C	UNSTEADY STATE HEAT TRANSFER INTO WALLS AND FLOOR	81000
C	SUBROUTINE COND(QWALL1,TWALL1,NTIME,L)	81001
C	DIMENSION T(2,100,10),Q(10)	81002
C		81003
C		81004
C		81005
C		81006
	NTEMP=10	81007
	NLAY=100	81008
	WWALL=110000.0	81009
	CWALL=0.25	81010
	AM=2.0	81011
	IF (L.GT.0) GO TO 220	81012
	IF (NTIME.GT.1) GO TO 130	81013
	DO 110 K=1,NTEMP	81014
	DO 100 J=1,NLAY	81015
100	T(1,J,K)=100.0	81016
110	CONTINUE	81017
C		81018
	DO 120 K=1,NTEMP	81019
	T(2,100,K)=100.0	81020
120	T(2,1,K)=100.0+100.0*(K-1)	81021
	GO TO 160	81022
130	DO 140 K=1,NTEMP	81023
	DO 140 J=1,NLAY	81024
	T(1,J,K)=T(2,J,K)	81025
140	T(2,J,K)=0.0	81026
C		81027
	DO 150 K=1,NTEMP	81028
	T(2,1,K)=T(1,1,K)	81029
150	T(2,100,K)=100.0	81030
160	NLAY2=NLAY-1	81031
	DO 180 K=1,NTEMP	81032
	DO 170 J=2,NLAY2	81033
170	T(2,J,K)=(T(1,J-1,K)+T(1,J+1,K)+(T(1,J,K)*(AM-2.0)))/AM	81034
180	CONTINUE	81035
C		81036
	DO 190 K=1,NTEMP	81037
	Q(K)=0.0	81038
190	CONTINUE	81039
C		81040
	DO 210 K=1,NTEMP	81041
	DO 200 J=1,NLAY2	81042
200	Q(K)=Q(K)+WWALL*CWALL*(T(2,J,K)-100.0)	81043
210	CONTINUE	81044
	RETURN	81045
C		81046
220	GO TO (230,270),L	81047
230	IF (QWALL1.LE.Q(1)) GO TO 260	81048
	DO 240 K=2,10	81049



XXXXXXXXXXXXXXXXXXXX
XXXXXXXXXXXXXXXXXXXX
XXXXXXXXXXXXSECRETXX
XXXXXXXXXXXXXXXXXXXX

~~CONFIDENTIAL~~

UNCLASSIFIED

* T I D Y *

UNSTEADY STATE HEAT TRANSFER INTO WALLS AND FLOOR

IF (QWALL1.LE.Q(K)) GO TO 250	81050
CONTINUE	81051
TWALL1=T(2,1,10)	81052
RETURN	81053
50 TWALL1=(T(2,1,K)-T(2,1,K-1))*(QWALL1-Q(K-1))/(Q(K)-Q(K-1))+T(2,1,K	81054
1-1)	81055
RETURN	81056
60 TWALL1=T(2,1,1)	81057
RETURN	81058
70 IF (TWALL1.LE.T(2,1,1)) GO TO 300	81059
DO 280 K=2,10	81060
IF (TWALL1.LE.T(2,1,K)) GO TO 290	81061
CONTINUE	81062
80 QWALL1=Q(10)	81063
RETURN	81064
90 QWALL1=(Q(K)-Q(K-1))*(TWALL1-T(2,1,K-1))/(T(2,1,K)-T(2,1,K-1))+Q(K	81065
1-1)	81066
RETURN	81067
00 QWALL1=Q(1)	81068
RETURN	81069
END	81070
	81071-

XXXXXXXXXXXXXXXXXXXX
XXXXXXXXXXXXXXXXXXXX
XXXXXXXXXXXXSECRETXX
XXXXXXXXXXXXXXXXXXXX

UNCLASSIFIED

~~CONFIDENTIAL~~

~~CONFIDENTIAL~~
UNCLASSIFIED

XXXXXXXXXXXXXXXXXXXX
XXXXXXXXXXXXXXXXXXXX
XXXXXXXXXXXXXXXXXXXX
XXXXXXXXXXXXXXXXXXXX

* T I D Y *

UNSTEADY STATE HEAT TRANSFER INTO WALLS

```
C      UNSTEADY STATE HEAT TRANSFER INTO WALLS
C      SUBROUTINE COND1(QWALL1,TWALL1,NTIME,L)
C
C      DIMENSION T(2,100,30),Q(30)
C
C      NTEMP=30
C      NLAY=100
C      MWALL=18200.0
C      CWALL=0.25
C      AM=2.0
C      IF (L.GT.0) GO TO 220
C      IF (NTIME.GT.1) GO TO 130
C      DO 110 K=1,NTEMP
C      DO 100 J=1,NLAY
C      T(1,J,K)=100.0
C      100 CONTINUE
C
C      DO 120 K=1,NTEMP
C      T(2,100,K)=100.0
C      120 T(2,1,K)=100.0+100.0*(K-1)
C      GO TO 160
C      130 DO 140 K=1,NTEMP
C      DO 140 J=1,NLAY
C      T(1,J,K)=T(2,J,K)
C      140 T(2,J,K)=0.0
C
C      DO 150 K=1,NTEMP
C      T(2,1,K)=T(1,1,K)
C      150 T(2,100,K)=100.0
C      160 NLAY2=NLAY-1
C      DO 180 K=1,NTEMP
C      DO 170 J=2,NLAY2
C      170 T(2,J,K)=(T(1,J-1,K)+T(1,J+1,K)+(T(1,J,K)*(AM-2.0)))/AM
C      180 CONTINUE
C
C      DO 190 K=1,NTEMP
C      Q(K)=0.0
C      190 CONTINUE
C
C      DO 210 K=1,NTEMP
C      DO 200 J=1,NLAY2
C      200 Q(K)=Q(K)+MWALL*CWALL*(T(2,J,K)-100.0)
C      210 CONTINUE
C      RETURN
C
C      220 GO TO (230,270),L
C      230 IF (QWALL1.LE.Q(1)) GO TO 260
C      DO 240 K=2,30
```

C1000
C1301
C1002
C1003
C1004
C1005
C1006
C1007
C1008
C1009
C1010
C1011
C1012
C1013
C1014
C1015
C1016
C1017
C1018
C1019
C1020
C1021
C1022
C1023
C1024
C1025
C1026
C1027
C1028
C1029
C1030
C1031
C1032
C1033
C1034
C1035
C1036
C1037
C1038
C1039
C1040
C1041
C1042
C1043
C1044
C1045
C1046
C1047
C1048
C1049



~~CONFIDENTIAL~~
UNCLASSIFIED

XXXXXXXXXXXXXXXXXXXX
XXXXXXXXXXXXXXXXXXXX
XXXXXXXXXXXXXXXXXXXX
XXXXXXXXXXXXXXXXXXXX

XXXXXXXXXXXXXXXXXXXX
XXXXXXXXXXXXXXXXXXXX
SECRET
XXXXXXXXXXXXXXXXXXXX
XXXXXXXXXXXXXXXXXXXX

~~CONFIDENTIAL~~

UNCLASSIFIED

* T I / D Y *

UNSTEADY STATE HEAT TRANSFER INTO WALLS

240	IF (QWALL1.LE.Q(K)) GO TO 250	C1050
	CONTINUE	C1051
	TWALL1=T(2,1,30)	C1052
	RETURN	C1053
250	TWALL1=(T(2,1,K)-T(2,1,K-1))*(QWALL1-Q(K-1))/(Q(K)-Q(K-1))+T(2,1,K-1)	C1054
	RETURN	C1055
260	TWALL1=T(2,1,1)	C1056
	RETURN	C1057
270	IF (TWALL1.LE.T(2,1,1)) GO TO 300	C1058
	DO 280 K=2,30	C1059
	IF (TWALL1.LE.T(2,1,K)) GO TO 290	C1060
280	CONTINUE	C1061
	QWALL1=Q(30)	C1062
	RETURN	C1063
290	QWALL1=(Q(K)-Q(K-1))*(TWALL1-T(2,1,K-1))/(T(2,1,K)-T(2,1,K-1))+Q(K-1)	C1064
	RETURN	C1065
300	QWALL1=Q(1)	C1066
	RETURN	C1067
	END	C1068
		C1069
		C1070
		C1071-

~~CONFIDENTIAL~~

81 -
XXXXXXXXXXXXXXXXXXXX
XXXXXXXXXXXXXXXXXXXX
SECRET
XXXXXXXXXXXXXXXXXXXX
XXXXXXXXXXXXXXXXXXXX

UNCLASSIFIED

~~CONFIDENTIAL~~

~~CONFIDENTIAL~~
UNCLASSIFIED

XXXXXXXXXXXXXXXXXXXX
XXXXXXXXXXXXXXXXXXXX
XXXXXXXXXXXXXXXXXXXX
SECRET
XXXXXXXXXXXXXXXXXXXX

* T I D Y *

UNSTEADY STATE HEAT TRANSFER INTO FLOOR

C	UNSTEADY STATE HEAT TRANSFER INTO FLOOR	D1000
C	SUBROUTINE BOND(QWALL1,TWALL1,NTIME,L)	D1001
C	DIMENSION T(2,100,20),Q(20)	D1002
C		D1003
C		D1004
C		D1005
C		D1006
	NTEMP=20	D1007
	NLAY=100	D1008
	WWALL=91500.0	D1009
	CWALL=0.25	D1010
	AM=2.0	D1011
	IF (L.GT.0) GO TO 220	D1012
	IF (NTIME.GT.1) GO TO 130	D1013
	DO 110 K=1,NTEMP	D1014
	DO 100 J=1,NLAY	D1015
100	T(1,J,K)=100.0	D1016
110	CONTINUE	D1017
C		D1018
	DO 120 K=1,NTEMP	D1019
	T(2,100,K)=100.0	D1020
120	T(2,1,K)=100.0+100.0*(K-1)	D1021
	GO TO 160	D1022
130	DO 140 K=1,NTEMP	D1023
	DO 140 J=1,NLAY	D1024
	T(1,J,K)=T(2,J,K)	D1025
140	T(2,J,K)=0.0	D1026
C		D1027
	DO 150 K=1,NTEMP	D1028
	T(2,1,K)=T(1,1,K)	D1029
150	T(2,100,K)=100.0	D1030
160	NLAY2=NLAY-1	D1031
	DO 180 K=1,NTEMP	D1032
	DO 170 J=2,NLAY2	D1033
170	T(2,J,K)=(T(1,J-1,K)+T(1,J+1,K)+(T(1,J,K)*(AM-2.0)))/AM	D1034
180	CONTINUE	D1035
C		D1036
	DO 190 K=1,NTEMP	D1037
	Q(K)=0.0	D1038
190	CONTINUE	D1039
C		D1040
	DO 210 K=1,NTEMP	D1041
	DO 200 J=1,NLAY2	D1042
200	Q(K)=Q(K)+WWALL*CWALL*(T(2,J,K)-100.0)	D1043
210	CONTINUE	D1044
	RETURN	D1045
C		D1046
220	GO TO (230,270),L	D1047
230	IF (QWALL1.LE.Q(1)) GO TO 260	D1048
	DO 240 K=2,20	D1049



UNCLASSIFIED

XXXXXXXXXXXXXXXXXXXX
XXXXXXXXXXXXXXXXXXXX
SECRET
XXXXXXXXXXXXXXXXXXXX
XXXXXXXXXXXXXXXXXXXX

XXXXXXXXXXXXXXXXXXXX
XXXXSECRETXXXXXXXX
XXXXXXXXXXXXXXXXXXXX
XX:XXXXXXXXXXXXXXXX

~~CONFIDENTIAL~~

UNCLASSIFIED

* T I D Y *

UNSTEADY STATE HEAT TRANSFER INTO FLOOR

IF (QWALL1.LE.Q(K)) GO TO 250	D1050
240 CONTINUE	D1051
TWALL1=T(2,1,20)	D1052
RETURN	D1053
250 TWALL1=(T(2,1,K)-T(2,1,K-1))*(QWALL1-Q(K-1))/(Q(K)-Q(K-1))+T(2,1,K	D1054
1-1)	D1055
RETURN	D1056
260 TWALL1=T(2,1,1)	D1057
RETURN	D1058
270 IF (TWALL1.LE.T(2,1,1)) GO TO 300	D1059
DO 280 K=2,20	D1060
IF (TWALL1.LE.T(2,1,K)) GO TO 290	D1061
280 CONTINUE	D1062
QWALL1=Q(20)	D1063
RETURN	D1064
290 QWALL1=(Q(K)-Q(K-1))*(TWALL1-T(2,1,K-1))/(T(2,1,K)-T(2,1,K-1))+Q(K	D1065
1-1)	D1066
RETURN	D1067
300 QWALL1=Q(1)	D1068
RETURN	D1069
END	D1070
	D1071-

XXXXXXXXXXXXXXXXXXXX
XXXXSECRETXXXXXXXX
XXXXXXXXXXXXXXXXXXXX
XXXXXXXXXXXXXXXXXXXX
~~UNCLASSIFIED~~
~~CONFIDENTIAL~~



~~SECRET~~
XXXXXXXXXXXXXXXXXXXX
XXXXXXXXXXXXXXXXXXXX
XXXXXXXXXXXXXXXXXXXX
XXXXXXXXXXXXXXXXXXXX
SECRET
XXXXXXXXXXXXXXXXXXXX
XXXXXXXXXXXXXXXXXXXX

UNCLASSIFIED

* T I D Y *

COLLISION PROBABILITY IN A SLAB

C COLLISION PROBABILITY IN A SLAB

C

SUBROUTINE ESCAPE(BMU,PC)

C

DIMENSION PP(40)

PP(1)=0.0484

PP(2)=0.0831

PP(3)=0.1127

PP(4)=0.1390

PP(5)=0.1629

PP(6)=0.1849

PP(7)=0.2054

PP(8)=0.2246

PP(9)=0.2427

PP(10)=0.2597

PP(11)=0.3932

PP(12)=0.4859

PP(13)=0.5554

PP(14)=0.6097

PP(15)=0.6533

PP(16)=0.6890

PP(17)=0.7187

PP(18)=0.7437

PP(19)=0.7651

PP(20)=0.8757

PP(21)=0.9167

PP(22)=0.9375

PP(23)=0.9500

PP(24)=0.9580

PP(25)=0.9650

PP(26)=0.9690

PP(27)=0.9720

PP(28)=0.9740

IF (BMU.LE.0.1) K=BMU*100.0

IF (BMU.LE.1.0.AND.BMU.GT.0.1) K=BMU*10.0+9.0

IF (BMU.LE.10.0.AND.BMU.GT.1.0) K=BMU+18.0

IF (BMU.GE.10.0) PC=0.974

IF (BMU.GE.10.0) RETURN

IF (BMU.LE.0.1) A=BMU*100.0

IF (BMU.LE.1.0.AND.BMU.GT.0.1) A=BMU*10.0+9.0

IF (BMU.LE.10.0.AND.BMU.GT.1.0) A=BMU+18.0

B=K

PC=PP(K)+(A-B)*(PP(K+1)-PP(K))

RETURN

END

E1000

E1001

E1002

E1003

E1004

E1005

E1006

E1007

E1008

E1009

E1010

E1011

E1012

E1013

E1014

E1015

E1016

E1017

E1018

E1019

E1020

E1021

E1022

E1023

E1024

E1025

E1026

E1027

E1028

E1029

E1030

E1031

E1032

E1033

E1034

E1035

E1036

E1037

E1038

E1039

E1040

E1041

E1042

E1043

E1044

~~SECRET~~
UNCLASSIFIED

XXXXXXXXXXXXXXXXXXXX
XXXXXSECRETXXXXX
XXXXXXXXXXXXXXXXXXXX
XXXXXXXXXXXXXXXXXXXX

XXXXXXXXXXXXXXXXXXXX
XXXXXXXXXXXXXXXXXXXX
XXXXXXXXXXXXXXXXXXXX
XXXXXXXXXXXXXXXXXXXX

~~SECRET~~
UNCLASSIFIED

* T I D Y *

COLLISION PROBABILITY IN A CYLINDER

C
C
C
C

COLLISION PROBABILITY IN A CYLINDER

SUBROUTINE GETOUT(AMU,PCC)

DIMENSION PP(40)

PP(1)=0.115

PP(2)=0.207

PP(3)=0.284

PP(4)=0.348

PP(5)=0.404

PP(6)=0.452

PP(7)=0.494

PP(8)=0.531

PP(9)=0.564

PP(10)=0.592

PP(11)=0.764

PP(12)=0.837

PP(13)=0.877

PP(14)=0.901

PP(15)=0.917

PP(16)=0.929

PP(17)=0.938

PP(18)=0.945

PP(19)=0.950

PP(20)=0.975

PP(21)=0.983

PP(22)=0.988

PP(23)=0.990

PP(24)=0.992

PP(25)=0.993

PP(26)=0.994

PP(27)=0.994

PP(28)=0.995

IF (AMU.LE.1.0) K=AMU*10.0

IF (AMU.LE.10.0.AND.AMU.GT.1.0) K=AMU+9.0

IF (AMU.LE.100.0.AND.AMU.GT.10.0) K=AMU*0.1+18.0

IF (AMU.GT.100.0) PCC=0.995

IF (AMU.GT.100.0) RETURN

IF (AMU.LE.1.0) A=AMU*10.0

IF (AMU.LE.10.0.AND.AMU.GT.1.0) A=AMU+9.0

IF (AMU.LE.100.0.AND.AMU.GT.10.0) A=AMU*0.1+18.0

B=K

PCC=PP(K)+(A-B)*(PP(K+1)-PP(K))

RETURN

END

F1000
F1001
F1002
F1003
F1004
F1005
F1006
F1007
F1008
F1009
F1010
F1011
F1012
F1013
F1014
F1015
F1016
F1017
F1018
F1019
F1020
F1021
F1022
F1023
F1024
F1025
F1026
F1027
F1028
F1029
F1030
F1031
F1032
F1033
F1034
F1035
F1036
F1037
F1038
F1039
F1040
F1041
F1042
F1043
F1044

UNCLASSIFIED

XXXXXXXXXXXXXXXXXXXX
XXXXXXXXXXXXXXXXXXXX
XXXXXXXXXXXXXXXXXXXX
XXXXXXXXXXXXXXXXXXXX



[REDACTED]

XXXXXXXXXXXXXXXXXXXX
XXXXXXXXXXXXXXXXXXXX
XXXXXXXXXXXXSECRETXXXX
XXXXXXXXXXXXXXXXXXXX

UNCLASSIFIED

[REDACTED]

(Blank)

- 86 -

UNCLASSIFIED

[REDACTED]

XXXXXXXXXXXXXXXXXXXX
XXXXXXXXXXXXXXXXXXXX
XXXXXXXXXXXXSECRETXXXX
XXXXXXXXXXXXXXXXXXXX

~~CONFIDENTIAL~~

XXXXXXXXXXXXXXXXXXXX
XXXXXXXXXXXXXXXXXXXX
XXXXSECRETXXXXXXXX
XXXXXXXXXXXXXXXXXXXX

UNCLASSIFIED

APPENDIX B

LAVA CODE OUTPUT

Units of BTU and degree Fahrenheit are used in the LAVA code. Units of pcu (pound-centigrade unit) and degree centigrade are used in the text of this report.

~~CONFIDENTIAL~~

XXXXXXXXXXXXXXXXXXXX
XXXXSECRETXXXXXXXX
XXXXXXXXXXXXXXXXXXXX

UNCLASSIFIED

~~CONFIDENTIAL~~

INPUT INFORMATION

MELTING TEMPERATURE OF FUEL 1220.0
MASS OF AIR FROM -40 5126.0
TEMPERATURE OF AMBIENT SYSTEM 100.0
EFFECTIVE MASS OF CORE 15000.0
EFFECTIVE MASS OF EFFLUENT PIPING AND PUMPS 150000.0
EFFECTIVE AREA OF EFFLUENT PIPING AND PUMPS 1000.0
EMISSIVITY OF EFFLUENT PIPING AND PUMPS 0.5
EMISSIVITY OF CONCRETE WALLS AT -40 0.8
EFFECTIVE SURFACE AREA OF CONCRETE WALLS 30000.0
THERMAL CONDUCTIVITY OF CONCRETE 0.5
COEFFICIENT FOR CONVECTION EQUATION 0.2
RELATIVE HEAT GENERATION 0.6

OUTPUT INFORMATION

TIME	FUEL TEMP	AVG PIPE TEMP	CONCRETE WALL TEMP	AIR TEMP	PIPE SURFACE TEMP	INTERFACE TEMP	HEAT IN
1	520.3	249.2	102.8	100.1	100.0	525.1	3700000.0
2	629.3	434.0	101.8	103.2	289.3	632.9	33000000.0
3	675.4	505.8	101.5	104.3	355.8	678.8	30800000.0
4	740.4	575.1	101.4	106.0	439.4	742.8	29000000.0
5	793.5	639.2	101.4	107.5	509.4	795.3	27300000.0

UNCLASSIFIED

XXXXXXXXXXXXXXXXXXXX
XXXXXXXXXXXXXXXXXXXX
XXXXXXXXXXXXXXXXXXXX
XXXXXXXXXXXXXXXXXXXX
XXXXXXXXXXXXXXXXXXXX

UNCLASSIFIED
XXXX
XXXX
XXXX



E. I. DU PONT DE NEMOURS & COMPANY
WILMINGTON, DELAWARE 19898

DPST-70-433-TL

~~RESTRICTED~~
UNCLASSIFIED

When separated from enclosures,
handle this document as

UNCLASSIFIED

EXPLOSIVES DEPARTMENT

October 29, 1970

Mr. N. Stetson, Manager (35)
Savannah River Operations Office
U. S. Atomic Energy Commission
Aiken, South Carolina 29801

Dear Mr. Stetson:


Attached is a copy of DPST-70-433, "Analysis of Postulated Core Meltdown of an SRP Reactor - Final Report." This document presents the calculated consequence of a loss-of-coolant accident in a Savannah River Plant reactor in which either: (1) the emergency cooling system fails to function or (2) actuation of the system is delayed. Preliminary calculations were contained in an earlier document, DPST-67-639.

This report is the second of the four reports requested by DRL-ACRS in September 1969, to complete the studies of the conformance of SRP reactors to licensing criteria. We expect to transmit the two remaining reports together with a summary report in early November 1970.

While this report might be considered a "Safety Analysis," we would not expect it to fall in the category of an SAR which is subject to formal approval by the AEC under the procedure now being discussed by our staffs.

Very truly yours,

ATOMIC ENERGY DIVISION


J. W. Croach, Director
Technical Division

WSD:bw
Attachment: DPST-70-433

DOCUMENT TRANSMITTED HEREWITH CONTAINS
RESTRICTED DATA

~~RESTRICTED~~
UNCLASSIFIED

~~SECRET~~
UNCLASSIFIED

DPST-70-433

DISTRIBUTION

- 1-35. N. Stetson, SROO
36. M. H. Wahl - J. D. Ellett
37. J. W. Croach - A. A. Johnson
38. F. E. Kruesi
39. D. F. Babcock - J. S. Neill
40. A. J. Schwertfeger - H. W. Bellas
41. J. G. Brewer
42. J. A. List
43. J. A. Monier - K. W. French, SRP
44. J. K. Lower - P. A. Dahlen
45. W. P. Bebbington - T. C. Evans
46. L. W. Fox
47. E. O. Kiger
48. W. M. Olliff - C. J. Temple
49. J. W. Joseph
50. C. H. Ice - L. H. Meyer, SRL
51. S. Mirshak
52. G. Dessauer
53. J. L. Crandall
54. P. L. Roggenkamp - B. C. Rusche
55. J. M. Boswell
56. G. F. Merz
57. H. E. Wingo
58. D. H. Knoebel
59. F. D. King
60. R. A. Gregg
61. C. E. Bailey
62. W. S. Durant
63. R. J. Brown
64. R. C. Thornberry
65. L. R. Jones
66. A. G. Evans
67. J. E. Beach
68. Vital Records File
- 69-75. TIS File.

UNCLASSIFIED
~~SECRET~~



E. I. DU PONT DE NEMOURS & COMPANY
INCORPORATED
WILMINGTON, DELAWARE 19898

EXPLOSIVES DEPARTMENT

~~SECRET~~
DPST-70-433-TL

When separated from enclosures,
handle this document as
UNCLASSIFIED.

October 29, 1970

Mr. N. Stetson, Manager (35)
Savannah River Operations Office
U. S. Atomic Energy Commission
Aiken, South Carolina 29801

TIS FILE
RECORD COPY

Dear Mr. Stetson:


Attached is a copy of DPST-70-433, "Analysis of Postulated Core Meltdown of an SRP Reactor - Final Report." This document presents the calculated consequence of a loss-of-coolant accident in a Savannah River Plant reactor in which either: (1) the emergency cooling system fails to function or (2) actuation of the system is delayed. Preliminary calculations were contained in an earlier document, DPST-67-639.

This report is the second of the four reports requested by DRL-ACRS in September 1969, to complete the studies of the conformance of SRP reactors to licensing criteria. We expect to transmit the two remaining reports together with a summary report in early November 1970.

While this report might be considered a "Safety Analysis," we would not expect it to fall in the category of an SAR which is subject to formal approval by the AEC under the procedure now being discussed by our staffs.

Very truly yours,

ATOMIC ENERGY DIVISION


J. W. Croach, Director
Technical Division

WSD:bw
Attachment: DPST-70-433


DOCUMENT TRANSMITTED HERewith CONTAINS
RESTRICTED DATA

DISTRIBUTION

- 1-35. N. Stetson, SROO
36. M. H. Wahl - J. D. Ellett
37. J. W. Croach - A. A. Johnson
38. F. E. Kruesi
39. D. F. Babcock - J. S. Neill
40. A. J. Schwertfeger - H. W. Bellas
41. J. G. Brewer
42. J. A. List
43. J. A. Monier - K. W. French, SRP
44. J. K. Lower - P. A. Dahlen
45. W. P. Bebbington - T. C. Evans
46. L. W. Fox
47. E. O. Kiger
48. W. M. Olliff - C. J. Temple
49. J. W. Joseph
50. C. H. Ice - L. H. Meyer, SRL
51. S. Mirshak
52. G. Dessauer
53. J. L. Crandall
54. P. L. Roggenkamp - B. C. Rusche
55. J. M. Boswell
56. G. F. Merz
57. H. E. Wingo
58. D. H. Knoebel
59. F. D. King
60. R. A. Gregg
61. C. E. Bailey
62. W. S. Durant
63. R. J. Brown
64. R. C. Thornberry
65. L. R. Jones
66. A. G. Evans
67. J. E. Beach
68. Vital Records File
- 69-75. TIS File

U.S. ATOMIC ENERGY COMMISSION
MAJOR CONTRACTOR'S RECOMMENDATION FOR
DISPOSITION OF SCIENTIFIC AND TECHNICAL DOCUMENT

*See Instructions on Reverse

1. AEC Report No. DPST-70-433	3. Title Analysis of Postulated Core Meltdown of an Reactor Final Report
2. Subject Category No.	
4. Type of Document ("X" one) <input checked="" type="checkbox"/> a. Scientific and Technical Report <input type="checkbox"/> b. Conference paper: Title of conference _____ Date of conference _____ Exact location of conference _____ <input type="checkbox"/> c. Other (Specify, Thesis, Translation, etc.)* _____	
5. Copies Transmitted ("X" one or more) <input type="checkbox"/> a. Copies being transmitted for standard distribution by AEC-TIC. <input type="checkbox"/> b. Copies being transmitted for special distribution per attached complete address list.* <input checked="" type="checkbox"/> c. Two completely legible, reproducible copies being transmitted to AEC-TIC.	
6. Recommended Distribution ("X" one) <input type="checkbox"/> a. Normal handling (after Patent clearance): no restraints on distribution except as may be required by the security classification. <input type="checkbox"/> b. Make available only to U.S. Government agencies and their contractors. <input checked="" type="checkbox"/> c. Make available only within AEC and to AEC contractors. <input type="checkbox"/> d. Make available only within AEC. <input type="checkbox"/> e. Make available only to those listed in item 12 below. <input type="checkbox"/> f. Other (Specify)* _____	
7. Recommended Announcement ("X" one) <input type="checkbox"/> a. Normal procedure may be followed.* <input checked="" type="checkbox"/> b. Recommend following announcement limitations: <u>no announcement</u>	
8. Reason for Restrictions Recommended in 6 or 7 above. <input type="checkbox"/> a. Preliminary information. <input checked="" type="checkbox"/> b. Prepared primarily for internal use. <input type="checkbox"/> c. Other (Explain) _____	
9. Patent Clearance ("X" one) <input checked="" type="checkbox"/> a. AEC patent clearance has been granted by responsible AEC patent group. <input type="checkbox"/> b. Document has been sent to responsible AEC patent group for clearance.	
10. National Security Information (For classified document only; "X" one) <input type="checkbox"/> a. Document does contain national security information other than restricted data. <input checked="" type="checkbox"/> b. Document does not contain national security information other than restricted data.	
11. Copy Reproduction and Distribution a. Total number of copies reproduced <u>72</u> b. Number of copies distributed outside originating organization <u>0</u>	
12. Additional Information or Remarks (Continue on separate sheet, if necessary)	
13. Submitted by (Name and Position) (Please print or type)* H. S. Hilborn, Senior Editor	
14. Organization Savannah River Laboratory	
15. Signature 	16. Date 1/15/76

OK
~~1388~~

EXTERNAL RELEASE OF TECHNICAL INFORMATION

Description of Material No. DPST-70-433 Date September 23, 1983

Title: ANALYSIS OF POSTULATED CORE MELTDOWN OF AN SRP REACTOR

Author(s) William S. Durant & Robert J. Brown

Date of Material

- () Classified DP Report
- () Classified Paper
- () Unclassified DP Report
- (XXX) Unclassified Paper
- () Classified Letter
- () Classified Abstract or Summary
- () Unclassified Letter
- () Unclassified Abstract or Summary

Technical Content

Approved by T. V. Crawford Date 10/24/83

Classification

Approved by T. V. Crawford Date 10/24/83

Approved by SWO'Pear / Cg Bonick Date 10/3/83
AED Classification Officer

Authority

CG-UF-3, Topic 2.2

Category if DP Report

Approved by N/A Date _____
Supervisor, I&PS

Released by:

A. F. Westerdahl 10/4/83 [Signature]
J. M. Gaver 10/12/83 [Signature]

U.S. DEPARTMENT OF ENERGY

DOE AND MAJOR CONTRACTOR RECOMMENDATIONS FOR
ANNOUNCEMENT AND DISTRIBUTION OF DOCUMENTS

See Instructions on Reverse Side

1. DOE Report No. DPST-70-433 (Deleted Version)	2. Contract No. DE-AC09-76SR00001	3. Subject Category No. UC-80
--	--------------------------------------	----------------------------------

4. Title
ANALYSIS OF POSTULATED CORE MELTDOWN OF AN SRP REACTOR

5. Type of Document ("x" one)

a. Scientific and technical report

b. Conference paper: Title of conference _____
Date of conference _____

Exact location of conference _____ Sponsoring organization _____

c. Other (specify planning, educational, impact, market, social, economic, thesis, translations, journal article manuscript, etc.)

6. Copies Transmitted ("x" one or more)

a. Copies being transmitted for standard distribution by DOE-TIC.

b. Copies being transmitted for special distribution per attached complete address list.

c. Two completely legible, reproducible copies being transmitted to DOE-TIC. (Classified documents, see instructions)

d. Twenty-seven copies being transmitted to DOE-TIC for TIC processing and NTIS sales.

7. Recommended Distribution ("x" one)

a. Normal handling (after patent clearance): no restraints on distribution except as may be required by the security classification. Make available only

b. To U.S. Government agencies and their contractors. c. within DOE and to DOE contractors.

d. within DOE. e. to those listed in item 13 below.

f. Other (Specify)

8. Recommended Announcement ("x" one)

a. Normal procedure may be followed. b. Recommend the following announcement limitations:

9. Reason for Restrictions Recommended in 7 or 8 above.

a. Preliminary information. b. Prepared primarily for internal use. c. Other (Explain)

10. Patent, Copyright and Proprietary Information

Does this information product disclose any new equipment, process or material? No Yes If so, identify page nos. _____

Has an invention disclosure been submitted to DOE covering any aspect of this information product? No Yes

If so, identify the DOE (or other) disclosure number and to whom the disclosure was submitted.

Are there any patent-related objections to the release of this information product? No Yes If so, state these objections.

Does this information product contain copyrighted material? No Yes

If so, identify the page number _____ and attach the license or other authority for the government to reproduce.

Does this information product contain proprietary information? No Yes If so, identify the page numbers _____

("x" one a. DOE patent clearance has been granted by responsible DOE patent group.

b. Document has been sent to responsible DOE patent group for clearance.

11. National Security Information (For classified document only; "x" one)

Document a. does b. does not contain national security information

12. Copy Reproduction and Distribution

Total number of copies reproduced _____ Number of copies distributed outside originating organization _____

13. Additional Information or Remarks (Continue on separate sheet, if necessary)

14. Submitted by (Name and Position) (Please print or type)

C. J. Banick, Sr. Information Specialist

Organization

Information & Publication Services, SRP Aiken, South Carolina 29808

Signature *CJ Banick* Date 6/27/84



E. I. DU PONT DE NEMOURS & COMPANY
INCORPORATED

ATOMIC ENERGY DIVISION

SAVANNAH RIVER PLANT
AIKEN, SOUTH CAROLINA 29808-0001
(TWX 810-771-2670 TEL 803-725-6211 WU AUGUSTA GA)

CC: S. W. O'Rear
September 23, 1983

Mr. A. F. Westerdahl, Chief
Patent Branch
U. S. Department of Energy
Aiken, South Carolina 29808

Dear Mr. Westerdahl:

REQUEST FOR PATENT REVIEW

Please review for patent matter the documents described in the attached list.

The documents are proposed for release to the general public. Following necessary approvals, copies will be sent to DOE/TIC and also to public reading rooms containing documents cited in the Draft Environmental Impact Statement Pertaining to the Proposed Restart of the L-Reactor at SRP.

If any technical clarification is needed please call C. J. Banick whose Document Review is attached.

Please telephone your comments to the Records Management office (Ext. 2606) and notify me by signing and returning to C. J. Banick the original of this letter. A copy is provided for your file.

If you decide to pursue a patent on any development covered, I shall be happy to supply additional information required such as appropriate references and the names of persons responsible for the development.

Very truly yours,

The above item is approved
for release.

S. W. O'Rear, Chief Supervisor
Records Management

By: C. J. Banick
C. J. Banick

A. F. Westerdahl 10/1/83
A. F. Westerdahl Date
Chief, Patent Branch
DOE-SR

SOME REFERENCES THAT ARE CITED IN THE L-REACTOR RESTART EIS

<u>DOCUMENT NUMBER</u>	<u>TITLE</u>	<u>AUTHOR(S)</u>
1. DPE-2383	Earthquake Criteria For The Savannah River Plant - March 1968	T. V. Crawford
2. DPE-3465	Danger Of Soil Liquefaction Caused By Earthquake At The Savannah River Plant	F. H. Herzog
3. DPST-69-566	Seismic Resistance Of The Savannah River Reactors	J. A. List
4. DPST-70-433	Analysis Of Postulated Core Melt-down Of An SRP Reactor	W. S. Durant / R. J. Brown /
5. DPST-70-435	Radioactivity In The Environs of Steel Creek - August 20, 1970	W. L. Marter
6. DPST-70-463	Analysis Of The Savannah River Reactor - Emergency Core Cooling System	J. W. Joseph, Jr. R. C. Thornberry
7. DPSP-70-1457	Source Rod Failure - K Area	W. M. Olliff
8. DPST-76-461	Tornadic Resistance of 105 Building Disassembly Areas	W. W. F. Yau C. W. Zeh
9. DPST-79-509	Energy Recovery With Hydraulic Turbines	J. L. Jarriell J. B. Price
10. DPST-79-531	Use of Cooling Ponds and Hydraulic Turbines to Save SRP Energy Consumption	J. B. Price
11. WILLJO-80-RSR	Report On The Savannah River Plant Hydroelectric Development	Tudor Engineering Co. Denver, Colorado
12. DPST-80-250	Preliminary Safety Analysis Defense Waste Processing Facility Reference Case Volume 1 of 4	W. R. Stevens
13. DPST-81-481	Analysis of Water Diversion Paths To By-Pass Clay Pipe	H. P. Olson



E. I. DU PONT DE NEMOURS & COMPANY
INCORPORATED

ATOMIC ENERGY DIVISION

SAVANNAH RIVER PLANT
AIKEN, SOUTH CAROLINA 29808-0001
(TWX 810-771-2670. TEL 803-725-6211, WU AUGUSTA, GA.)

CC: A. F. Westerdahl, DOE-SR
S. W. O'Rear

September 23, 1983

TO: S. W. O'REAR

FROM: C. J. BANICK *CJB*

DOCUMENT REVIEW

Document: See Attached List

Title:

Author(s)

Contractual Origin: DE-AC09-SR7600001

Present Classification: Unclassified Paper

References:

No items were noted that, in my opinion, should be called to the attention of the DOE for patent consideration.

CC: J. M. Gaver, DOE-SR
E. B. Sheldon, SRP
W. C. Reinig
L. Hibbard
S. Mirshak - J. A. Porter, SRL
D A. Ward - M. R. Buckner
T. V. Crawford
A. L. Boni
J. C. Corey
File (*DAST-70-433*)

September 23, 1983

TO DISTRIBUTION

The documents described in the attached list are proposed for release to the general public. Following necessary approvals, copies will be sent to DOE/TIC and also to public reading rooms containing documents cited in the Draft Environmental Impact Statement Pertaining to the Proposed Restart of the L-Reactor at SRP.

The classification reviewer has determined this document to be unclassified.

If there are comments about its release, notify the Records Management office as soon as possible (Ext. 2606).

TO: Senior Information Specialist, I&PS, SRL, 773-A DATE: 10/12/83

DOCUMENT NO.: DPST-70-433, Analysis of Postulated Core
Meltdown Of An SRP Reactor

RECEIVED OEA/SR ON: 9 / 26 / 83

The above referenced document has been reviewed by SR staff and is:

Approved for release as written.

Approved for release subject to the following changes:

Document contains Section 148 information.

Bill Wisenbacker has deleted version

Not Approved for release.

ADDITIONAL COMMENTS:

Deleted version placed in DOE-SR Reading Room,
Aiken, SC. RRS 10/14/83

for M R Rearden
Robert C. Webb, Deputy Director
Office of External Affairs

Attachment

~~DPST-70-433~~

6/28

- send to TIC
- do we have a folder on this?
- Be sure that the number reads like this: DPST-70-433
Deleted Version

~~DPST-70-433~~

6	852.2	700.2	101.5	109.0	576.1	853.4	2650000.0
7	904.7	758.8	101.7	110.5	637.9	905.2	2560000.0
8	957.8	815.3	101.9	111.9	698.6	957.9	2480000.0
9	1007.4	869.6	102.2	113.4	756.3	1007.8	2400000.0
10	1056.7	921.9	102.6	114.8	811.6	1056.6	2340000.0
11	1104.8	972.5	103.0	116.3	865.0	1103.3	2280000.0
12	1150.4	1021.5	103.5	117.9	916.7	1149.3	2220000.0
13	1196.7	1068.8	104.0	119.1	965.8	1194.3	2190000.0
14	1220.0	1112.9	104.7	120.8	1020.4	1216.6	2160000.0
15	1220.0	1148.0	105.4	122.4	1080.0	1215.2	2110000.0
16	1220.0	1170.0	106.1	124.0	1126.2	1212.5	2050000.0
17	1220.0	1182.5	106.9	124.8	1154.2	1209.3	2020000.0
18	1298.1	1196.9	107.7	124.5	1146.2	1285.7	2000000.0

AT THIS CONDITION THE PIPE COLLAPSES

INPUT INFORMATION

FLOOR AREA AT -40	5000.0
MELTING TEMPERATURE OF LAVA	1900.0
LINEAR ABSORPTION COEF OF FUEL	0.20000
LINEAR ABSORPTION COEF OF STAINLESS STEEL	0.57000
DENSITY OF FUEL	200.00000
DENSITY OF STAINLESS STEEL	480.00000
EMISSIVITY OF DEBRIS	0.5

XXXXXXXXXXXXXXXXXXXX
 XXXXXXXXXXXXXXXXXXXX
 XXXXXXXXXXXXXXXXXXXX
 XXXXXXXXXXXXXXXXXXXX

~~CONFIDENTIAL~~

UNCLASSIFIED

~~CONFIDENTIAL~~

XXXXXXXXXXXXXXXXXXXX
 XXXXXXXXXXXXXXXXXXXX
 XXXXXXXXXXXXXXXXXXXX
 XXXXXXXXXXXXXXXXXXXX

UNCLASSIFIED

~~CONFIDENTIAL~~

MASS OF STEEL IN LAVA

85350.7

OUTPUT INFORMATION

~~SECRET~~
UNCLASSIFIED

TIME	AVG LAVA TEMP	LAVA SURF TEMP	LAVA AREA	WALL TEMP	AIR TEMP	HEAT IN	HEAT OXID	HEAT CONV	HEAT COND	HEAT FLO
19	1904.4	1901.9	120.0	109.2	105.8	1960000.0	1813.1	8630.9	912792.6	475177.2
20	1903.1	1900.4	280.0	110.3	116.1	1940000.0	4359.3	20205.6	1048918.0	1111118.0
21	1903.6	1901.2	420.0	112.0	123.6	1920000.0	6697.0	30195.9	943722.7	166655.6
22	1906.3	1904.2	540.0	114.2	129.3	1900000.0	8822.1	38669.1	835768.1	214937.9
23	1903.4	1901.5	660.0	116.9	135.2	1880000.0	11010.0	47054.0	852427.1	262745.8
24	1903.8	1902.1	760.0	119.9	140.1	1860000.0	12869.3	53915.6	739335.3	301982.9
25	1904.0	1902.4	850.0	123.2	144.7	1840000.0	14630.2	60098.7	687435.9	337964.5
26	1904.3	1902.8	930.0	126.7	148.8	1820000.0	16240.2	65551.9	634553.8	369966.6
27	1905.1	1903.8	1000.0	130.4	152.9	1800000.0	17698.5	70357.9	579717.8	398236.2
28	1902.9	1901.6	1070.0	134.3	156.6	1790000.0	19140.7	75017.4	587203.5	425606.6
29	1901.8	1900.5	1130.0	138.4	159.9	1770000.0	20355.9	78907.7	529405.8	448227.7
30	1902.5	1901.3	1180.0	142.5	162.8	1760000.0	21430.8	82180.7	470683.1	467857.8
31	1904.9	1903.8	1220.0	146.6	165.3	1740000.0	22386.2	84884.2	411687.7	484989.3
32	1901.2	1900.1	1270.0	150.8	168.4	1730000.0	23475.7	88138.0	479115.8	504317.6
33	1903.8	1902.8	1300.0	155.0	170.3	1710000.0	24125.9	89999.6	354274.3	515684.5
34	1904.9	1903.9	1330.0	159.3	172.5	1700000.0	24910.9	92051.4	356631.9	529218.6
35	1904.2	1903.2	1360.0	163.5	174.6	1690000.0	25617.5	93993.7	358958.4	541310.4
36	1902.3	1901.4	1390.0	167.7	176.5	1670000.0	26245.9	95819.6	359604.4	551983.4
37	1903.2	1902.2	1410.0	171.9	178.0	1650000.0	26691.2	97092.2	296114.3	559493.6
38	1903.0	1902.1	1430.0	176.0	179.5	1640000.0	27184.0	98366.1	296554.3	567701.1
39	1901.7	1900.8	1450.0	180.1	180.8	1620000.0	27561.2	99501.4	295908.1	573957.8

XXXXXXXXXXXXXXXXXXXX
XXXXXXXXXXXXXXXXXXXX
XXXXXXXXXXXXXXXXXXXX
XXXXXXXXXXXXXXXXXXXX

UNCLASSIFIED

XXXXXXXXXXXXXXXXXXXX
XXXXXXXXXXXXXXXXXXXX
XXXXXXXXXXXXXXXXXXXX
XXXXXXXXXXXXXXXXXXXX

40	1903.4	1902.5	1460.0	184.2	181.6	1600000.0	27866.7	100166.4	232139.1	578945.3
41	1903.9	1903.1	1470.0	188.2	182.6	1580000.0	28176.4	100861.3	231945.1	583984.7
42	1903.9	1903.1	1480.0	192.2	183.7	1570000.0	28434.6	101501.2	231362.6	588163.4
43	1903.3	1902.5	1490.0	196.1	184.7	1560000.0	28655.7	102079.4	230053.7	591727.7
44	1902.2	1901.4	1500.0	199.9	185.8	1550000.0	28843.8	102609.6	228671.7	594746.9
45	1904.9	1904.1	1500.0	203.7	186.5	1540000.0	28896.5	102590.4	163537.9	595512.2
46	1902.9	1902.1	1510.0	207.5	187.8	1530000.0	29158.9	103229.1	225985.8	599719.2
47	1904.7	1903.9	1510.0	211.1	188.5	1520000.0	29154.8	103145.6	161224.6	599569.8
48	1901.9	1901.1	1520.0	214.8	189.7	1510000.0	29364.1	103705.5	222620.9	602898.6
49	1903.1	1902.3	1520.0	218.3	190.4	1500000.0	29315.3	103566.1	157207.8	602026.1
50	1903.5	1902.7	1520.0	221.8	191.2	1490000.0	29367.5	103555.1	155664.6	602782.6
51	1903.7	1902.9	1520.0	225.2	192.0	1470000.0	29388.2	103521.5	154403.3	603030.4
52	1903.6	1902.9	1520.0	228.6	192.8	1460000.0	29392.3	103460.3	152172.9	603010.1
53	1903.4	1902.6	1520.0	231.9	193.6	1450000.0	29381.5	103379.8	150318.4	602749.1
54	1902.9	1902.1	1520.0	235.2	194.4	1440000.0	29356.8	103284.3	148478.9	602265.8
55	1902.2	1901.5	1520.0	238.4	195.2	1430000.0	29319.6	103173.9	146225.6	601589.3
56	1901.5	1900.7	1520.0	241.5	195.9	1420000.0	29224.2	102990.2	143324.2	599962.4
57	1900.6	1899.8	1520.0	244.6	196.7	1410000.0	29201.4	102901.3	141283.0	599510.1
58	1900.0	1899.3	1520.0	247.6	197.5	1400000.0	29172.5	102803.7	139689.4	598957.1
59	1900.0	1896.2	1520.0	250.5	198.1	1390000.0	28961.1	102470.9	135895.7	595456.5
60	1900.0	1896.2	1520.0	253.4	198.9	1380000.0	28962.9	102418.9	133871.7	595401.8
61	1900.0	1896.2	1520.0	256.3	199.7	1370000.0	28964.6	102364.9	133144.2	595347.7
62	1900.0	1896.3	1520.0	259.1	200.5	1360000.0	28966.3	102301.2	132285.9	595293.8
63	1900.0	1896.3	1520.0	261.9	201.2	1350000.0	28968.0	102240.6	131336.3	595249.6
64	1900.0	1896.3	1520.0	264.6	202.0	1340000.0	28969.8	102182.0	130490.5	595196.0

XXXXXXXXXXXXXXXXXXXX
 XXXXXXXXXXXXXXXXXXXX
 XXXXXXXXXXXXXXXXXXXX
 XXXXXXXXXXXXXXXXXXXX
 XXXXXXXXXXXXXXXXXXXX

~~CONFIDENTIAL~~
 UNCLASSIFIED

XXXXXSECRETXXXXXX
 XXXXXXXXXXXXXXXXXXXX
 XXXXXXXXXXXXXXXXXXXX
 XXXXXXXXXXXXXXXXXXXX
 XXXXXXXXXXXXXXXXXXXX

UNCLASSIFIED


~~CONFIDENTIAL~~

~~CONFIDENTIAL~~

XXXXXXXXXXXXXXXXXXXX
XXXXXXXXXXXXXXXXXXXX
XXXXXXXXXXXXXXXXXXXX
XXXXXXXXXXXXXXXXXXXX

UNCLASIFIED

90	1900.0	1896.8	1520.0	324.9	219.9	1180000.0	28997.3	100761.7	110093.2	593607.7
91	1900.0	1896.8	1520.0	326.9	220.6	1180000.0	28997.3	100711.2	109423.8	593532.2
92	1900.0	1896.8	1520.0	328.9	221.2	1170000.0	28999.0	100663.1	108761.5	593484.5
93	1900.0	1896.8	1520.0	330.8	221.8	1170000.0	28999.0	100613.3	108116.0	593409.3
94	1900.0	1896.8	1520.0	332.7	222.4	1160000.0	29000.8	100565.9	107474.2	593362.1
95	1900.0	1896.8	1520.0	334.7	223.0	1150000.0	29000.8	100516.7	106851.7	593287.7
96	1900.0	1896.9	1520.0	336.6	223.6	1150000.0	29002.5	100470.2	106235.4	593240.2
97	1900.0	1896.9	1520.0	338.4	224.2	1150000.0	29002.5	100421.6	105634.2	593166.1
98	1900.0	1896.9	1520.0	340.3	224.8	1150000.0	29002.5	100373.6	105011.4	593092.0
99	1900.0	1896.9	1520.0	342.1	225.4	1140000.0	29004.2	100328.0	104450.3	593045.6
100	1900.0	1896.9	1520.0	344.0	226.0	1140000.0	29004.2	100280.4	103860.7	592971.4
101	1900.0	1896.9	1520.0	345.8	226.6	1140000.0	29004.2	100233.2	103293.1	592897.8
102	1900.0	1896.9	1520.0	347.6	227.2	1130000.0	29006.0	100188.7	102731.6	592851.7
103	1900.0	1896.9	1520.0	349.3	227.7	1130000.0	29006.0	100142.1	102198.8	592778.6
104	1900.0	1896.9	1520.0	351.1	228.3	1130000.0	29006.0	100095.8	101629.8	592705.1
105	1900.0	1896.9	1520.0	352.9	228.9	1120000.0	29007.7	100052.2	101126.8	592668.7
106	1900.0	1896.9	1520.0	354.6	229.4	1120000.0	29007.7	100006.5	100589.8	592596.0
107	1900.0	1896.9	1520.0	356.3	230.0	1120000.0	29007.7	99961.1	100073.7	592522.9
108	1900.0	1897.0	1520.0	358.0	230.6	1110000.0	29009.4	99918.4	99570.2	592477.7
109	1900.0	1897.0	1520.0	359.7	231.1	1110000.0	29009.4	99873.6	99084.9	592405.0
110	1900.0	1897.0	1520.0	361.4	231.7	1110000.0	29009.4	99829.1	98563.0	592333.0
111	1900.0	1897.0	1520.0	363.0	232.2	1100000.0	29011.1	99787.2	98105.5	592288.0
112	1900.0	1897.0	1520.0	364.7	232.8	1100000.0	29011.1	99743.3	97623.9	592216.0
113	1900.0	1897.0	1520.0	366.3	233.3	1100000.0	29011.1	99699.6	97144.1	592144.7
114	1900.0	1897.0	1520.0	368.0	233.8	1090000.0	29012.9	99658.6	96687.5	592100.5



UNCLASSIFIED

XXXXX'SECRET'XXXXXXXX
XXXXXXXXXXXXXXXXXXXX
XXXXXXXXXXXXXXXXXXXX
XXXXXXXXXXXXXXXXXXXX

~~CONFIDENTIAL~~



~~CONFIDENTIAL~~ SECRET UNCLASSIFIED

115	1900.0	1897.0	1520.0	369.6	234.4	1090000.0	29012.9	99615.5	96246.5	592028.7
116	1900.0	1897.0	1520.0	371.2	234.9	1090000.0	29012.9	99572.6	95769.1	591957.3
117	1900.0	1897.0	1520.0	372.8	235.4	1080000.0	29014.6	99532.4	95347.2	591913.8
118	1900.0	1897.0	1520.0	374.3	236.6	1080000.0	29014.6	99490.1	94906.6	591842.4
119	1900.0	1897.0	1520.0	375.9	236.5	1090000.0	29014.6	99448.0	94467.4	591771.4
120	1900.0	1897.1	1520.0	377.4	237.0	1070000.0	29016.3	99408.6	94048.3	591728.0
121	1900.0	1897.1	1520.0	379.0	237.5	1070000.0	29016.3	99367.0	93642.7	591657.3
122	1900.0	1897.1	1520.0	380.5	238.0	1070000.0	29016.3	99325.7	93200.6	591586.6
123	1900.0	1897.1	1520.0	382.0	238.5	1060000.0	29018.0	99287.0	92814.2	591544.2
124	1900.0	1897.1	1520.0	383.5	239.0	1060000.0	29018.0	99246.1	92410.4	591473.6
125	1900.0	1897.1	1520.0	385.0	239.5	1060000.0	29018.0	99205.6	91999.4	591403.7
126	1900.0	1897.1	1520.0	386.5	240.0	1050000.0	29019.8	99167.6	91617.5	591361.3
127	1900.0	1897.1	1520.0	388.0	240.5	1050000.0	29019.8	99127.5	91237.2	591291.2
128	1900.0	1897.2	1520.0	389.4	241.0	1040000.0	29021.5	99089.8	90861.0	591248.7
129	1900.0	1897.2	1520.0	390.9	241.5	1040000.0	29021.5	99050.2	90481.6	591179.4
130	1900.0	1897.2	1520.0	392.3	242.0	1040000.0	29021.5	99010.9	90096.1	591109.8
131	1900.0	1897.2	1520.0	393.7	242.5	1030000.0	29023.2	98974.1	89741.4	591068.0
132	1900.0	1897.2	1520.0	395.2	243.0	1030000.0	29023.2	98935.1	89375.9	590998.9
133	1900.0	1897.2	1520.0	396.6	243.5	1020000.0	29024.9	98898.6	89035.7	590957.6
134	1900.0	1897.2	1520.0	398.0	244.0	1020000.0	29024.9	98860.1	88670.4	590888.7
135	1900.0	1897.2	1520.0	399.4	244.4	1020000.0	29024.9	98821.9	88306.8	590820.0
136	1900.0	1897.2	1520.0	400.7	244.9	1010000.0	29026.7	98786.1	87972.0	590778.9
137	1900.0	1897.2	1520.0	402.1	245.4	1010000.0	29026.7	98748.3	87632.1	590710.6
138	1900.0	1897.3	1520.0	403.5	245.8	1000000.0	29028.3	98712.9	87298.3	590669.3
139	1900.0	1897.3	1520.0	404.8	246.3	1000000.0	29028.3	98675.6	86964.8	590601.3

SECRET

UNCLASSIFIED

XXXXXXXXXXXXXXXXXXXX
SECRET
XXXXXXXXXXXXXXXXXXXX
XXXXXXXXXXXXXXXXXXXX

~~CONFIDENTIAL~~
UNCLASSIFIED

140	1900.0	1897.3	1520.0	406.2	246.8	1000000.0	29028.3	98638.4	86617.9	590533.1
141	1900.0	1897.3	1520.0	407.5	247.2	990000.0	29030.1	98603.7	86306.7	590493.1
142	1900.0	1897.3	1520.0	408.8	247.7	990000.0	29030.1	98566.9	85977.9	590425.1
143	1900.0	1897.3	1520.0	410.2	248.1	980000.0	29031.8	98532.4	85673.5	590385.1
144	1900.0	1897.3	1520.0	411.5	248.6	980000.0	29031.8	98496.1	85351.7	590317.6
145	1900.0	1897.3	1520.0	412.8	249.0	980000.0	29031.8	98459.9	85023.9	590250.1
146	1900.0	1897.3	1520.0	414.1	249.5	970000.0	29033.5	98426.2	84726.6	590210.4
147	1900.0	1897.3	1520.0	415.4	249.9	970000.0	29033.5	98390.4	84420.5	590143.2
148	1900.0	1897.4	1520.0	416.6	250.4	960000.0	29035.3	98356.9	84128.2	590103.4
149	1900.0	1897.4	1520.0	417.9	250.8	950000.0	29035.3	98321.5	83827.9	590036.7
150	1900.0	1897.4	1520.0	419.2	251.3	960000.0	29035.3	98286.3	83512.8	589970.1
151	1900.0	1897.4	1520.0	420.4	251.7	960000.0	29035.3	98251.4	83202.2	589903.4
152	1900.0	1897.4	1520.0	421.7	252.1	950000.0	29037.0	98218.7	82930.2	589864.2
153	1900.0	1897.4	1520.0	422.9	252.6	950000.0	29037.0	98184.1	82642.9	589797.8
154	1900.0	1897.4	1520.0	424.1	253.0	950000.0	29037.0	98149.6	82335.6	589731.4
155	1900.0	1897.4	1520.0	425.4	253.4	950000.0	29037.0	98115.3	82044.6	589665.6
156	1900.0	1897.4	1520.0	426.6	253.9	940000.0	29038.7	98083.4	81786.1	589626.9
157	1900.0	1897.4	1520.0	427.8	254.3	940000.0	29038.7	98049.3	81509.6	589561.3
158	1900.0	1897.4	1520.0	429.0	254.7	940000.0	29038.7	98015.6	81220.7	589495.4
159	1900.0	1897.4	1520.0	430.2	255.1	940000.0	29038.7	97982.0	80933.2	589429.6
160	1898.4	1895.8	1520.0	431.4	255.5	930000.0	28998.5	97897.7	79923.1	588712.2
161	1885.9	1883.4	1520.0	432.5	255.5	930000.0	28559.1	97307.8	71260.5	581510.4
162	1875.3	1872.8	1520.0	433.6	255.3	930000.0	27853.7	96381.3	54985.2	569890.4
163	1866.3	1863.8	1520.0	434.7	255.3	930000.0	27265.8	95613.5	40222.1	560112.0
164	1858.1	1855.6	1520.0	435.7	255.4	920000.0	26763.1	94942.2	29590.4	551667.7

XXXXXXXXXXXXXXXXXXXX
SECRET
XXXXXXXXXXXXXXXXXXXX
XXXXXXXXXXXXXXXXXXXX
XXXXXXXXXXXXXXXXXXXX

UNCLASSIFIED

~~CONFIDENTIAL~~



~~CONFIDENTIAL~~

XXXXXXXXXXXXXXXXXXXX
XXXXXXXXXXXXXXXXXXXX
XXXXXXXXXXXXXXXXXXXX
XXXXXXXXXXXXXXXXXXXX

UNCLASSIFIED

165	1851.0	1848.5	1520.0	436.6	255.5	920000.0	26322.3	94333.2	21159.3	544214.4
166	1844.7	1842.2	1520.0	437.6	255.5	920000.0	25941.1	93799.6	14833.3	537715.4
167	1839.0	1836.5	1520.0	438.5	255.7	920000.0	25606.1	93324.4	10840.1	531974.1
168	1833.5	1831.0	1520.0	439.4	255.8	910000.0	25298.8	92879.9	8945.6	525670.9
169	1828.5	1826.0	1520.0	440.2	255.9	910000.0	25171.3	92458.1	5070.3	521681.3
170	1823.9	1821.4	1520.0	441.1	256.0	910000.0	25140.9	92071.5	4523.4	517133.6
171	1819.6	1817.1	1520.0	441.9	256.1	910000.0	25113.0	91714.3	3579.0	512970.4
172	1815.2	1812.8	1520.0	442.7	256.2	900000.0	25086.1	91369.1	3502.7	508975.2
173	1811.1	1808.7	1520.0	443.5	256.4	900000.0	25059.6	91028.5	3889.4	505050.4
174	1807.3	1804.8	1520.0	444.2	256.5	900000.0	25034.7	90708.4	3884.4	501382.6
175	1803.6	1801.1	1520.0	445.0	256.6	900000.0	25011.2	90406.4	4431.6	497936.0
176	1799.7	1797.3	1520.0	445.7	256.7	890000.0	24988.0	90106.2	5579.2	494536.5
177	1796.1	1793.7	1520.0	446.4	256.8	890000.0	24964.6	89804.7	6030.5	491128.7
178	1792.7	1790.2	1520.0	447.1	257.0	890000.0	24942.5	89520.3	6266.8	487928.2
179	1789.4	1786.9	1520.0	447.7	257.1	890000.0	24921.6	89250.2	7101.3	484900.0
180	1786.2	1783.8	1520.0	448.4	257.2	890000.0	24901.5	88990.7	8257.5	482010.6
181	1782.8	1780.4	1520.0	449.1	257.3	880000.0	24881.4	88730.2	9040.1	479116.5
182	1779.6	1777.2	1520.0	449.7	257.4	880000.0	24860.9	88465.7	9960.0	476187.2
183	1776.5	1774.1	1520.0	450.3	257.5	880000.0	24841.2	88212.1	11216.2	473386.9
184	1773.5	1771.1	1520.0	450.9	257.6	880000.0	24822.3	87967.6	12279.7	470691.4
185	1770.6	1768.2	1520.0	451.5	257.7	880000.0	24804.1	87732.4	13173.6	468121.3
186	1767.5	1765.1	1520.0	452.1	257.8	870000.0	24785.8	87495.4	13839.7	465528.7
187	1764.6	1762.2	1520.0	452.7	257.9	870000.0	24757.0	87252.8	14772.3	462885.1
188	1761.7	1759.3	1520.0	453.2	258.0	870000.0	24749.0	87021.0	15500.8	460364.5
189	1758.0	1755.6	1520.0	453.8	258.1	870000.0	24731.8	86798.9	16238.1	457958.6

~~CONFIDENTIAL~~

XXXXXXXXXXXXXXXXXXXX
XXXXXXXXXXXXXXXXXXXX
XXXXXXXXXXXXXXXXXXXX
XXXXXXXXXXXXXXXXXXXX

UNCLASSIFIED

UNCLASSIFIED

XXXXXXXXXXXXXXXXXXXX
XXXXXXXXXXXXXXXXXXXX
XXXXXXXXXXXXXXXXXXXX
XXXXXXXXXXXXXXXXXXXX
XXXXXXXXXXXXXXXXXXXX

~~SECRET~~

190	1756.4	1754.0	1520.0	454.3	258.2	870000.0	24715.3	86585.6	16440.3	455657.6
191	1753.5	1751.2	1520.0	454.8	258.3	860000.0	24698.7	86369.7	17569.2	453340.0
192	1750.8	1748.4	1520.0	455.4	258.4	860000.0	24681.4	86147.2	18400.4	450949.1
193	1748.1	1745.8	1520.0	455.9	258.4	860000.0	24654.9	85934.2	19123.1	448662.6
194	1745.6	1743.3	1520.0	456.4	258.5	860000.0	24649.0	85729.7	19882.4	446478.6
195	1743.2	1740.8	1520.0	456.8	258.6	860000.0	24633.8	85532.7	20657.6	444381.8
196	1740.5	1738.2	1520.0	457.3	258.7	850000.0	24618.2	85331.9	21224.8	442253.3
197	1738.0	1735.6	1520.0	457.8	258.8	850000.0	24602.2	85125.1	21534.2	440059.4
198	1735.5	1733.2	1520.0	458.2	258.8	850000.0	24586.9	84928.7	21878.2	437978.8
199	1733.2	1730.9	1520.0	458.7	258.9	850000.0	24572.4	84741.4	22365.2	436004.4
200	1731.0	1728.7	1520.0	459.1	259.0	850000.0	24558.4	84561.4	22899.6	434114.4
201	1728.5	1726.2	1520.0	459.6	259.1	840000.0	24544.2	84377.7	23300.2	432191.2
202	1726.2	1723.9	1520.0	460.0	259.1	840000.0	24529.4	84187.3	23479.7	430202.1
203	1723.9	1721.6	1520.0	460.4	259.2	840000.0	24515.4	84007.1	23732.4	428316.5
204	1721.8	1719.5	1520.0	460.8	259.3	840000.0	24502.1	83835.1	24108.5	426520.2
205	1719.4	1717.1	1520.0	461.2	259.3	830000.0	24488.4	83659.1	24376.7	424697.6
206	1717.2	1714.9	1520.0	461.6	259.4	830000.0	24474.2	83476.7	24403.0	422802.6
207	1715.0	1712.7	1520.0	462.0	259.4	830000.0	24460.8	83304.6	24550.1	421022.6
208	1713.0	1710.7	1520.0	462.4	259.5	830000.0	24448.0	83140.6	24871.2	419322.9
209	1710.7	1708.4	1520.0	462.7	259.5	820000.0	24434.9	82972.3	25074.9	417590.1
210	1708.5	1706.3	1520.0	463.1	259.6	820000.0	24421.3	82797.5	25036.4	415792.7
211	1706.4	1704.2	1520.0	463.5	259.6	820000.0	24408.4	82632.7	25082.8	414094.4
212	1704.5	1702.2	1520.0	463.8	259.7	820000.0	24396.2	82476.0	25337.8	412487.7
213	1702.3	1700.0	1520.0	464.2	259.7	810000.0	24383.6	82314.7	25523.4	410841.6

XXXXXXXXXXXXXXXXXXXX
XXXXXXSECRET
XXXXXXXXXX...
XXXXXXXXXXXXXXXXXXXX

UNCLASSIFIED

~~SECRET~~

[REDACTED]
[REDACTED]
SECRET
[REDACTED]

[REDACTED]

UNCLASSIFIED

[REDACTED]

FOR THE

SECRET

[REDACTED]

UNCLASSIFIED

[REDACTED]

OSR 3-17

DON'T SAY IT - WRITE IT

TO D. A. WARD LOCATION 773A DATE 2/18/82
FROM BETTY JOHNSON PHONE NO. 2147 LOCATION 773A-TIS

We have a request from Regina Harris, DOE/SR for DPST-70-433.

Please initial BJW.

Preventive Safety - Prevents Injuries