

663343  
DP-1306

AEC RESEARCH AND DEVELOPMENT REPORT

# FORCED-CONVECTION SUBCOOLED CRITICAL HEAT FLUX

D<sub>2</sub>O AND H<sub>2</sub>O COOLANT WITH ALUMINUM  
AND STAINLESS STEEL HEATERS

D. H. KNOEBEL  
S. D. HARRIS  
B. CRAIN, JR.  
R. M. BIDERMAN

**RECORD  
COPY**

DO NOT RELEASE  
FROM FILE



*Savannah River Laboratory*

*Aiken, South Carolina*

**NOTICE**

This report was prepared as an account of work sponsored by the United States Government. Neither the United States nor the United States Atomic Energy Commission, nor any of their employees, nor any of their contractors, subcontractors, or their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness or usefulness of any information, apparatus, product or process disclosed, or represents that its use would not infringe privately owned rights.

Printed in the United States of America  
Available from  
National Technical Information Service  
U. S. Department of Commerce  
5285 Port Royal Road  
Springfield, Virginia 22151  
Price: Printed Copy \$3.00; Microfiche \$0.95

663343

DP-1306

Engineering & Equipment  
(TID-4500, UC-38)

## FORCED-CONVECTION SUBCOOLED CRITICAL HEAT FLUX

D<sub>2</sub>O AND H<sub>2</sub>O COOLANT WITH ALUMINUM  
AND STAINLESS STEEL HEATERS

by

D. H. Knoebel  
S. D. Harris  
B. Crain, Jr.

and

R. M. Biderman  
Heat Transfer Research Facility  
Columbia University  
New York, N.Y.

Approved by

J. M. Boswell, Research Manager  
Reactor Engineering Division

February 1973

E. I. DU PONT DE NEMOURS & COMPANY  
SAVANNAH RIVER LABORATORY  
AIKEN, S. C. 29801

CONTRACT AT(07-2)-1 WITH THE  
UNITED STATES ATOMIC ENERGY COMMISSION

## ABSTRACT

Forced-convection critical heat flux data and correlations are presented for both heavy water ( $D_2O$ ) and light water ( $H_2O$ ) coolant. The data were obtained with stainless steel and aluminum heaters which formed the inner wall of an annular channel. The critical heat flux for  $D_2O$  was determined to be 16% greater than that for  $H_2O$  at the same coolant velocity and subcooling. The critical heat flux for aluminum heaters was determined to be at least 20% higher than that for stainless steel at the same coolant velocity and subcooling. A brief discussion of possible mechanisms for the difference is included. A combined improvement of 40% in the burnout heat flux is shown for aluminum heaters with  $D_2O$  coolant over that for stainless steel heaters with  $H_2O$  coolant. The results are for ideal heaters. When using the equations discussed in this report, factors must be applied for nonidealities such as the effect of spacer ribs.

## CONTENTS

	<u>Page</u>
Introduction . . . . .	5
Summary . . . . .	6
Discussion . . . . .	7
Experimental Equipment and Procedure . . . . .	7
SRL Test Loop . . . . .	7
Columbia University Test Facility . . . . .	9
Results . . . . .	11
H <sub>2</sub> O Coolant and Stainless Steel Heaters . . . . .	11
D <sub>2</sub> O Coolant and Stainless Steel Heaters . . . . .	17
Aluminum Surface and H <sub>2</sub> O Coolant . . . . .	19
Background . . . . .	19
Results . . . . .	19
Aluminum Surface and D <sub>2</sub> O Coolant . . . . .	21
Correlation of Data . . . . .	21
Appendices	
A. Nomenclature . . . . .	31
B. Critical Heat Flux Data . . . . .	33
References . . . . .	55

## LIST OF TABLES AND FIGURES

<u>Table</u>		<u>Page</u>
I	Summary of Test Conditions . . . . .	7
II	Properties of Light and Heavy Water . . . . .	24
III	Properties of Stainless Steel and Aluminum . . . . .	26
 <u>Figure</u>		
1	Schematic of SRL Flow Loop . . . . .	8
2	Schematic of Columbia University Low Pressure Loop . . . . .	10
3	SRL Critical Heat Flux Results With Stainless Steel Surfaces and H <sub>2</sub> O Coolant . . . . .	12
4	Columbia University Critical Heat Flux Results With Stainless Steel Heaters and H <sub>2</sub> O Coolant . . . . .	14
5	SRL Critical Heat Flux With 2-inch-wide Rectangular Channel With Stainless Steel Heaters and H <sub>2</sub> O Coolant . . . . .	15
6	Critical Heat Flux at Low Subcooling With Stainless Steel Heaters and H <sub>2</sub> O Coolant . . . . .	16
7	Critical Heat Flux Results With Stainless Steel Heaters and D <sub>2</sub> O Coolant . . . . .	18
8	Critical Heat Flux Results for Aluminum Heaters and H <sub>2</sub> O Coolant . . . . .	20
9	Effect of Aluminum Oxide on the Critical Heat Flux . . . . .	22
10	Critical Heat Flux With Aluminum Heaters and D <sub>2</sub> O Coolant . . . . .	23
11	Comparison of Generalized Correlation With All Critical Heat Flux Data . . . . .	25
12	Comparison of Equation 5 With Cu-Ni Critical Heat Flux Data . . . . .	27
13	Effect of Aluminum Heater Thickness on The Critical Heat Flux . . . . .	28

## INTRODUCTION

A reactor at the Savannah River Plant has operated at the highest neutron flux ever achieved in a nuclear reactor,  $\sim 6.1 \times 10^{15}$  n/(cm<sup>2</sup>-sec). This neutron flux was attained by operating at heat fluxes in excess of 2.66 million Btu/(hr-ft<sup>2</sup>).

The Savannah River Laboratory and Columbia University have been engaged in studies to define the critical heat flux for subcooled nucleate boiling. The results of these studies are used in optimization of the fuel assembly design and in developing specifications for components required to achieve the very high power densities. Initial efforts were aimed at relating the heat flux to the usual variables of velocity, temperature, pressure, and geometry. In addition, the effect of many nonidealities which lower the burnout heat flux, e.g., spacer ribs and local hot spots, were also studied.<sup>1-4</sup>

The Savannah River fuel geometry consists of annuli through which D<sub>2</sub>O flows past the bounding fuel surfaces. Coolant conditions range up to velocities of 70 ft/sec, pressures of  $\sim 150$  psia, and effluent temperatures of about 180°F.<sup>1</sup>

Most of the experimental studies before 1967 were made with stainless steel or copper-nickel heaters because of power and current limitations at SRL, even though coextruded aluminum-clad, uranium-aluminum alloy fuel tubes are used in the Savannah River Plant reactors. Also, light water (H<sub>2</sub>O) was used as a coolant in place of D<sub>2</sub>O.

More recent studies (after 1967) have been concerned with the accuracy of critical heat flux data, effect of coolant, and effect of heater material. The initial mathematical correlation based on improved data obtained with stainless steel heaters and H<sub>2</sub>O coolant was presented earlier.<sup>5</sup> This report presents the data used in the earlier correlation along with recent critical heat flux results obtained with stainless steel heaters with D<sub>2</sub>O, aluminum heaters with H<sub>2</sub>O, and aluminum heaters with D<sub>2</sub>O. Correlation of these groups of data is presented. A generalized empirical correlation of all the data is also presented.

## SUMMARY

Empirical correlations of the critical heat flux are presented for individual data groups (stainless steel heaters - H<sub>2</sub>O coolant; stainless steel heaters - D<sub>2</sub>O coolant; aluminum heaters - H<sub>2</sub>O coolant; and aluminum heaters - D<sub>2</sub>O coolant). These correlations are applicable to subcoolings greater than 45°F and should not be extrapolated beyond coolant conditions shown in Table I; however, the results can be applied to surfaces longer than 24 inches. The critical heat flux for D<sub>2</sub>O is 16% greater than for H<sub>2</sub>O at constant coolant subcooling and velocity. The critical heat flux of aluminum heaters is a minimum of 20% greater than for stainless steel. The combined effect of D<sub>2</sub>O coolant and aluminum surfaces is a 40% increase in critical heat flux compared to that for H<sub>2</sub>O coolant and stainless steel surfaces.

The results presented in this report are for ideal surfaces and do not include allowances for nonideal effects such as spacer ribs on the critical heat flux. Studies concerning the presence of ribs and other nonideal effects are in progress.



## DISCUSSION

### EXPERIMENTAL EQUIPMENT AND PROCEDURE

Experimental data were obtained at the Columbia University Heat Transfer Facility and the Savannah River Heat Transfer Laboratory. The ranges of test conditions are summarized in Table I.

TABLE I  
Summary of Test Conditions<sup>a</sup>

Laboratory	Material	Heater		Coolant		
		Diameter or Width, inches	Length, inches	Material	Equivalent Diameter, inches	Geometry
Savannah River	Stainless Steel	0.5	24	H <sub>2</sub> O	0.375	annular
Savannah River	Stainless Steel	0.5	24	D <sub>2</sub> O	0.375	annular
Savannah River	Stainless Steel	2.0	20	H <sub>2</sub> O	0.4 - 0.5	rectangular
Columbia	Stainless Steel	2.125	24	H <sub>2</sub> O	0.4	annular
Columbia	Stainless Steel	0.75	24	H <sub>2</sub> O	0.4	annular
Columbia	Stainless Steel	0.75	24	D <sub>2</sub> O	0.4	annular
Columbia	Aluminum	0.75	24	H <sub>2</sub> O	0.4	annular
Columbia	Aluminum	0.75	24	D <sub>2</sub> O	0.4	annular
Columbia	Aluminum	1.00	24	H <sub>2</sub> O	0.4	annular

a. Range of Test Conditions:

Coolant velocity	15-60 ft/sec.
Coolant subcooling	7-160°F <sup>b</sup>
Critical heat flux	1-6.5 x 10 <sup>6</sup> Btu/(hr-ft <sup>2</sup> )
Pressure	30-95 psia

Burnout Detection:

SRL	- visual observation of incandescent spot
CU	- bridge-type detector or physical failure

b. Data below 45°F subcooling not used in correlations (See Figure 6)

### SRL Test Loop

The flow loop and test section cross section at SRL are shown schematically in Figure 1. The loop consists of a pump, deionizer, surge tank, heat exchanger, and the test section. The loop was filled with distilled water. The water was deionized and degassed at the beginning of each day of testing. Flow is measured with a Potter turbine flow meter. Maximum flow rate is 60 gpm. Water enters the top of the test section and flows downward past the heater. Both inlet and outlet temperatures are recorded. Outlet pressure and pressure drop across the test




FIG. 1 Schematic of SRL Flow Loop

section are also recorded. Heat is generated by resistance heating with DC power. Eight welding generators connected in parallel provide 320 KW at 8000 amp DC.<sup>6</sup>

Tests are made at constant power and flow by increasing the bulk temperature to the point of burnout (point at which the critical heat flux is exceeded). By interrupting a test when a spot on the heater glowed red (before physical burnout), multiple, reproducible tests could be made on the same heater. As-drawn annealed stainless steel tubing was used to fabricate the heaters. No special precautions were taken to ensure uniform surface finish on the test sections, except that heaters with circumferential scratches or marks were not used.

An initial check test was run on each heater. This check test was repeated after approximately every five tests. If the check test varied by more than 5% from the original check test, the heater was discarded. A change in critical heat flux for the same experimental conditions was usually caused by bowing of the heater. Alignment of the heater and housing was one of the most important factors in obtaining reproducible data. The heaters have four alignment pins, 2.5 inches from the end of the heated length on either end.

#### Columbia University Test Facility

The Columbia University Heat Transfer Facility has a 3.5 MW DC power supply from two motor generator sets. The generators are connected in parallel and can supply a maximum of 20,000 amp at 175 volts. This power source was used to heat test elements under simulated reactor conditions.

The Columbia test loop (Figure 2) has a maximum pressure rating of 250 psig and consisted of two centrifugal pumps, three shell and tube heat exchangers, a deionizer, a piston pump to control pressure, connecting piping, and a housing section to accommodate test sections. Two pumps connected in series are capable of providing 200 gpm at 350 ft differential head. The loop piping is stainless steel, but aluminum and copper did contact the water as part of the test section. The water was deionized and deaerated before each series of tests.

The flow rate was measured by a Potter turbine flow meter, and the inlet and outlet temperatures to the test section were measured by iron-constantan thermocouples and a temperature sensor. The inlet and exit pressures were measured by Bourdon-tube pressure gages, and the pressure drop across the heated length of a simulated fuel rod was measured with a U-tube manometer.




FIG. 2 Schematic of Columbia University Low Pressure Loop

The aluminum heaters were constructed of Type 5052 aluminum drawn over ceramic spacers. The heaters were installed vertically with the cooling water flowing downward. The test sections had a heated length of 2 ft and an overall length of 6 ft. The heater formed the inner wall of the coolant annulus. The outer wall was constructed of aluminum sleeves designed to give the desired equivalent diameter. The extension pieces which comprised most of the length of the test section were either Type 6061 aluminum, nickel 200, or electrolytic copper. The electrical connectors at the ends of the test section were silver-plated copper.

Thermal expansion of the test section was permitted by "O"-ring seals on the top and bottom. Counterweighting the heavy bus connectors prevented large tensile or compressive forces on the test section and also increased the reliability of the joints of the test section.

The concentricity of the heater tube in the annulus was maintained by three sets of spacer pins mounted in the wall of the outer annular surface. Three asbestos phenolic pins in each set were spaced at 120° intervals. The pins contacted the heater with a concave surface, which matched the curvature of the heater tube. Six sets of three pins each were used in later tests to improve concentricity.

Tests were conducted at constant flow and exit bulk temperature. The inlet temperature was decreased as the power (heat flux) was increased to the point of burnout. Multiple tests could be made on a stainless steel heater by using a resistance bridge burnout detector to terminate the test before heater destruction. Some test conditions were recorded as safe operating points with aluminum heaters to avoid heater destruction. (The low melting point of the aluminum and high power density made use of a burnout detector impractical.)

## RESULTS

### H<sub>2</sub>O Coolant and Stainless Steel Heaters

The SRL H<sub>2</sub>O results (Figure 3 and Table B-1) are correlated by the following empirical equation:\*

$$\frac{Q}{A} \Big|_{Cr} = 153,600 (1 + 0.0515 V)(1 + 0.069 T_{sub}) \quad (1)$$

---

\* The nomenclature is given on page 31.




FIG. 3 SRL Critical Heat Flux Results With Stainless Steel Surfaces and H<sub>2</sub>O Coolant

The correlation is based on 132 experimental burnout points (through test 835 in Table B-1) obtained with 10 different heaters. The standard deviation was 3.5%. The correlation has been verified by an additional 106 points obtained on 10 additional heaters (tests after 835 in Table B-1). The tests before test 619 were used to develop data acquisition techniques and to determine control required to obtain reproducible data. After test 619, all data were recorded on recorders. The correlation of the additional 106 points had a standard deviation of 4.4%. The magnitude of the standard deviation and the maximum deviation (10%) indicate that the scatter in the data can be attributed to experimental errors. Data for subcooling below 45°F subcooling were not used in the correlation because of additional void effects below this subcooling. Data obtained on bowed heaters, on heaters with fabrication defects, or in tests with poor heat balances were excluded from the analysis. Equation 1 was based on SRL data for one geometry, i.e., annular downward flow with ½-inch-OD x 24-inch-long heaters and a 0.875-inch-ID housing.

However, the Columbia University data (Figure 4, Table B-2) on both ¾-inch and 2.1-inch-OD heaters agree well with Equation 1, although the scatter of these results is more than with the SRL results. Approximately 200 tests were conducted at Columbia University. The first tests (138 total) were conducted using an inflexible mandrel-type heater design. Acceptable data were not obtained with this design (large scatter and no reproducibility); therefore, all these results were discarded. Other results were discarded because of heater defects, poor alignment, or poor heat balances. The remaining 27 points are shown in Figure 4.

Critical heat flux data were obtained by Thorgerson<sup>7</sup> at SRL with a 2-inch-wide rectangular channel heated from one side. These data (68 points), shown in Figure 5 and Table B-3, agree very well with Equation 1. Thorgerson's data for gap thicknesses of 0.2 to 0.24 inches had a standard deviation of 5.9% and a maximum deviation of 14% from Equation 1.

The improved correlation of data over previous studies<sup>2-4</sup> can be attributed to better data acquisition. Furthermore, by limiting the correlations to subcoolings greater than 45°F, the correlations are even better. As shown in Figure 6, there is a distinct break below 45°F in the curve of critical heat flux as a function of subcooling at constant mass velocity or linear velocity based on inlet volumetric flow rate. The break in the curve can be accounted for by increased vapor volume at the critical condition, which causes an increase in the local velocities for uniformly heated tubes; hence, the increased critical heat fluxes.




FIG. 4 Columbia University Critical Heat Flux Results With  
 Stainless Steel Heaters and H<sub>2</sub>O Coolant






FIG. 5 SRL Critical Heat Flux With 2-inch-wide Rectangular Channel With Stainless Steel Heaters and H<sub>2</sub>O Coolant




FIG. 6 Critical Heat Flux at Low Subcooling With Stainless Steel Heaters and H<sub>2</sub>O Coolant

The results presented in Figures 3, 4, and 5 were obtained at pressures of 30, 55, and 95 psia. No pressure effect was apparent for subcoolings greater than 45°F. However, at lower subcoolings (<45°F) there was a pressure effect, but additional data are required to verify the extent of the effect.

Equation 1 has been compared with a number of other critical heat flux correlations by Gambill.<sup>5</sup> He compared his correlation with Equation 1, Mirshak and Towell,<sup>4</sup> Provornin and Semonov,<sup>8</sup> and Griffel.<sup>9</sup> The critical heat fluxes agreed reasonably well. However, both Mirshak and Towell and Griffel developed correlations applicable to subcoolings below and above 45°F, which accounts for some of the differences between those correlations and Equation 1. Equation 1 predicts critical heat fluxes about 41% higher than the correlation in Reference 2 at 135°F subcooling, 50 psia, and 25 ft/sec, and about 23% lower at 45°F subcooling, 50 psia, and 25 ft/sec. The data in Figure 3 have been correlated quite well with Reynolds' analogy.<sup>7</sup>

## D<sub>2</sub>O Coolant and Stainless Steel Heaters

The critical heat fluxes for D<sub>2</sub>O are correlated by the following equation and are summarized in Figure 7 and Tables B-4 and B-5.

$$\frac{Q}{A} \Big|_{Cr} = 178,000 (1 + 0.0515 V)(1 + 0.069 T_{sub}) \quad (2)$$

The data include 37 points obtained at SRL and 6 points obtained at Columbia University. The standard deviation from the correlation is less than 4%.

Because of the possibility that critical heat fluxes for D<sub>2</sub>O might be higher than for H<sub>2</sub>O, studies were initiated to better define the critical heat flux with D<sub>2</sub>O coolant. Because of the high cost of D<sub>2</sub>O (~\$30/lb), special precautions were taken to reduce losses. The D<sub>2</sub>O used at SRL was 93% D<sub>2</sub>O and 7% H<sub>2</sub>O. Similarly, data at Columbia University were obtained with 90% D<sub>2</sub>O and 10% H<sub>2</sub>O. Because the SRL data for D<sub>2</sub>O were obtained with the same apparatus and type of heaters as used for the H<sub>2</sub>O data, the comparison of these data should indicate quite accurately differences in the critical heat flux due to coolant. The critical heat flux for D<sub>2</sub>O measured in the tests is 16% higher than that for H<sub>2</sub>O at the same velocity and approximately 8.5% higher at the same mass velocity. The critical heat flux is estimated to be 1% higher for 99.97% D<sub>2</sub>O (linear extrapolation).




FIG. 7 Critical Heat Flux Results With Stainless Steel Heaters and D<sub>2</sub>O Coolant

## Aluminum Surface and H<sub>2</sub>O Coolant

### *Background*

The effect of heater material on the critical heat flux has been investigated with pool boiling conditions.<sup>10,11</sup> Tests indicated that although stainless steel and copper had equivalent critical heat fluxes, critical heat fluxes for aluminum were up to 20% greater. Because the thermal properties of copper are much better than those of aluminum and because the critical heat fluxes for copper agree with those for stainless steel, the higher critical heat flux for aluminum at pool boiling conditions cannot be attributed to the thermal properties.

Previous work at Savannah River Laboratory indicated that critical heat fluxes for aluminum with forced convection cooling were higher than those for stainless steel. These tests were limited by the power supply at SRL. In 1966, a program was begun at Columbia University to measure the burnout heat fluxes with aluminum surfaces over a broader range. Initial heater designs at Columbia University contained an indirectly heated aluminum tube two inches in diameter (stainless steel heater electrically insulated from an outer aluminum sheath). Thermal expansion and assembly problems limited operation to heat fluxes below about  $1.5 \times 10^6$  Btu/(hr-ft<sup>2</sup>). Higher heat fluxes were subsequently obtained with direct resistance heating of aluminum heaters with diameters of 0.75- and 1.0-inch.

### *Results*

The critical heat flux results for aluminum heaters and H<sub>2</sub>O coolant included 18 tests with physical burnout, 22 tests with safe operating points with critical heat fluxes more than 20% greater than stainless steel at equivalent coolant conditions, and 20 tests with safe operating points with critical heat fluxes between 15 and 20% greater than stainless steel heaters. These results are correlated by the following equation and are shown in Figure 8 and Table B-6.

$$\frac{Q}{A} \Big|_{Cr} = 188,000 (1 + 0.0515 V)(1 + 0.069 T_{sub}) \quad (3)$$

Deviations from the correlation ranged from -6.6% to +16% for heater thicknesses of 0.020, 0.028, and 0.035 inches.

Critical heat fluxes were also determined for aluminum-oxide-coated aluminum heaters. The oxide coatings were formed either




FIG. 8 Critical Heat Flux Results for Aluminum Heaters and H<sub>2</sub>O Coolant

by a commercial anodizing process or by steam autoclaving at SRL. The anodized heaters obtained from the first vendor had a specified oxide thickness of 1 mil. After several tests, the oxide was measured to be a minimum of 2.4 mils thick. The oxide layers formed by autoclaving at SRL were up to 0.6-mil thick, and the anodized heaters from a second vendor had a maximum oxide thickness of 1.4 mils. There were significant differences in the thermal conductivity of the oxides [0.4 to 0.7 Btu/(hr-ft-°F)]. The thermal conductivities were calculated from the known oxide thickness, the heat flux at failure, an estimated surface temperature of 360°F based on some special surface temperature measurements at SRL, and the internal surface temperature equal to the melting point of aluminum at the time of failure. The oxide thickness was determined by metallographic sectioning and measurement of the oxide thickness on a 1000X photograph of the section.

Test sections that operated at heat fluxes corresponding to internal temperatures in excess of 1100°F failed by internal melting instead of local burnout. Internal melting was verified in several tests by an internal thermocouple. The results of these tests are summarized in Figure 9 and Table B-7. The oxide did not directly affect the critical heat flux, but did limit the operating heat flux when the large temperature gradients across the oxide layer caused internal melting.

#### Aluminum Surface and D<sub>2</sub>O Coolant

Several tests conducted with aluminum heaters and D<sub>2</sub>O coolant are summarized in Table B-8. The observed critical heat fluxes are correlated by the following equation, which predicts critical heat fluxes 40% greater than for H<sub>2</sub>O and stainless surfaces:

$$\frac{Q}{A} \Big|_{Cr} = 218,000 (1 + 0.0515 V)(1 + 0.069 T_{Sub}) \quad (4)$$

Data shown in Figure 10 are compared to Equation 4 and verify the independent increase in critical heat flux of 20% for aluminum over stainless steel surfaces and of 16% for D<sub>2</sub>O over H<sub>2</sub>O coolant discussed earlier.

#### CORRELATION OF DATA

The correlation of all the data presented for D<sub>2</sub>O, H<sub>2</sub>O, stainless steel, and aluminum based on a least squares regression analysis is:




FIG. 9 Effect of Aluminum Oxide on the Critical Heat Flux






FIG. 10 Critical Heat Flux With Aluminum Heaters and D<sub>2</sub>O Coolant

$$\frac{Q}{A} \Big|_{Cr} = 1360 \left( \frac{We}{Re} \right)_C^{0.573} \left( \rho C_p T_{sub} \right)_C^{0.759} \left( \rho C_p \right)_H^{0.621} \left( k \right)_H^{0.190} \quad (5)$$

This empirical correlation fits the data with a standard deviation of 4.8% and a maximum deviation of 16%. The data are compared with this equation in Figure 11.

The most striking differences in physical properties between H<sub>2</sub>O and D<sub>2</sub>O at 262°F are density, viscosity, and heat of vaporization as indicated in Table II. Although the density affects the volumetric heat capacity, and the viscosity represents a measure of the shear stress in the laminar sublayer, factors containing only density and viscosity have not been applied quantitatively with success to correlate critical heat flux data.

TABLE II  
Properties of Light Water and Heavy Water

Property	Evaluated Temperature	H <sub>2</sub> O Value	D <sub>2</sub> O Value	% D <sub>2</sub> O Contribution
T <sub>sat</sub> , °F	-	312	313	+ 0.321
T <sub>bulk</sub> , °F	-	212	213	+ 0.472
$\bar{T}$ , °F	-	262	263	+ 0.382
$\mu$ , lb <sub>m</sub> /(ft-hr)	$\bar{T}$	0.5082	0.5566	+ 9.52
$\sigma$ , lb <sub>f</sub> /ft	$\bar{T}$	0.3542 x 10 <sup>-2</sup>	0.3501 x 10 <sup>-2</sup>	- 1.16
(We/Re)	$\bar{T}$	0.0372	0.0411	+10.4
$\rho$ , lb <sub>m</sub> /ft <sup>3</sup>	$\bar{T}$	58.5	64.9	+10.9
c <sub>p</sub> , Btu/(lb <sub>m</sub> -°F)	$\bar{T}$	1.02	0.994	- 2.55
$\rho c_p$ , Btu/(ft <sup>3</sup> -°F)	$\bar{T}$	59.7	64.5	+ 8.04
$\rho$ , lb <sub>m</sub> /ft <sup>3</sup>	T <sub>sat</sub>	57.0	63.1	+10.7
$\lambda$ , Btu/lb <sub>m</sub>	T <sub>sat</sub>	901	824	- 8.55
$\rho \lambda$ , Btu/ft <sup>3</sup>	T <sub>sat</sub>	51,300	52,000	+ 1.36
k, (Btu-ft)/(hr-ft <sup>2</sup> -°F)	$\bar{T}$	0.396	0.371	- 6.31

The ratio of the Weber and Reynolds numbers in Equation 5 can be interpreted as the ratio of viscous forces to surface tension forces acting on a bubble at the surface. The viscous forces are attempting to remove the bubble (delaying burnout), and the surface tension forces are attempting to retain the bubble on the surface. The choice of the ratio of Weber and Reynolds Numbers is based on




FIG. 11 Comparison of Generalized Correlation With All  
 Critical Heat Flux Data

Chang's analysis.<sup>13</sup> The second term in Equation 5 ( $\rho C_p T_{\text{sub}})_C$  expresses the heat removal capacity of the coolant on a unit volume basis. This term includes both the effects of coolant subcooling and of variation in the volumetric heat capacity of the coolant.

The third term  $(\rho C_p)_H$  and fourth term  $(k)_H$  in the correlation are the volumetric heat capacity and thermal conductivity of the heater, respectively. These terms express the ability of the heater surface to absorb heat and to fin heat away from hot spots on the surface. Unlike pool boiling behavior previously discussed, the thermal properties of the heater are important at forced flow conditions. The differences in the properties of stainless steel and aluminum are summarized in Table III.

TABLE III  
Properties of Stainless Steel and Aluminum

Property	Stainless Steel Value	Aluminum Value	Aluminum Contribution, %
$k, (\text{Btu}\cdot\text{ft})/(\text{hr}\cdot\text{ft}^2\cdot^\circ\text{F})$	10.0	117.0	+1070.0
$\rho, \text{lb}_m/\text{ft}^3$	501.0	167.0	- 66.7
$c_p, \text{Btu}/(\text{lb}_m\cdot^\circ\text{F})$	0.120	0.245	+ 104.0
$\rho c_p, \text{Btu}/(\text{ft}^3\cdot^\circ\text{F})$	60.1	40.9	- 31.9

Equation 5 was also compared with some earlier critical heat flux data obtained with Cu-Ni heaters and H<sub>2</sub>O coolant (Figure 12).<sup>2</sup> The average deviation of these data from Equation 5 is ~16%. This error could be decreased by including these data in the correlation. However, the functional dependence of Equation 5 on heater properties would still at best be empirical.

Because of the limited range of data used in Equation 5, the functional dependence of the critical heat flux on coolant and heater physical properties can be very misleading. This is apparent in the comparison with Cu-Ni data of Figure 12. Hence, Equation 5 is applicable only to the range of data, coolant types, and heater materials summarized in Table I.

The data in Figure 13 indicate an effect of heater thickness on the critical heat flux. Available data<sup>10,12</sup> for thin stainless steel heaters also indicate that the critical heat flux is a




FIG. 12 Comparison of Equation 5 With Cu-Ni Critical Heat Flux Data




FIG. 13 Effect of Aluminum Heater Thickness on The Critical Heat Flux

function of heater thickness. For stainless steel, this effect disappears at a thickness of 0.004 inch. Because of the factor of 12 difference in thermal conductivities, the critical heat flux for aluminum would approach an asymptotic value at about 0.050 inches which is verified by the trend shown in Figure 13.

In an attempt to understand the increased critical heat fluxes for aluminum versus stainless steel, an analytical model was developed for computer analyses. The model accounted for internal conduction and used surface heat transfer coefficients as a function of surface temperature. Burnout was initiated on the surface by decreasing the heat transfer coefficient at a local area to one-tenth the steady state value. This reduction represents placement of a vapor film on the surface. The heat transfer coefficient was held constant for some fixed time and was then allowed to follow the temperature dependence model. The surface then either recovered or melted. The time which represented the point between recovery or melting was a function of hydrodynamic conditions. This dynamic model did indicate that stainless steel should not have as high a critical heat flux as aluminum, but this analysis could not indicate magnitudes. The result of this theoretical study indicated that the difference was due to the time scale of burnout and the finning ability of that portion of the heater with temperatures below the Leidenfrost point. Note that a heater material effect based on thermal properties would not be applicable at pool boiling conditions, where the vapor films are large, and the buoyancy forces and vapor residence times are controlling.

The equations presented in this report are applicable only to ideal surfaces. Preliminary studies at Savannah River Laboratory to determine the effect of a 60-mil spacer rib contacting a stainless steel or aluminum heater indicate as much as a 40% reduction in the respective critical heat flux predicted by the ideal correlations. The reduction in heat flux by the rib is a function of the subcooling and velocity.





## APPENDIX A

### NOMENCLATURE

$\frac{Q}{A}|_{Cr}$  = critical heat flux, Btu/(hr-ft<sup>2</sup>)

$\frac{We}{Re}$  = ratio of the Weber Number to the Reynolds Number,  
 $\frac{\mu V}{\sigma g_c}$

We = Weber Number,  $\frac{V^2 D \rho}{\sigma g_c}$  \*

Re = Reynolds Number,  $\frac{V \rho D}{\mu}$

$\bar{T}$  = film temperature,  $(T_{sat} + T_{bulk})/2$ , °F

$T_{sub}$  = coolant subcooling  $(T_{sat} - T_{bulk})$ , °F

$T_{sat}$  = coolant saturation temperature, °F

$T_{bulk}$  = bulk coolant temperature, °F

D = diameter of bubble on heater surface, ft

$D_e$  = coolant channel equivalent diameter, in

V = coolant velocity, ft/sec

$g_c$  = gravitational constant,  $(lb_m \cdot ft)/(lb_f \cdot sec^2)$

$c_p$  = specific heat capacity, Btu/(lb<sub>m</sub>·°F)

k = thermal conductivity,  $(Btu \cdot ft)/(hr \cdot ft^2 \cdot °F)$

$\mu$  = coolant viscosity, lb<sub>m</sub>/(ft·sec)

$\sigma$  = surface tension, lb<sub>f</sub>/ft

$\lambda$  = heat of vaporization, Btu/lb<sub>m</sub>

$\rho$  = density, lb<sub>m</sub>/ft<sup>3</sup>

Subscripts: C = coolant  
H = heater

---

\* All coolant properties except heat of vaporization were evaluated at film temperature; heat of vaporization was evaluated at saturation temperature. Heater properties were evaluated at saturation temperature.



## APPENDIX B

### CRITICAL HEAT FLUX DATA

The following data are tabulated in this appendix.

Run Number

Heater ID — identification, if known

Length, inch

Dia. — diameter or width of rectangular channel, inch

Thick. — thickness, inch

Coolant Channel Equivalent diameter, inch

Pressure drop, psi

Conditions at point of burnout

Pressure, psia

Velocity, ft/sec

Subcooling, °F

Critical heat flux, Btu/hr-ft<sup>2</sup>

Comments pertinent to test data exclusion from correlations

1. Subcooling less than 45°F
2. No burnout
3. Heater bowed or damaged during previous test
4. Flaws in heater fabrication
5. Poor heat balance
6. Safe operating point — flux too low to validate appropriate correlation
7. Pressure effect — observed only at 95 psia and velocity of 15 ft/sec

TABLE B-1  
 CRITICAL HEAT FLUX DATA  
 STAINLESS STEEL - LIGHT WATER SAVANNAH RIVER LABORATORY

RUN NUMBER	ID	HEATER LENGTH IN.	HEATER DIA. IN.	HEATER THICK. IN.	COOLANT CHANNEL EQUIV. DIA. IN.	PRESSURE DROP PSI	LOCAL PRESSURE PSIA	COOLANT VELOCITY FT/SEC	CONDITIONS AT BURNOUT SUBCOOLING DEG F	CRITICAL HEAT FLUX 10 <sup>6</sup> BTU/HR-SQFT	COMMENTS
619	D7	24.0	0.500	0.120	0.375	7.85	55.38	30.08	95.17	3.076	
620	D7	24.0	0.500	0.120	0.375	7.85	54.39	29.91	88.22	2.878	
621	D7	24.0	0.500	0.120	0.375	7.46	55.93	29.80	72.70	2.421	
622	D7	24.0	0.500	0.120	0.375	7.24	55.31	29.74	51.57	1.856	
623	D7	24.0	0.500	0.120	0.375	7.12	54.81	29.75	53.05	1.865	
624	D7	24.0	0.500	0.120	0.375	7.61	53.67	29.76	37.35	1.667	( 5 )
625	D7	24.0	0.500	0.120	0.375	8.59	56.10	29.58	28.04	1.490	( 1 )
626	D7	24.0	0.500	0.120	0.375	8.10	29.97	29.33	40.63	1.847	( 1 )
627	D7	24.0	0.500	0.120	0.375	11.41	32.50	29.32	30.35	1.678	( 1 )
628	D7	24.0	0.500	0.120	0.375	17.49	28.71	29.30	12.58	1.510	( 2 )
629	D7	24.0	0.500	0.120	0.375	2.45	30.60	14.64	85.07	1.850	
630	D7	24.0	0.500	0.120	0.375	2.58	29.79	14.94	77.60	1.636	
631	D7	24.0	0.500	0.120	0.375	2.58	29.72	14.62	71.59	1.516	
632	D7	24.0	0.500	0.120	0.375	5.64	31.23	14.53	63.50	1.355	
633	D7	24.0	0.500	0.120	0.375	5.64	30.24	14.76	54.52	1.210	
634	D7	24.0	0.500	0.120	0.375	7.88	35.29	14.32	17.26	1.084	( 2 )
635	D7	24.0	0.500	0.120	0.375	7.88	56.86	30.00	101.50	3.087	
636	D7	24.0	0.500	0.120	0.375	7.78	54.98	29.97	94.81	2.866	
637	D7	24.0	0.500	0.120	0.375	2.45	93.17	15.20	115.60	2.486	
638	D7	24.0	0.500	0.120	0.375	2.31	94.66	14.94	107.39	2.243	
639	D7	24.0	0.500	0.120	0.375	2.40	93.60	15.08	86.02	1.865	
640	D7	24.0	0.500	0.120	0.375	2.99	94.00	14.68	62.41	1.494	( 7 )
641	D7	24.0	0.500	0.120	0.375	3.04	94.81	14.10	54.31	1.355	( 7 )
642	D7	24.0	0.500	0.120	0.375	3.68	93.86	14.25	36.29	1.364	( 6 )
643	D7	24.0	0.500	0.120	0.375	2.31	55.04	14.67	89.60	1.766	( 3 )
644	D7	24.0	0.500	0.120	0.375	2.94	56.34	14.54	59.04	1.345	( 3 )
645	D7	24.0	0.500	0.120	0.375	2.94	55.78	14.93	56.12	1.204	( 3 )
646	D7	24.0	0.500	0.120	0.375	7.85	56.55	30.13	110.70	3.121	( 3 )
647	D6	24.0	0.500	0.120	0.375	8.74	59.07	30.26	95.47	3.114	( 4 )
648	D6	24.0	0.500	0.120	0.375	6.39	57.07	30.22	86.72	2.853	( 4 )
649	D6	24.0	0.500	0.120	0.375	8.15	55.86	30.19	71.19	2.435	( 4 )
650	D6	24.0	0.500	0.120	0.375	8.74	56.31	30.14	48.33	1.850	( 4 )
651	D6	24.0	0.500	0.120	0.375	9.86	57.58	30.15	39.89	1.688	( 4 )
652	D6	24.0	0.500	0.120	0.375	13.40	56.47	29.97	20.25	1.508	( 4 )
653	D6	24.0	0.500	0.120	0.375	9.42	104.58	28.90	47.90	1.840	( 4 )
654	D6	24.0	0.500	0.120	0.375	8.98	28.95	29.71	43.99	1.969	( 4 )
655	D6	24.0	0.500	0.120	0.375	9.77	29.41	30.10	37.69	1.852	( 4 )
656	D6	24.0	0.500	0.120	0.375	18.35	29.58	30.10	15.82	1.690	( 4 )
657	D6	24.0	0.500	0.120	0.375	15.90	55.47	45.13	67.25	3.107	( 4 )
658	D6	24.0	0.500	0.120	0.375	15.66	55.46	45.18	62.51	2.873	( 4 )
659	D6	24.0	0.500	0.120	0.375	18.85	54.02	44.61	35.69	2.486	( 4 )
660	D6	24.0	0.500	0.120	0.375	26.99	54.06	44.68	18.67	2.137	( 4 )
661	D6	24.0	0.500	0.120	0.375	8.69	54.42	30.27	90.90	3.197	( 4 )
662	D6	24.0	0.500	0.120	0.375	8.54	55.50	30.25	87.17	3.006	( 4 )
663	D6	24.0	0.500	0.120	0.375	8.29	29.39	29.89	70.40	2.484	( 4 )
664	D6	24.0	0.500	0.120	0.375	8.24	29.39	29.88	66.96	2.311	( 4 )
665	D6	24.0	0.500	0.120	0.375	9.03	29.35	29.88	46.84	2.079	( 4 )
666	D6	24.0	0.500	0.120	0.375	16.15	55.89	45.23	76.88	3.447	( 4 )
667	D6	24.0	0.500	0.120	0.375	15.90	55.38	45.21	69.08	3.206	( 4 )
668	D6	24.0	0.500	0.120	0.375	15.70	55.66	45.19	63.25	2.966	( 4 )

TABLE B-1 (CONTINUED)  
 CRITICAL HEAT FLUX DATA  
 STAINLESS STEEL - LIGHT WATER SAVANNAH RIVER LABORATORY

RUN NUMBER	ID	HEATER LENGTH IN.	HEATER DIA. IN.	HEATER THICK. IN.	COOLANT CHANNEL EQUIV. DIA. IN.	PRESSURE GRUP PSI	LOCAL PRESSURE PSIA	COOLANT VELOCITY FT/SEC	CONDITIONS AT BURNOUT SUBCOOLING DEG F	CRITICAL HEAT FLUX 10 <sup>6</sup> BTU/HR-SQFT	COMMENTS
669	D6	24.0	0.500	0.120	0.375	15.70	56.64	45.34	59.58	2.813	( 4 )
670	D6	24.0	0.500	0.120	0.375	15.80	58.63	45.19	66.04	2.932	( 4 )
671	D6	24.0	0.500	0.120	0.375	16.59	55.43	44.89	35.53	2.522	( 4 )
672	D6	24.0	0.500	0.120	0.375	15.58	56.34	44.93	55.53	2.759	( 4 )
673	D6	24.0	0.500	0.120	0.375	24.78	56.65	44.87	25.40	2.351	( 4 )
674	D6	24.0	0.500	0.120	0.375	2.94	55.17	14.63	85.95	1.939	( 4 )
675	D6	24.0	0.500	0.120	0.375	3.31	55.88	14.84	78.14	1.771	( 4 )
676	D6	24.0	0.500	0.120	0.375	3.46	55.93	14.59	64.35	1.589	( 4 )
677	D6	24.0	0.500	0.120	0.375	4.05	56.00	14.58	53.62	1.451	( 4 )
678	D6	24.0	0.500	0.120	0.375	4.81	55.84	14.91	39.01	1.291	( 4 )
679	D6	24.0	0.500	0.120	0.375	7.68	55.93	14.58	9.59	1.091	( 4 )
680	D6	24.0	0.500	0.120	0.375	8.91	55.33	30.57	96.17	3.164	( 4 )
681	D6	24.0	0.500	0.120	0.375	8.74	55.51	30.33	89.69	2.992	( 4 )
682	D6	24.0	0.500	0.120	0.375	2.92	97.85	15.52	119.84	2.581	( 4 )
683	D6	24.0	0.500	0.120	0.375	2.85	97.85	15.44	110.14	2.392	( 4 )
684	D6	24.0	0.500	0.120	0.375	3.24	98.21	15.02	71.05	1.890	( 4 )
685	D6	24.0	0.500	0.120	0.375	3.51	99.13	14.38	62.82	1.627	( 4 )
686	D6	24.0	0.500	0.120	0.375	3.71	107.03	13.89	45.40	1.420	( 4 )
687	D6	24.0	0.500	0.120	0.375	8.64	59.35	30.39	108.58	3.233	( 4 )
688	D6	24.0	0.500	0.120	0.375	8.12	56.60	30.06	95.44	3.002	( 4 )
689	D6	24.0	0.500	0.120	0.375	8.05	56.00	29.97	89.01	2.817	( 4 )
690	D6	24.0	0.500	0.120	0.375	8.00	56.49	29.88	80.95	2.628	( 4 )
691	D6	24.0	0.500	0.120	0.375	7.95	56.29	29.87	75.26	2.455	( 4 )
692	D6	24.0	0.500	0.120	0.375	8.00	56.09	29.85	65.23	2.245	( 4 )
693	D6	24.0	0.500	0.120	0.375	8.49	56.27	30.38	54.90	1.998	( 4 )
694	D6	24.0	0.500	0.120	0.375	8.44	55.81	30.12	52.92	1.922	( 4 )
695	D6	24.0	0.500	0.120	0.375	9.18	56.60	30.14	41.78	1.688	( 1 )
696	D6	24.0	0.500	0.120	0.375	17.72	54.94	28.80	8.44	1.478	( 2 )
697	D6	24.0	0.500	0.120	0.375	15.70	56.36	44.88	84.71	3.460	( 4 )
698	D6	24.0	0.500	0.120	0.375	15.66	56.86	45.12	75.55	3.139	( 4 )
699	D6	24.0	0.500	0.120	0.375	15.56	56.55	45.34	70.76	3.001	( 4 )
700	D6	24.0	0.500	0.120	0.375	15.41	56.94	44.99	63.23	2.709	( 4 )
701	D6	24.0	0.500	0.120	0.375	15.12	56.71	45.11	59.09	2.529	( 4 )
702	D6	24.0	0.500	0.120	0.375	20.42	55.87	45.27	37.53	2.228	( 2 )
703	D6	24.0	0.500	0.120	0.375	2.50	55.44	14.22	96.25	2.070	( 4 )
704	D6	24.0	0.500	0.120	0.375	2.60	56.05	14.04	86.54	1.789	( 4 )
705	D6	24.0	0.500	0.120	0.375	3.12	57.00	13.98	73.19	1.521	( 4 )
706	D6	24.0	0.500	0.120	0.375	3.04	56.09	14.48	65.38	1.422	( 4 )
707	D6	24.0	0.500	0.120	0.375	5.59	56.49	13.98	32.89	1.199	( 1 )
708	D6	24.0	0.500	0.120	0.375	7.66	55.56	30.09	112.18	3.101	( 3 )
709	D9	24.0	0.500	0.120	0.375	8.54	56.74	30.21	104.20	2.966	( 6 )
710	D9	24.0	0.500	0.120	0.375	8.34	56.92	30.21	97.47	2.772	( 4 )
711	D9	24.0	0.500	0.120	0.375	7.80	56.53	29.39	91.12	2.549	( 4 )
712	D9	24.0	0.500	0.120	0.375	7.56	56.16	29.38	82.53	2.425	( 4 )
713	D9	24.0	0.500	0.120	0.375	7.56	56.45	29.05	73.80	2.225	( 4 )
714	D9	24.0	0.500	0.120	0.375	8.20	57.61	29.73	64.96	2.016	( 4 )
715	D9	24.0	0.500	0.120	0.375	8.64	55.73	29.72	54.25	1.831	( 4 )
716	D5	24.0	0.500	0.120	0.375	8.17	56.06	29.98	100.75	3.103	( 4 )
717	D5	24.0	0.500	0.120	0.375	7.95	54.81	30.24	84.62	2.857	( 4 )
718	D5	24.0	0.500	0.120	0.375	7.56	55.60	29.40	83.16	2.642	( 4 )

TABLE B-1 (CONTINUED)  
 CRITICAL HEAT FLUX DATA  
 STAINLESS STEEL -LIGHT WATER SAVANNAH RIVER LABORATORY

RUN NUMBER	ID	HEATER LENGTH IN.	HEATER DIA. IN.	HEATER THICK. IN.	COOLANT CHANNEL EQUIV. DIA. IN.	PRESSURE DROP PSI	LOCAL COOLANT PRESSURE PSIA	COOLANT VELOCITY FT/SEC	CONDITIONS AT BURNOUT SUBCOOLING DEG F	CRITICAL HEAT FLUX 10 <sup>6</sup> BTU/HR-SQFT	COMMENTS
719	D5	24.0	0.500	0.120	0.375	7.53	59.53	28.83	74.52	2.446	
720	D5	24.0	0.500	0.120	0.375	8.04	59.51	30.05	102.29	3.076	
721	D5	24.0	0.500	0.120	0.375	7.92	58.43	30.22	91.84	2.853	
722	D5	24.0	0.500	0.120	0.375	7.81	58.08	30.21	82.30	2.619	
723	D5	24.0	0.500	0.120	0.375	7.74	58.91	30.17	78.50	2.419	
724	D5	24.0	0.500	0.120	0.375	7.96	58.89	30.31	100.10	3.105	
725	D5	24.0	0.500	0.120	0.375	7.97	58.51	30.18	97.81	2.873	
726	D5	24.0	0.500	0.120	0.375	7.90	59.38	30.19	89.10	2.650	
727	D5	24.0	0.500	0.120	0.375	7.84	57.22	30.17	79.31	2.439	
728	D4	24.0	0.500	0.120	0.375	7.87	58.38	30.08	92.34	3.109	
729	D4	24.0	0.500	0.120	0.375	7.82	58.46	30.32	85.10	2.873	
730	D4	24.0	0.500	0.120	0.375	7.63	57.74	30.23	78.37	2.659	
731	D4	24.0	0.500	0.120	0.375	7.58	57.75	30.21	68.87	2.453	
732	D4	24.0	0.500	0.120	0.375	7.84	59.21	30.23	97.65	3.098	
733	D4	24.0	0.500	0.120	0.375	7.80	58.38	30.24	95.49	3.087	
734	D11	24.0	0.500	0.120	0.375	7.69	58.08	29.85	94.19	3.098	
735	D11	24.0	0.500	0.120	0.375	7.58	58.98	30.07	88.97	2.869	
736	D11	24.0	0.500	0.120	0.375	7.51	58.29	30.22	80.21	2.641	
737	D11	24.0	0.500	0.120	0.375	7.46	58.41	30.19	72.92	2.443	
738	D11	24.0	0.500	0.120	0.375	7.78	58.99	30.40	98.89	3.105	
739	D11	24.0	0.500	0.120	0.375	9.54	58.89	30.36	82.64	2.642	
740	D10	24.0	0.500	0.120	0.375	7.95	57.45	30.33	95.38	3.116	
741	D10	24.0	0.500	0.120	0.375	8.06	59.17	30.45	103.55	3.121	
742	D10	24.0	0.500	0.120	0.375	7.94	58.93	30.52	95.22	2.887	
743	D10	24.0	0.500	0.120	0.375	7.88	58.70	30.52	86.62	2.680	
744	D10	24.0	0.500	0.120	0.375	7.82	58.93	30.50	75.74	2.457	
745	D10	24.0	0.500	0.120	0.375	8.06	58.94	30.54	102.29	3.130	
746	D10	24.0	0.500	0.120	0.375	7.89	59.49	30.50	85.99	2.666	
747	D5	24.0	0.500	0.120	0.375	8.10	56.07	30.22	100.87	3.105	
748	D5	24.0	0.500	0.120	0.375	7.90	56.01	30.20	93.47	2.862	
749	D5	24.0	0.500	0.120	0.375	7.75	56.46	30.18	85.84	2.650	
750	D5	24.0	0.500	0.120	0.375	7.66	56.45	30.16	76.81	2.428	
751	D5	24.0	0.500	0.120	0.375	2.77	55.61	15.74	100.89	2.030	
752	D5	24.0	0.500	0.120	0.375	2.75	55.61	15.48	89.28	1.865	
753	D5	24.0	0.500	0.120	0.375	2.65	56.04	14.98	78.89	1.672	
754	D5	24.0	0.500	0.120	0.375	2.63	55.92	14.97	71.73	1.517	
755	D5	24.0	0.500	0.120	0.375	8.02	56.29	29.43	99.47	3.110	
756	D5	24.0	0.500	0.120	0.375	16.17	56.61	46.24	78.88	3.332	
757	D5	24.0	0.500	0.120	0.375	16.37	57.65	46.18	90.04	3.607	
758	D5	24.0	0.500	0.120	0.375	15.88	56.36	46.22	74.47	3.110	
759	D5	24.0	0.500	0.120	0.375	15.63	56.95	46.26	69.32	2.880	
760	D5	24.0	0.500	0.120	0.375	15.36	57.30	46.29	63.77	2.668	
761	D5	24.0	0.500	0.120	0.375	15.14	56.91	46.29	55.44	2.441	
762	D5	24.0	0.500	0.120	0.375	8.05	56.45	30.03	110.14	3.128	( 6)
763	D5	24.0	0.500	0.120	0.375	8.05	56.37	30.04	106.97	3.103	( 6)
764	D5	24.0	0.500	0.120	0.375	7.68	55.99	30.02	88.65	2.641	( 6)
765	D5	24.0	0.500	0.120	0.375	7.51	55.46	30.12	56.36	1.849	( 6)
766	D4	24.0	0.500	0.120	0.375	8.39	55.48	30.06	97.49	3.092	
767	D4	24.0	0.500	0.120	0.375	8.17	55.04	30.05	92.47	2.880	
768	D4	24.0	0.500	0.120	0.375	8.05	55.29	30.04	83.95	2.650	

TABLE B-1 (CONTINUED)  
 CRITICAL HEAT FLUX DATA  
 STAINLESS STEEL -LIGHT WATER SAVANNAH RIVER LABORATORY

RUN NUMBER	ID	HEATER			COOLANT CHANNEL EQUIV. DIA. IN.	PRESSURE DROP PSI	LOCAL COOLANT CONDITIONS AT BURNOUT			CRITICAL HEAT FLUX 10 <sup>6</sup> BTU/HR-SQFT	COMMENTS
		LENGTH IN.	DIA. IN.	THICK. IN.			PRESSURE PSIA	VELOCITY FT/SEC	SUBCOOLING DEG F		
769	04	24.0	0.500	0.120	0.375	7.95	55.38	30.02	74.57	2.425	
770	04	24.0	0.500	0.120	0.375	8.39	55.41	30.07	100.33	3.110	
771	04	24.0	0.500	0.120	0.375	16.91	55.96	45.37	90.49	3.609	
772	04	24.0	0.500	0.120	0.375	16.73	56.38	45.34	83.14	3.359	
773	04	24.0	0.500	0.120	0.375	16.54	55.73	45.99	74.30	3.114	
774	04	24.0	0.500	0.120	0.375	16.29	55.69	46.12	67.88	2.880	
775	04	24.0	0.500	0.120	0.375	15.92	55.90	46.03	62.44	2.686	
776	04	24.0	0.500	0.120	0.375	15.68	55.65	45.92	54.43	2.437	
777	04	24.0	0.500	0.120	0.375	8.64	54.96	30.13	104.20	3.110	( 3 )
778	011	24.0	0.500	0.120	0.375	8.24	55.87	30.13	100.13	3.020	
779	011	24.0	0.500	0.120	0.375	8.05	55.97	30.11	91.24	2.869	
780	011	24.0	0.500	0.120	0.375	7.95	55.62	30.19	83.12	2.651	
781	011	24.0	0.500	0.120	0.375	7.85	56.07	30.26	74.45	2.435	
782	011	24.0	0.500	0.120	0.375	16.81	56.86	46.18	85.50	3.616	
783	011	24.0	0.500	0.120	0.375	16.49	56.71	46.23	80.06	3.355	
784	011	24.0	0.500	0.120	0.375	16.32	56.93	46.21	74.54	3.112	
785	011	24.0	0.500	0.120	0.375	16.12	56.45	46.10	67.84	2.871	
786	011	24.0	0.500	0.120	0.375	15.68	56.33	46.10	61.27	2.655	
787	011	24.0	0.500	0.120	0.375	15.92	56.33	46.61	52.74	2.327	
788	011	24.0	0.500	0.120	0.375	8.15	55.40	29.96	105.75	3.127	
789	011	24.0	0.500	0.120	0.375	8.02	55.85	29.96	95.87	2.887	
790	011	24.0	0.500	0.120	0.375	7.87	54.97	30.11	52.47	1.840	
791	011	24.0	0.500	0.120	0.375	8.80	56.86	30.07	46.22	1.676	
792	011	24.0	0.500	0.120	0.375	13.24	54.80	29.70	21.44	1.512	( 2 )
793	011	24.0	0.500	0.120	0.375	8.28	55.60	30.46	103.12	3.105	
794	011	24.0	0.500	0.120	0.375	6.23	99.94	14.24	50.29	1.523	( 7 )
795	011	24.0	0.500	0.120	0.375	8.14	56.02	30.14	128.27	3.094	( 4 )
796	012	24.0	0.500	0.120	0.375	8.72	56.05	30.63	99.85	3.116	
797	012	24.0	0.500	0.120	0.375	8.36	56.07	30.60	55.42	2.878	
798	012	24.0	0.500	0.120	0.375	8.25	56.14	30.60	66.27	2.851	
799	012	24.0	0.500	0.120	0.375	8.14	55.90	30.57	79.45	2.437	
800	012	24.0	0.500	0.120	0.375	8.59	56.10	30.61	103.99	3.118	
801	012	24.0	0.500	0.120	0.375	16.82	56.01	45.95	91.33	3.627	
802	012	24.0	0.500	0.120	0.375	15.53	56.32	45.92	84.53	3.366	
803	012	24.0	0.500	0.120	0.375	16.29	56.53	45.91	77.83	3.128	
804	012	24.0	0.500	0.120	0.375	16.17	56.29	45.87	70.99	2.903	
805	012	24.0	0.500	0.120	0.375	15.86	56.39	46.08	64.60	2.646	
806	012	24.0	0.500	0.120	0.375	15.93	55.95	46.06	57.15	2.432	
807	012	24.0	0.500	0.120	0.375	6.72	59.71	30.21	108.79	3.121	( 3 )
808	012	24.0	0.500	0.120	0.375	8.14	56.07	30.20	109.22	3.020	( 3 )
809	012	24.0	0.500	0.120	0.375	16.53	56.34	29.06	13.82	1.508	( 3 )
810	012	24.0	0.500	0.120	0.375	3.06	29.91	15.31	68.09	1.337	( 3 )
811	012	24.0	0.500	0.120	0.375	2.94	29.34	15.06	60.59	1.190	( 3 )
812	012	24.0	0.500	0.120	0.375	3.38	29.39	14.89	48.96	1.058	( 3 )
813	012	24.0	0.500	0.120	0.375	8.12	55.66	30.04	110.27	3.026	( 3 )
814	012	24.0	0.500	0.120	0.375	2.80	94.65	14.77	66.89	1.508	( 3 )
815	012	24.0	0.500	0.120	0.375	2.60	95.40	14.41	60.53	1.368	( 3 )
816	012	24.0	0.500	0.120	0.375	3.24	98.47	15.15	42.41	1.220	( 3 )
817	012	24.0	0.500	0.120	0.375	8.17	59.78	30.02	117.29	3.118	( 3 )
818	013	24.0	0.500	0.120	0.375	8.54	55.65	30.47	96.71	3.092	

TABLE B-1 (CONTINUED)  
 CRITICAL HEAT FLUX DATA  
 STAINLESS STEEL -LIGHT WATER SAVANNAH RIVER LABORATORY

RUN NUMBER	ID	HEATER LENGTH IN.	HEATER DIA. IN.	HEATER THICK. IN.	COOLANT CHANNEL EQUIV. DIA. IN.	PRESSURE DROP PSI	LOCAL COOLANT PRESSURE PSIA	CONDITIONS VELOCITY FT/SEC	AT BURNOUT SUBCOOLING DEG F	CRITICAL HEAT FLUX 10 <sup>6</sup> BTU/HR-SQFT	COMMENTS
819	D13	24.0	0.500	0.120	0.375	8.30	55.44	30.53	90.05	2.871	
820	D13	24.0	0.500	0.120	0.375	8.18	54.75	30.51	83.14	2.655	
821	D13	24.0	0.500	0.120	0.375	8.00	55.28	30.49	74.70	2.435	
822	D13	24.0	0.500	0.120	0.375	16.79	56.21	46.17	85.55	3.609	
823	D13	24.0	0.500	0.120	0.375	16.57	56.20	46.08	80.71	3.366	
824	D13	24.0	0.500	0.120	0.375	16.89	56.56	46.13	74.18	3.098	
825	D13	24.0	0.500	0.120	0.375	16.15	56.73	46.11	68.78	2.887	
826	D13	24.0	0.500	0.120	0.375	15.91	56.71	45.76	62.24	2.642	
827	D13	24.0	0.500	0.120	0.375	8.45	55.87	30.21	103.73	3.110	
828	D13	24.0	0.500	0.120	0.375	8.50	55.77	30.21	104.65	3.110	
829	D13	24.0	0.500	0.120	0.375	8.25	55.29	30.46	102.02	3.092	
830	D13	24.0	0.500	0.120	0.375	2.70	54.84	15.42	96.75	2.036	
831	D13	24.0	0.500	0.120	0.375	2.63	55.18	15.33	87.79	1.843	
832	D13	24.0	0.500	0.120	0.375	2.70	55.33	15.06	79.07	1.670	
833	D13	24.0	0.500	0.120	0.375	2.78	54.66	14.97	66.29	1.505	
834	D13	24.0	0.500	0.120	0.375	2.92	55.43	14.95	58.37	1.345	
835	D13	24.0	0.500	0.120	0.375	3.51	55.48	15.16	47.47	1.204	
836	D13	24.0	0.500	0.120	0.375	8.08	54.90	29.97	108.58	3.094	( 3 )
837	D14	24.0	0.500	0.120	0.375	6.09	56.05	30.33	98.62	3.038	
838	D14	24.0	0.500	0.120	0.375	7.81	56.13	30.38	98.10	2.813	
839	D14	24.0	0.500	0.120	0.375	7.69	56.05	30.54	87.88	2.592	
840	D14	24.0	0.500	0.120	0.375	7.51	56.16	30.61	79.20	2.392	
841	D14	24.0	0.500	0.120	0.375	7.61	95.45	30.28	107.42	3.060	
842	D14	24.0	0.500	0.120	0.375	7.36	95.19	30.25	86.44	2.637	
843	D14	24.0	0.500	0.120	0.375	2.55	55.70	15.36	96.53	1.998	
844	D14	24.0	0.500	0.120	0.375	2.43	54.78	14.59	91.17	1.825	
845	D14	24.0	0.500	0.120	0.375	2.61	55.89	14.94	75.67	1.652	
846	D14	24.0	0.500	0.120	0.375	15.92	56.95	46.75	77.11	3.069	
847	D14	24.0	0.500	0.120	0.375	15.27	56.04	46.09	69.98	2.815	
848	D14	24.0	0.500	0.120	0.375	24.29	57.29	15.12	119.45	2.407	
849	D14	24.0	0.500	0.120	0.375	2.35	55.53	14.95	111.44	2.203	
850	D14	24.0	0.500	0.120	0.375	2.38	55.64	14.95	97.31	2.014	
851	D14	24.0	0.500	0.120	0.375	2.53	55.97	14.92	88.54	1.829	
852	D14	24.0	0.500	0.120	0.375	7.76	55.71	30.09	108.27	3.060	
853	D15	24.0	0.500	0.120	0.375	8.04	55.94	30.13	102.35	3.323	
854	D15	24.0	0.500	0.120	0.375	7.82	56.27	30.11	95.81	3.091	
855	D15	24.0	0.500	0.120	0.375	7.63	56.03	30.10	86.08	2.842	
856	D15	24.0	0.500	0.120	0.375	7.58	55.91	30.08	77.53	2.612	
857	D15	24.0	0.500	0.120	0.375	7.46	55.91	30.07	71.28	2.421	
858	D15	24.0	0.500	0.120	0.375	7.70	56.03	30.04	63.13	2.210	
859	D15	24.0	0.500	0.120	0.375	2.85	55.75	15.04	99.43	2.210	
860	D15	24.0	0.500	0.120	0.375	2.77	55.64	14.94	94.59	2.038	
861	D15	24.0	0.500	0.120	0.375	2.80	55.80	15.00	82.03	1.836	
862	D15	24.0	0.500	0.120	0.375	3.11	56.41	14.87	80.48	1.661	
863	D15	24.0	0.500	0.120	0.375	8.04	55.94	30.12	107.78	3.339	
864	D15	24.0	0.500	0.120	0.375	7.85	54.98	30.11	99.14	3.083	
865	D15	24.0	0.500	0.120	0.375	14.51	56.36	45.67	80.98	3.346	
866	D15	24.0	0.500	0.120	0.375	15.13	56.59	45.73	74.34	3.091	
867	D15	24.0	0.500	0.120	0.375	14.92	56.40	45.60	67.09	2.851	
868	D15	24.0	0.500	0.120	0.375	14.92	56.05	45.52	59.40	2.628	



TABLE E-1 (CONTINUED)  
 CRITICAL HEAT FLUX DATA  
 STAINLESS STEEL - LIGHT WATER SAVANNAH RIVER LABORATORY

RUN NUMBER	ID	HEATER			COOLANT CHANNEL EQUIV. DIA. IN.	PRESSURE * DRUP PSI	LOCAL COOLANT CONDITIONS AT BURNDOUT			CRITICAL HEAT FLUX 10 <sup>6</sup> BTU/HR-SQFT	COMMENTS
		LENGTH IN.	DIA. IN.	THICK. IN.			PRESSURE PSIA	VELOCITY FT/SEC	SUBCOOLING DEG F		
869	D15	24.0	0.500	0.120	0.375	7.75	95.14	30.22	111.02	3.341	
870	D15	24.0	0.500	0.120	0.375	7.63	95.25	30.09	119.21	3.600	( 3 )
871	D15	24.0	0.500	0.120	0.375	7.44	95.00	30.12	113.38	3.355	( 3 )
872	D15	24.0	0.500	0.120	0.375	2.58	55.63	14.96	117.20	2.416	( 3 )
873	D15	24.0	0.500	0.120	0.375	2.48	55.28	14.87	109.82	2.203	( 3 )
874	D15	24.0	0.500	0.120	0.375	7.66	95.03	30.08	109.57	3.083	( 3 )
875	D15	24.0	0.500	0.120	0.375	14.46	63.41	45.07	46.89	2.210	( 3 )
876	D15	24.0	0.500	0.120	0.375	9.46	37.44	45.46	20.61	2.210	( 3 )
877	D15	24.0	0.500	0.120	0.375	25.19	56.68	30.21	36.38	1.507	( 3 )
878	D16	24.0	0.500	0.120	0.375	8.44	55.87	30.56	114.01	3.292	
879	D16	24.0	0.500	0.120	0.375	8.12	55.62	30.57	100.57	3.073	
880	D16	24.0	0.500	0.120	0.375	8.00	55.84	30.87	90.40	2.842	
881	D16	24.0	0.500	0.120	0.375	7.78	55.67	30.15	81.09	2.614	
882	D16	24.0	0.500	0.120	0.375	7.75	55.90	30.46	73.42	2.414	
883	D16	24.0	0.500	0.120	0.375	7.75	55.60	30.43	64.87	2.203	
884	D16	24.0	0.500	0.120	0.375	2.63	55.32	14.88	93.08	2.025	
885	D16	24.0	0.500	0.120	0.375	2.58	55.52	14.87	83.30	1.840	
886	D16	24.0	0.500	0.120	0.375	2.60	55.53	15.26	76.43	1.667	
887	D16	24.0	0.500	0.120	0.375	3.41	56.31	15.38	63.02	1.492	
888	D16	24.0	0.500	0.120	0.375	3.29	55.69	30.09	113.44	3.312	
889	D16	24.0	0.500	0.120	0.375	15.88	56.37	45.83	90.79	3.555	
890	D16	24.0	0.500	0.120	0.375	15.61	56.12	45.74	82.35	3.308	
891	D16	24.0	0.500	0.120	0.375	15.36	56.11	45.96	74.90	3.080	
892	D16	24.0	0.500	0.120	0.375	15.12	56.32	45.84	69.43	2.842	
893	D16	24.0	0.500	0.120	0.375	15.12	56.30	45.73	61.61	2.615	
894	D16	24.0	0.500	0.120	0.375	7.90	95.62	30.20	128.79	3.587	
895	D16	24.0	0.500	0.120	0.375	7.75	95.38	30.34	118.44	3.344	
896	D16	24.0	0.500	0.120	0.375	22.55	57.02	29.85	110.38	3.080	
897	D16	24.0	0.500	0.120	0.375	15.66	56.70	45.96	93.87	3.586	
898	D16	24.0	0.500	0.120	0.375	21.86	58.35	45.49	29.00	2.209	( 1 )
899	D16	24.0	0.500	0.120	0.375	7.51	55.58	29.99	56.43	1.832	
900	D16	24.0	0.500	0.120	0.375	8.12	55.51	29.81	47.57	1.652	
901	D16	24.0	0.500	0.120	0.375	13.03	54.79	29.58	22.09	1.487	( 6 )
902	D16	24.0	0.500	0.120	0.375	4.32	55.85	14.74	36.65	1.195	( 1 )
903	D16	24.0	0.500	0.120	0.375	14.65	56.27	45.55	64.48	2.428	( 3 )
904	D16	24.0	0.500	0.120	0.375	14.67	56.08	45.82	55.75	2.196	( 3 )
905	D16	24.0	0.500	0.120	0.375	24.52	56.67	45.56	25.60	2.014	( 3 )
906	D16	24.0	0.500	0.120	0.375	7.73	55.15	30.05	52.70	1.663	( 3 )
907	D16	24.0	0.500	0.120	0.375	8.64	55.97	29.95	45.20	1.562	( 3 )
908	D16	24.0	0.500	0.120	0.375	8.74	56.66	29.96	45.90	1.465	( 5 )
909	D16	24.0	0.500	0.120	0.375	12.76	52.70	29.32	19.73	1.337	( 3 )
910	D16	24.0	0.500	0.120	0.375	3.02	55.89	14.86	62.06	1.327	( 3 )
911	D16	24.0	0.500	0.120	0.375	3.33	55.74	14.55	46.75	1.192	( 5 )
912	D17	24.0	0.500	0.120	0.375	8.50	54.98	30.50	104.94	3.317	
913	D17	24.0	0.500	0.120	0.375	7.64	54.97	30.57	98.32	3.051	
914	D17	24.0	0.500	0.120	0.375	7.40	55.36	30.55	92.47	2.970	
915	D17	24.0	0.500	0.120	0.375	7.27	54.51	30.60	87.35	3.028	
916	D17	24.0	0.500	0.120	0.375	7.84	54.45	30.55	116.01	3.319	
917	D17	24.0	0.500	0.120	0.375	8.62	55.00	30.40	41.94	1.643	( 1 )
918	D17	24.0	0.500	0.120	0.375	13.56	54.80	30.36	20.09	1.485	( 2 )

TABLE B-1 (CONTINUED)  
 CRITICAL HEAT FLUX DATA  
 STAINLESS STEEL -LIGHT WATER SAVANNAH RIVER LABORATORY

RUN NUMBER	ID	HEATER LENGTH IN.	HEATER DIA. IN.	HEATER THICK. IN.	COOLANT CHANNEL EQUIV. DIA. IN.	PRESSURE DROP PSI	LOCAL COOLANT PRESSURE PSIA	CONDITIONS AT BURNOUT VELOCITY FT/SEC	SUBCOOLING DEG F	CRITICAL HEAT FLUX 10 <sup>6</sup> BTU/HR-SQFT	COMMENTS
919	D17	24.0	0.500	0.120	0.375	15.62	55.93	46.13	92.72	3.562	
920	D17	24.0	0.500	0.120	0.375	13.90	55.83	45.30	54.49	2.394	
921	D17	24.0	0.500	0.120	0.375	19.86	55.25	45.08	31.99	2.201	( 2 )
922	D18	24.0	0.500	0.120	0.375	8.39	57.47	30.28	92.25	3.132	
923	D18	24.0	0.500	0.120	0.375	11.04	53.44	29.56	18.99	1.370	( 2 )
924	D18	24.0	0.500	0.120	0.375	8.34	55.29	30.19	91.04	3.116	
925	D18	24.0	0.500	0.120	0.375	8.14	55.48	30.10	95.18	3.116	
926	D18	24.0	0.500	0.120	0.375	9.65	55.18	29.74	37.58	1.611	( 1 )
927	D18	24.0	0.500	0.120	0.375	15.12	51.03	29.67	14.54	1.526	( 2 )
928	D18	24.0	0.500	0.120	0.375	8.30	55.74	30.27	96.75	3.145	
929	D18	24.0	0.500	0.120	0.375	8.14	56.87	30.33	86.98	2.864	
930	D18	24.0	0.500	0.120	0.375	9.63	50.06	30.23	37.73	1.687	( 1 )
931	D18	24.0	0.500	0.120	0.375	14.14	54.27	29.97	14.89	1.534	( 2 )
932	D18	24.0	0.500	0.120	0.375	8.39	55.89	30.34	98.77	3.110	
933	D18	24.0	0.500	0.120	0.375	24.67	46.29	44.97	13.39	2.056	( 2 )
934	D18	24.0	0.500	0.120	0.375	24.67	54.25	46.07	21.01	2.263	( 1 )
935	D18	24.0	0.500	0.120	0.375	9.12	54.70	29.60	37.78	1.703	( 1 )
936	D18	24.0	0.500	0.120	0.375	16.79	50.03	29.17	8.71	1.539	( 2 )
947	D18	24.0	0.500	0.120	0.375	3.98	55.55	14.48	53.24	1.382	( 3 )
948	D19	24.0	0.500	0.120	0.375	8.25	56.91	30.34	106.45	3.395	
949	D19	24.0	0.500	0.120	0.375	8.11	55.54	30.35	96.79	3.159	
940	D19	24.0	0.500	0.120	0.375	9.62	54.91	30.00	36.70	1.699	( 1 )
941	D19	24.0	0.500	0.120	0.375	8.20	56.08	30.35	98.28	3.152	
942	D19	24.0	0.500	0.120	0.375	3.43	55.75	15.12	62.64	1.692	
943	D19	24.0	0.500	0.120	0.375	8.24	57.92	30.38	110.92	3.148	( 3 )
944	D19	24.0	0.500	0.120	0.375	7.66	98.29	29.30	55.48	2.074	( 3 )
945	D19	24.0	0.500	0.120	0.375	7.26	30.83	29.65	60.16	2.072	( 3 )
946	D19	24.0	0.500	0.120	0.375	8.64	30.65	30.13	37.33	1.872	( 3 )
947	D19	24.0	0.500	0.120	0.375	9.47	30.85	30.35	29.23	1.674	( 3 )
948	D20	24.0	0.500	0.120	0.375	7.90	56.86	30.46	116.55	3.352	
949	D20	24.0	0.500	0.120	0.375	7.70	57.29	30.46	109.85	3.100	
950	D20	24.0	0.500	0.120	0.375	7.16	29.85	30.11	71.87	2.198	
951	D20	24.0	0.500	0.120	0.375	7.02	30.14	29.80	64.57	2.009	
952	D20	24.0	0.500	0.120	0.375	7.02	30.14	29.95	54.47	1.823	
953	D20	24.0	0.500	0.120	0.375	10.60	31.06	29.64	26.80	1.654	( 1 )
954	D20	24.0	0.500	0.120	0.375	7.56	44.27	30.40	95.06	3.089	
955	D20	24.0	0.500	0.120	0.375	2.45	29.85	15.29	88.24	1.834	
956	D20	24.0	0.500	0.120	0.375	2.31	29.84	15.29	76.79	1.660	
957	D20	24.0	0.500	0.120	0.375	2.45	29.35	15.28	68.42	1.485	
958	D20	24.0	0.500	0.120	0.375	2.60	30.05	15.10	59.81	1.339	
959	D20	24.0	0.500	0.120	0.375	3.43	56.36	14.86	64.04	1.350	
960	D20	24.0	0.500	0.120	0.375	7.46	57.17	14.23	119.00	3.082	
961	D20	24.0	0.500	0.120	0.375	6.82	57.53	30.10	82.26	2.218	
962	D20	24.0	0.500	0.120	0.375	17.37	57.84	30.06	63.43	1.831	
963	D20	24.0	0.500	0.120	0.375	10.94	56.64	29.90	56.68	1.660	
964	D20	24.0	0.500	0.120	0.375	7.26	58.02	29.75	24.05	1.501	( 2 )
965	D20	24.0	0.500	0.120	0.375	6.97	33.00	29.54	22.48	1.501	( 2 )
966	D20	24.0	0.500	0.120	0.375	6.87	31.13	29.99	60.35	1.579	( 6 )
967	D21	24.0	0.500	0.120	0.375	6.39	57.15	30.48	116.28	3.316	( 4 )
968	D21	24.0	0.500	0.120	0.375	7.65	57.58	30.13	112.00	3.058	( 4 )

TABLE B-1 (CONTINUED)  
 CRITICAL HEAT FLUX DATA  
 STAINLESS STEEL -LIGHT WATER SAVANNAH RIVER LABORATORY

RUN NUMBER	ID	HEATER LENGTH IN.	HEATER DIA. IN.	THICK. IN.	COOLANT CHANNEL EQUIV. DIA. IN.	PRESSURE DROP PSI	LOCAL PRESSURE PSIA	COOLANT VELOCITY FT/SEC	CONDITIONS AT BURNOUT SUBCOOLING DEG F	CRITICAL HEAT FLUX 10 <sup>6</sup> BTU/HR-SQFT	COMMENTS
969	021	24.0	0.500	0.120	0.375	7.75	57.37	30.14	106.63	2.837	( 4 )
970	021	24.0	0.500	0.120	0.375	8.10	57.40	30.14	124.00	3.310	( 4 )
971	021	24.0	0.500	0.120	0.375	7.80	57.30	30.23	58.00	1.818	( 4 )
972	021	24.0	0.500	0.120	0.375	7.95	56.71	30.23	49.34	1.652	( 4 )
973	021	24.0	0.500	0.120	0.375	12.07	55.00	29.96	23.99	1.483	( 4 )
974	021	24.0	0.500	0.120	0.375	2.65	57.58	15.16	125.96	2.196	( 4 )
975	021	24.0	0.500	0.120	0.375	2.55	56.77	15.08	115.36	2.005	( 4 )
976	021	24.0	0.500	0.120	0.375	2.65	56.98	15.16	105.05	1.822	( 4 )
977	021	24.0	0.500	0.120	0.375	2.65	56.98	15.15	93.58	1.638	( 4 )
978	021	24.0	0.500	0.120	0.375	3.43	56.46	14.87	81.29	1.480	( 4 )
979	021	24.0	0.500	0.120	0.375	3.73	58.35	15.25	69.61	1.334	( 4 )
980	021	24.0	0.500	0.120	0.375	7.85	57.43	30.11	121.16	3.060	( 4 )
981	021	24.0	0.500	0.120	0.375	14.87	57.99	45.71	63.79	2.390	( 4 )
982	021	24.0	0.500	0.120	0.375	14.87	57.99	45.83	56.50	2.194	( 4 )
983	021	24.0	0.500	0.120	0.375	14.87	57.25	45.81	49.52	2.007	( 4 )
984	021	24.0	0.500	0.120	0.375	14.87	57.06	45.53	30.83	1.449	( 4 )
985	021	24.0	0.500	0.120	0.375	19.88	81.35	45.46	51.57	1.822	( 4 )
986	021	24.0	0.500	0.120	0.375	3.29	57.52	15.03	85.73	1.485	( 4 )
987	021	24.0	0.500	0.120	0.375	3.34	58.14	14.94	73.80	1.328	( 4 )
988	021	24.0	0.500	0.120	0.375	3.53	56.28	14.85	60.12	1.181	( 4 )
989	021	24.0	0.500	0.120	0.375	3.19	30.25	14.85	81.45	1.480	( 4 )
990	021	24.0	0.500	0.120	0.375	3.43	27.40	14.84	66.22	1.318	( 4 )
991	021	24.0	0.500	0.120	0.375	3.29	31.12	14.89	65.56	1.179	( 4 )
992	021	24.0	0.500	0.120	0.375	7.90	57.54	30.18	129.69	3.060	( 4 )
993	021	24.0	0.500	0.120	0.375	7.36	57.68	30.13	66.58	1.814	( 4 )
994	021	24.0	0.500	0.120	0.375	7.41	57.46	30.11	59.78	1.647	( 4 )
995	021	24.0	0.500	0.120	0.375	15.31	49.28	29.95	16.34	1.483	( 4 )
996	021	24.0	0.500	0.120	0.375	2.60	30.00	15.14	94.57	1.472	( 4 )
997	021	24.0	0.500	0.120	0.375	2.90	30.42	15.13	83.27	1.318	( 4 )
998	021	24.0	0.500	0.120	0.375	3.04	36.26	14.97	71.99	1.174	( 4 )
999	021	24.0	0.500	0.120	0.375	7.85	57.56	29.97	142.18	3.044	( 4 )
1	022	24.0	0.500	0.120	0.375	7.85	57.74	30.58	49.29	3.060	
2	022	24.0	0.500	0.120	0.375	7.71	57.43	30.49	90.49	2.840	
3	022	24.0	0.500	0.120	0.375	16.93	56.06	45.60	37.31	2.412	( 1 )
4	022	24.0	0.500	0.120	0.375	14.48	57.91	45.59	53.27	2.614	
5	022	24.0	0.500	0.120	0.375	7.70	57.26	30.18	102.49	3.071	
6	022	24.0	0.500	0.120	0.375	8.83	55.75	30.16	46.22	1.822	
7	022	24.0	0.500	0.120	0.375	9.72	56.21	29.99	37.49	1.652	( 1 )
8	022	24.0	0.500	0.120	0.375	12.37	52.71	30.02	18.49	1.494	( 2 )
9	022	24.0	0.500	0.120	0.375	7.60	57.26	30.34	103.01	3.067	
10	022	24.0	0.500	0.120	0.375	2.35	57.04	15.26	105.34	2.207	
11	022	24.0	0.500	0.120	0.375	2.80	57.50	14.92	76.97	2.020	
12	022	24.0	0.500	0.120	0.375	3.93	59.23	14.64	62.05	1.485	
13	023	24.0	0.500	0.120	0.375	6.10	57.92	30.04	96.30	3.087	
14	023	24.0	0.500	0.120	0.375	17.30	58.33	30.11	90.50	2.860	
15	023	24.0	0.500	0.120	0.375	7.51	57.41	29.93	47.39	1.832	
16	023	24.0	0.500	0.120	0.375	8.44	56.87	29.92	36.94	1.665	( 1 )
17	023	24.0	0.500	0.120	0.375	35.58	59.10	45.60	42.25	2.421	( 1 )
18	023	24.0	0.500	0.120	0.375	7.90	57.23	30.04	98.21	3.083	
19	023	24.0	0.500	0.120	0.375	2.85	57.83	14.97	99.72	2.216	

TABLE B-1 (CONTINUED)  
 CRITICAL HEAT FLUX DATA  
 STAINLESS STEEL -LIGHT WATER SAVANNAH RIVER LABORATORY

RUN NUMBER	ID	HEATER			COOLANT CHANNEL EQUIV. DIA. IN.	PRESSURE DROP PSI	LOCAL COOLANT CONDITIONS AT BURNOUT			CRITICAL HEAT FLUX 10 <sup>6</sup> BTU/HR-SQFT	COMMENTS
		LENGTH IN.	DIA. IN.	THICK. IN.			PRESSURE PSIA	VELOCITY FT/SEC	SUBCOOLING DEG F		
20	D23	24.0	0.500	0.120	0.375	2.70	58.58	14.73	73.30	1.656	
21	D23	24.0	0.500	0.120	0.375	15.85	58.07	45.58	80.57	3.353	
22	D23	24.0	0.500	0.120	0.375	15.41	57.94	45.54	65.70	2.862	
23	D23	24.0	0.500	0.120	0.375	15.16	58.02	45.60	58.54	2.632	
24	D23	24.0	0.500	0.120	0.375	15.95	57.18	45.13	46.40	2.414	( 5)
25	D23	24.0	0.500	0.120	0.375	16.98	58.34	45.10	34.56	2.209	( 1)
26	D23	24.0	0.500	0.120	0.375	7.71	54.93	30.15	48.04	1.832	
27	D23	24.0	0.500	0.120	0.375	8.44	57.57	30.23	40.41	1.665	( 1)
28	D23	24.0	0.500	0.120	0.375	10.56	55.66	30.08	22.03	1.494	( 5)
29	D23	24.0	0.500	0.120	0.375	2.61	57.58	15.02	72.95	1.660	
30	D23	24.0	0.500	0.120	0.375	2.61	57.62	14.72	66.55	1.494	
31	D23	24.0	0.500	0.120	0.375	8.25	57.33	30.26	104.54	3.096	( 3)

TABLE B-2  
CRITICAL HEAT FLUX DATA  
STAINLESS STEEL - LIGHT WATER COLUMBIA UNIVERSITY

RUN NUMBER	ID	HEATER			COOLANT CHANNEL EQUIV. DIA. IN.	PRESSURE DROP PSI	LOCAL COOLANT CONDITIONS AT BURNOUT			CRITICAL HEAT FLUX 10 <sup>6</sup> BTU/HR-SQFT	COMMENTS
		LENGTH IN.	DIA. IN.	THICK. IN.			PRESSURE PSIA	VELOCITY FT/SEC	SUBCOOLING DEG F		
213	S	24.0	0.750	0.020	0.308	12.00	64.70	30.16	98.28	2.295	( 4 )
139	R	24.0	2.125	0.0	0.332	11.00	64.70	30.01	136.80	3.020	( 4 )
140	R	24.0	2.125	0.0	0.332	11.50	64.70	30.06	135.00	3.182	( 4 )
141	R	24.0	2.125	0.0	0.332	11.50	64.70	29.90	82.80	2.464	( 4 )
142	S	24.0	2.125	0.0	0.332	11.30	64.70	30.01	138.60	3.251	( 4 )
143	S	24.0	2.125	0.0	0.332	10.50	64.70	30.01	91.80	2.412	( 4 )
144	S	24.0	2.125	0.0	0.332	11.50	64.70	30.01	135.00	3.128	( 4 )
145	S	24.0	2.125	0.0	0.332	12.00	64.70	30.01	79.20	2.077	( 4 )
146	S	24.0	2.125	0.0	0.332	11.50	64.70	30.01	79.20	2.083	( 4 )
147	S	24.0	2.125	0.0	0.332	10.50	64.70	29.85	140.40	2.803	( 4 )
148	S	24.0	2.125	0.0	0.332	10.80	64.70	29.90	144.00	2.779	( 4 )
149	T	24.0	2.125	0.0	0.332	12.50	64.70	30.01	135.00	3.616	( 4 )
150	T	24.0	2.125	0.0	0.332	11.50	64.70	30.01	82.80	2.416	( 4 )
151	T	24.0	2.125	0.0	0.332	12.50	64.70	30.01	138.60	3.605	( 4 )
152	T	24.0	2.125	0.0	0.332	12.00	64.70	30.01	82.80	2.417	( 4 )
153	T	24.0	2.125	0.0	0.332	23.50	64.70	44.99	79.20	3.112	( 4 )
154	T	24.0	2.125	0.0	0.332	24.00	64.70	44.99	81.00	3.155	( 4 )
155	T	24.0	2.125	0.0	0.332	12.30	64.70	30.01	135.00	3.773	( 4 )
156	T	24.0	2.125	0.0	0.332	13.50	64.70	30.01	54.00	1.787	( 4 )
157	T	24.0	2.125	0.0	0.332	25.30	64.70	44.40	59.40	2.605	( 4 )
158	T	24.0	2.125	0.0	0.332	13.50	64.70	14.82	82.80	1.728	( 4 )
159	T	24.0	2.125	0.0	0.332	16.00	64.70	15.09	48.60	1.336	( 4 )
160	T	24.0	2.125	0.0	0.332	15.00	64.70	15.03	81.00	1.759	( 4 )
161	T	24.0	2.125	0.0	0.332	16.00	64.70	15.00	54.00	1.480	( 4 )
162	T	24.0	2.125	0.0	0.332	14.50	64.70	30.01	54.00	1.883	( 4 )
163	T	24.0	2.125	0.0	0.332	25.50	64.70	44.95	55.80	2.421	( 4 )
164	T	24.0	2.125	0.0	0.332	26.00	64.70	44.99	52.20	2.380	( 4 )
165	T	24.0	2.125	0.0	0.332	12.00	64.70	30.01	138.60	3.724	( 4 )
166	T	24.0	2.125	0.0	0.332	23.00	64.70	44.45	108.00	3.814	( 4 )
167	T	24.0	2.125	0.0	0.332	24.00	64.70	44.99	111.60	3.931	( 4 )
168	T	24.0	2.125	0.0	0.332	24.00	64.70	14.95	135.00	2.362	( 4 )
169	T	24.0	2.125	0.0	0.332	24.70	64.70	14.82	124.20	2.216	( 3 )
170	T	24.0	2.125	0.0	0.332	25.50	64.70	15.00	135.00	2.372	( 3 )
171	T	24.0	2.125	0.0	0.332	11.50	64.70	29.90	135.00	3.389	( 3 )
173	V	24.0	2.125	0.0	0.332	7.50	64.70	14.58	41.40	1.390	( 1 )
174	V	24.0	2.125	0.0	0.332	7.00	64.70	14.56	61.20	1.852	( 4 )
175	V	24.0	2.125	0.0	0.332	4.00	64.70	14.56	82.80	2.029	( 4 )
176	W	24.0	2.125	0.0	0.332	11.50	64.70	29.14	136.80	3.073	( 4 )
177	W	24.0	2.125	0.0	0.332	11.50	64.70	29.27	136.80	3.143	( 4 )
178	W	24.0	2.125	0.0	0.332	11.50	64.70	29.38	90.00	2.718	( 4 )
179	W	24.0	2.125	0.0	0.332	12.00	64.70	29.17	142.20	3.400	( 4 )
180	W	24.0	2.125	0.0	0.332	11.00	64.70	29.27	84.60	1.892	( 4 )
181	W	24.0	2.125	0.0	0.332	10.50	64.70	29.22	90.00	1.852	( 4 )
224	W	24.0	0.750	0.0	0.308	18.50	64.70	30.08	108.18	3.062	( 4 )
225	X	24.0	0.750	0.0	0.308	37.50	64.70	45.46	111.96	3.652	( 4 )
226	X	24.0	0.750	0.0	0.308	38.50	64.70	45.46	108.18	3.665	( 4 )
227	X	24.0	0.750	0.0	0.308	6.50	64.70	15.52	106.56	2.311	( 4 )
228	X	24.0	0.750	0.0	0.308	6.00	64.70	14.86	106.20	2.333	( 4 )
229	X	24.0	0.750	0.0	0.308	18.50	64.70	30.16	104.94	3.069	( 4 )
230	X	24.0	0.750	0.0	0.308	0.0	64.70	30.16	90.00	2.362	( 4 )

TABLE B-2 (CONTINUED)  
 CRITICAL HEAT FLUX DATA  
 STAINLESS STEEL -LIGHT WATER COLUMBIA UNIVERSITY

RUN NUMBER	ID	HEATER			COOLANT CHANNEL		PRESSURE DROP PSI	LOCAL COOLANT CONDITIONS AT BURNOUT			CRITICAL HEAT FLUX 10 <sup>6</sup> BTU/HR-SQFT	COMMENTS
		LENGTH IN.	DIA. IN.	THICK. IN.	EQUIV. DIA. IN.	PRESSURE PSIA		VELOCITY FT/SEC	SUBCOOLING DEG F			
231	Y	24.0	0.750	0.0	0.308	14.00	64.70	30.08	84.96	2.248		
232	Y	24.0	0.750	0.0	0.308	15.50	64.70	15.08	79.92	2.007		
233	Z	24.0	0.750	0.0	0.308	15.00	64.70	30.23	96.48	2.009	( 6 )	
234	Z	24.0	0.750	0.0	0.308	16.00	64.70	30.23	86.40	2.304		
235	Z	24.0	0.750	0.0	0.308	31.00	64.70	44.42	110.88	2.509	( 6 )	
236	Z	24.0	0.750	0.0	0.308	31.00	64.70	44.42	81.72	3.413		
237	Z	24.0	0.750	0.0	0.308	31.50	64.70	45.46	80.64	3.382		
238	Z	24.0	0.750	0.0	0.308	14.50	64.70	30.08	80.64	2.650		
239	Z	24.0	0.750	0.0	0.308	14.80	64.70	15.52	80.64	1.888		
240	Z	24.0	0.750	0.0	0.308	15.30	64.70	15.37	53.64	1.490		
241	Z	24.0	0.750	0.0	0.308	17.00	64.70	30.30	46.98	1.818		

TABLE B-3  
 CRITICAL HEAT FLUX DATA  
 STAINLESS STEEL -LIGHT WATER SAVANNAH RIVER LABORATORY

RUN NUMBER	HEATER LENGTH IN.	HEATER DIA. IN.	HEATER THICK. IN.	COOLANT CHANNEL EQUIV. DIA. IN.	PRESSURE DROP PSI	LOCAL COOLANT PRESSURE PSIA	COOLANT VELOCITY FT/SEC	CONDITIONS AT BURNOUT SUBCOOLING DEG F	CRITICAL HEAT FLUX 10 <sup>6</sup> BTU/HR-SQFT	COMMENTS
10	0.0	2.050	0.0	0.440	4.31	55.62	27.46	73.51	2.142	
11	0.0	2.050	0.0	0.440	3.96	55.25	27.22	75.38	2.146	
12	0.0	2.050	0.0	0.440	3.94	54.37	27.23	90.38	2.464	
13	0.0	2.050	0.0	0.440	4.08	54.37	27.12	77.00	2.146	
14	0.0	2.050	0.0	0.440	4.87	57.00	26.44	62.32	1.849	
15	0.0	2.050	0.0	0.440	8.51	56.63	27.06	40.14	1.462	( 1 )
16	0.0	2.050	0.0	0.440	8.31	52.75	32.73	106.92	2.993	
17	0.0	2.050	0.0	0.440	6.57	57.00	33.97	65.09	1.976	
18	0.0	2.050	0.0	0.440	5.68	52.87	34.02	77.49	2.290	
19	0.0	2.050	0.0	0.440	5.56	53.00	34.04	92.41	2.797	
20	0.0	2.050	0.0	0.440	7.45	52.75	34.05	110.00	2.965	
33	0.0	2.050	0.0	0.440	6.64	54.50	33.84	62.84	2.155	
35	0.0	2.050	0.0	0.440	7.55	56.50	32.11	75.91	2.605	
36	0.0	2.050	0.0	0.440	7.33	53.50	31.62	93.55	3.098	
37	0.0	2.050	0.0	0.440	7.16	54.00	31.47	97.60	3.188	
38	0.0	2.050	0.0	0.440	8.09	54.75	33.50	62.48	2.383	
39	0.0	2.050	0.0	0.440	9.08	54.13	33.41	50.29	2.169	
40	0.0	2.050	0.0	0.440	19.43	46.75	30.88	13.93	1.966	( 1 )
41	0.0	2.050	0.0	0.440	7.58	52.25	32.47	102.49	3.377	
42	0.0	2.050	0.0	0.440	24.60	56.00	42.65	16.22	2.383	( 1 )
44	0.0	2.050	0.0	0.440	14.96	54.75	46.71	56.66	2.621	
45	0.0	2.050	0.0	0.440	16.29	55.50	46.67	61.40	3.119	
46	0.0	2.050	0.0	0.440	16.38	53.25	46.73	77.92	3.667	
47	0.0	2.050	0.0	0.440	16.29	53.50	46.53	80.77	3.798	
48	0.0	2.050	0.0	0.440	17.78	56.00	46.43	44.82	2.633	( 1 )
49	0.0	2.050	0.0	0.440	17.79	57.12	46.67	51.70	2.378	
50	0.0	2.050	0.0	0.440	18.57	57.88	39.56	31.99	2.185	( 1 )
51	0.0	2.050	0.0	0.440	8.66	57.62	32.10	68.65	2.630	
52	0.0	2.050	0.0	0.440	8.66	54.50	32.11	86.24	3.116	
53	0.0	2.050	0.0	0.440	2.41	53.25	16.65	124.29	2.660	
54	0.0	2.050	0.0	0.440	3.08	51.25	17.99	75.60	1.946	
55	0.0	2.050	0.0	0.440	3.81	54.13	17.01	51.62	3.355	
56	0.0	2.050	0.0	0.440	5.34	50.12	16.12	27.56	1.402	( 1 )
57	0.0	2.050	0.0	0.440	5.78	54.13	16.87	24.61	1.314	( 1 )
58	0.0	2.050	0.0	0.440	3.30	53.25	17.71	66.83	1.957	
59	0.0	2.050	0.0	0.440	2.83	54.25	17.73	89.15	2.153	
60	0.0	2.050	0.0	0.440	8.86	55.62	33.49	55.55	2.362	
61	0.0	2.050	0.0	0.440	6.84	55.00	33.88	81.90	2.848	
62	0.0	2.050	0.0	0.440	6.42	55.12	34.09	104.27	3.379	
63	0.0	2.050	0.0	0.440	7.16	55.25	31.73	74.61	2.603	
64	0.0	2.050	0.0	0.440	6.69	56.63	31.90	75.80	2.601	
65	0.0	2.050	0.0	0.440	7.11	68.50	31.32	71.23	2.592	
66	0.0	2.050	0.0	0.440	7.26	52.87	32.17	72.58	2.581	
67	0.0	2.050	0.0	0.440	7.31	52.25	31.80	70.96	2.597	
68	0.0	2.050	0.0	0.440	7.16	53.75	31.26	74.32	2.662	
69	0.0	2.050	0.0	0.440	2.56	48.12	15.55	70.67	1.760	
70	0.0	2.050	0.0	0.440	3.27	55.50	16.41	63.04	1.746	
71	0.0	2.050	0.0	0.440	3.05	53.50	16.26	66.47	1.807	
72	0.0	2.050	0.0	0.440	3.22	54.75	16.11	65.47	1.784	
73	0.0	2.050	0.0	0.440	2.41	53.50	15.15	75.37	1.804	

TABLE B-3 (CONTINUED)  
 CRITICAL HEAT FLUX DATA  
 STAINLESS STEEL -LIGHT WATER SAVANNAH RIVER LABORATORY

RUN NUMBER	ID	HEATER LENGTH IN.	HEATER DIA. IN.	HEATER THICK. IN.	COOLANT CHANNEL EQUIV. DIA. IN.	PRESSURE DROP PSI	LOCAL PRESSURE PSIA	COOLANT VELOCITY FT/SEC	CONDITIONS AT BURNOUT SUBCOOLING DEG F	CRITICAL HEAT FLUX 10 <sup>6</sup> BTU/HR-SQFT	COMMENTS
74		0.0	2.050	0.0	0.440	2.66	56.12	16.18	72.29	1.818	
75		0.0	2.050	0.0	0.440	2.66	55.87	16.30	78.05	1.946	
76		0.0	2.050	0.0	0.440	2.46	54.37	16.49	93.58	2.191	
77		0.0	2.050	0.0	0.440	2.29	54.13	16.57	106.18	2.414	
78		0.0	2.050	0.0	0.440	2.29	53.50	16.42	119.70	2.644	
79		0.0	2.050	0.0	0.440	2.31	53.50	16.41	115.67	2.599	
80		0.0	2.050	0.0	0.440	2.66	56.63	15.91	70.69	1.766	
112		0.0	2.050	0.0	0.440	6.99	50.50	36.63	112.61	3.359	
113		0.0	2.050	0.0	0.440	7.31	54.13	29.74	95.31	2.713	
114		0.0	2.050	0.0	0.440	7.36	52.25	29.67	96.52	2.804	
115		0.0	2.050	0.0	0.440	7.77	54.37	29.30	69.52	2.266	
116		0.0	2.050	0.0	0.440	8.29	56.50	29.63	67.45	2.086	
117		0.0	2.050	0.0	0.440	7.58	49.87	27.09	104.92	2.970	
118		0.0	2.050	0.0	0.440	5.90	57.88	13.92	18.04	1.224	( 1 )
119		0.0	2.050	0.0	0.440	3.57	50.50	14.83	70.94	1.629	
128		0.0	2.050	0.0	0.440	7.33	54.13	28.93	49.14	1.897	
140		0.0	2.050	0.0	0.440	2.83	52.95	16.30	77.35	1.798	
141		0.0	2.050	0.0	0.440	2.53	53.86	16.25	96.39	2.200	
142		0.0	2.050	0.0	0.440	2.31	53.10	16.46	129.31	2.673	
143		0.0	2.050	0.0	0.440	2.53	53.87	16.33	104.18	2.214	
144		0.0	2.050	0.0	0.440	8.86	53.50	32.26	46.24	1.996	
145		0.0	2.050	0.0	0.440	6.72	52.87	31.50	81.20	2.687	
147		0.0	2.050	0.0	0.440	6.47	53.37	30.97	81.81	2.646	
148		0.0	2.050	0.0	0.440	14.15	52.87	46.53	55.01	2.635	
149		0.0	2.050	0.0	0.440	14.10	53.41	46.00	60.10	2.669	
150		0.0	2.050	0.0	0.440	14.22	53.75	46.21	74.99	3.181	
151		0.0	2.050	0.0	0.440	14.19	53.95	46.37	79.94	3.280	
152		0.0	2.050	0.0	0.440	13.92	54.16	46.39	92.45	3.679	
153		0.0	2.050	0.0	0.440	14.27	54.46	46.58	73.94	3.159	
154		0.0	2.050	0.0	0.440	9.89	55.63	30.32	55.19	2.005	
155		0.0	2.050	0.0	0.440	7.70	53.36	30.69	77.99	2.659	
156		0.0	2.050	0.0	0.440	7.60	53.36	31.16	108.94	3.438	
157		0.0	2.050	0.0	0.440	7.65	53.58	30.98	79.13	2.682	
158		0.0	2.050	0.0	0.440	3.27	53.16	15.41	66.96	1.807	
159		0.0	2.050	0.0	0.440	2.88	54.31	15.73	90.54	2.185	
160		0.0	2.050	0.0	0.440	2.61	51.11	15.79	119.45	2.633	
161		0.0	2.050	0.0	0.440	2.76	53.00	15.72	95.94	2.214	
162		0.0	2.050	0.0	0.440	2.71	52.95	15.95	108.41	2.473	
163		0.0	2.050	0.0	0.440	4.23	54.49	15.40	56.57	1.584	
167		0.0	2.050	0.0	0.440	14.51	52.72	45.34	79.29	3.247	
168		0.0	2.050	0.0	0.440	14.44	54.55	45.35	83.29	3.337	
169		0.0	2.050	0.0	0.440	18.23	54.13	43.83	40.05	2.083	( 1 )
170		0.0	2.050	0.0	0.440	19.02	53.37	41.58	44.68	2.232	( 1 )
171		0.0	2.050	0.0	0.440	21.00	58.71	43.73	47.23	2.389	
172		0.0	2.050	0.0	0.440	18.30	53.14	44.84	50.04	2.592	
173		0.0	2.050	0.0	0.440	15.99	53.50	29.06	16.38	1.634	( 1 )
174		0.0	2.050	0.0	0.440	11.51	56.98	29.93	52.49	2.014	
175		0.0	2.050	0.0	0.440	6.74	57.25	15.50	18.16	1.294	( 1 )
176		0.0	2.050	0.0	0.440	4.92	52.62	15.58	42.55	1.442	( 1 )
177		0.0	2.050	0.0	0.440	4.38	53.30	15.54	52.60	1.559	



TABLE B-3 (CONTINUED)  
CRITICAL HEAT FLUX DATA  
STAINLESS STEEL -LIGHT WATER SAVANNAH RIVER LABORATORY

RUN NUMBER ID	HEATER			COOLANT CHANNEL EQUIV. DIA. IN.	PRESSURE DROP PSI	LOCAL COOLANT PRESSURE PSIA	CONDITIONS AT BURNOUT		CRITICAL HEAT FLUX 10 <sup>6</sup> BTU/HR-SQFT	COMMENTS
	LENGTH IN.	DIA. IN.	THICK. IN.				VELOCITY FT/SEC	SUBCOOLING DEG F		
178	0.0	2.050	0.0	0.440	4.67	54.27	15.56	60.68	1.616	

TABLE B-4  
CRITICAL HEAT FLUX DATA  
STAINLESS STEEL -HEAVY WATER SAVANNAH RIVER LABORATORY

RUN NUMBER ID	HEATER			COOLANT CHANNEL EQUIV. DIA. IN.	PRESSURE DROP PSI	LOCAL COOLANT CONDITIONS AT BURNOUT			CRITICAL HEAT FLUX 10 <sup>6</sup> BTU/HR-SQFT	COMMENTS
	LENGTH IN.	DIA. IN.	THICK. IN.			PRESSURE PSIA	VELOCITY FT/SEC	SUBCOOLING DEG F		
1	24.0	0.500	0.120	0.375	9.63	55.62	31.60	130.50	5.166	
2	24.0	0.500	0.120	0.375	9.66	55.57	31.74	138.28	5.202	
3	24.0	0.500	0.120	0.375	9.12	56.64	31.33	125.26	4.770	
4	24.0	0.500	0.120	0.375	9.68	54.53	31.08	160.96	6.102	
5	24.0	0.500	0.120	0.375	9.12	55.60	31.95	113.63	4.392	
6	24.0	0.500	0.120	0.375	9.61	54.16	30.80	177.32	6.102	
7	24.0	0.500	0.120	0.375	9.22	54.34	30.98	158.40	5.616	
8	24.0	0.500	0.120	0.375	9.27	54.93	31.18	140.54	5.220	
9	24.0	0.500	0.120	0.375	18.26	55.60	46.91	116.48	5.868	
10	24.0	0.500	0.120	0.375	9.44	54.24	30.80	156.40	5.634	
11	24.0	0.500	0.120	0.375	9.63	54.59	30.27	177.46	6.480	
12	24.0	0.500	0.120	0.375	9.76	54.39	30.58	156.24	6.030	
13	24.0	0.500	0.120	0.375	9.46	54.00	30.71	144.70	5.634	
14	24.0	0.500	0.120	0.375	9.39	54.34	30.87	134.75	5.166	
15	24.0	0.500	0.120	0.375	9.12	57.63	30.61	127.73	4.824	
16	24.0	0.500	0.120	0.375	19.12	56.72	47.55	126.13	6.300	
17	24.0	0.500	0.120	0.375	17.28	57.27	45.58	113.60	5.652	
18	24.0	0.500	0.120	0.375	3.01	54.07	15.52	194.40	4.410	( 3 )
19	24.0	0.500	0.120	0.375	3.03	54.44	15.18	179.08	4.068	( 3 )
20	24.0	0.500	0.120	0.375	3.25	55.06	15.66	159.41	3.834	( 3 )
21	24.0	0.500	0.120	0.375	3.01	55.49	15.64	148.91	3.420	( 3 )
22	24.0	0.500	0.120	0.375	9.12	55.01	30.17	161.15	5.724	( 3 )
23	24.0	0.500	0.120	0.375	10.00	55.61	31.31	156.94	6.048	
24	24.0	0.500	0.120	0.375	3.06	55.54	15.42	168.52	4.374	
25	24.0	0.500	0.120	0.375	3.08	54.56	15.41	193.52	4.752	
26	24.0	0.500	0.120	0.375	3.10	55.95	15.16	162.61	4.050	
27	24.0	0.500	0.120	0.375	10.00	55.47	30.88	146.86	5.580	
28	24.0	0.500	0.120	0.375	16.43	55.07	46.36	128.05	6.264	
29	24.0	0.500	0.120	0.375	17.25	58.55	45.06	113.00	5.598	
30	24.0	0.500	0.120	0.375	3.16	54.67	15.50	196.58	4.788	
31	24.0	0.500	0.120	0.375	9.56	55.27	30.81	141.07	5.580	
32	24.0	0.500	0.120	0.375	2.86	55.46	15.02	192.10	4.788	
33	24.0	0.500	0.120	0.375	2.96	55.48	15.49	177.84	4.410	
34	24.0	0.500	0.120	0.375	2.79	54.88	15.39	165.37	4.086	
35	24.0	0.500	0.120	0.375	9.22	55.10	30.62	152.15	5.634	
36	24.0	0.500	0.120	0.375	9.41	54.92	30.81	147.26	5.634	
37	24.0	0.500	0.120	0.375	17.89	55.41	45.30	124.51	6.390	
38	24.0	0.500	0.120	0.375	17.45	59.54	45.41	107.82	5.598	
39	24.0	0.500	0.120	0.375	9.22	54.91	30.65	142.79	5.634	
40	24.0	0.500	0.120	0.375	18.48	56.72	46.26	136.89	7.038	
41	24.0	0.500	0.120	0.375	17.35	56.86	45.34	107.41	5.742	
43	24.0	0.500	0.120	0.375	3.37	54.79	15.58	191.12	4.860	
44	24.0	0.500	0.120	0.375	10.79	54.66	30.37	105.53	2.826	( 2 )
45	24.0	0.500	0.120	0.375	8.50	54.49	30.42	54.85	2.844	( 2 )
46	24.0	0.500	0.120	0.375	20.65	55.43	45.00	57.83	3.762	( 2 )

TABLE B-5  
 CRITICAL HEAT FLUX DATA  
 STAINLESS STEEL -HEAVY WATER COLUMBIA UNIVERSITY

RUN NUMBER ID	HEATER			COOLANT CHANNEL EQUIV. DIA. IN.	PRESSURE DROP PSI	LOCAL COOLANT CONDITIONS AT BURNOUT			CRITICAL HEAT FLUX 10 <sup>6</sup> BTU/HR-SQFT	COMMENTS
	LENGTH IN.	DIA. IN.	THICK. IN.			PRESSURE PSIA	VELOCITY FT/SEC	SUBCOOLING DEG F		
14	24.0	0.750	0.018	0.308	17.20	64.70	30.15	104.22	3.438	
121	24.0	0.750	0.018	0.308	20.50	65.20	29.91	104.22	3.658	( 2 )
123	24.0	0.750	0.018	0.308	20.10	64.20	29.93	90.00	2.979	( 2 )
125	24.0	0.750	0.018	0.308	6.60	64.70	14.90	108.00	2.594	( 2 )
126	24.0	0.750	0.018	0.308	6.60	66.20	15.00	88.56	2.236	( 2 )
127	24.0	0.750	0.018	0.308	6.40	65.70	15.01	70.56	1.863	( 2 )
141	24.0	0.750	0.018	0.308	30.30	65.40	45.00	55.62	2.785	
161	24.0	0.750	0.018	0.308	31.50	64.70	44.97	77.58	3.276	
171	24.0	0.750	0.018	0.308	28.80	64.70	44.78	99.36	3.852	
191	24.0	0.750	0.018	0.308	16.90	64.70	29.93	90.90	3.031	
211	24.0	0.750	0.018	0.308	39.50	65.20	44.76	141.30	6.457	
281	24.0	0.750	0.018	0.308	17.40	65.00	29.97	124.20	4.054	
124	24.0	0.750	0.018	0.308	20.10	64.70	30.11	72.36	2.614	( 2 )

TABLE B-6  
CRITICAL HEAT FLUX DATA  
ALUMINUM -LIGHT WATER COLUMBIA UNIVERSITY

RUN NUMBER	ID	HEATER LENGTH IN.	HEATER DIA. IN.	HEATER THICK. IN.	COOLANT CHANNEL EQUIV. DIA. IN.	PRESSURE DROP PSI	LOCAL PRESSURE PSIA	COOLANT VELOCITY FT/SEC	CONDITIONS AT BURNOUT SUBCOOLING DEG F	CRITICAL HEAT FLUX 10 <sup>6</sup> BTU/HR-SQFT	COMMENTS
184		24.0	0.750	0.035	0.308	6.00	64.70	15.23	70.20	1.998	
185		24.0	0.750	0.035	0.308	7.00	64.70	15.00	30.60	1.350	( 1 )
186		24.0	0.750	0.035	0.308	21.00	64.70	30.53	25.20	1.634	( 1 )
187		24.0	1.000	0.020	0.323	13.00	64.70	30.38	52.20	1.588	( 4 )
188		24.0	1.000	0.020	0.323	17.00	64.70	30.60	52.20	2.250	
189		24.0	1.000	0.020	0.323	15.00	64.70	30.60	88.20	2.905	( 4 )
190		24.0	1.000	0.020	0.323	5.00	64.70	14.81	83.70	2.077	( 6 )
191		24.0	1.000	0.020	0.323	4.00	64.70	14.91	106.20	2.846	
192		24.0	1.000	0.020	0.323	16.00	64.70	29.33	68.40	2.648	
193		24.0	1.000	0.020	0.323	29.50	64.70	45.35	63.00	2.889	( 4 )
195		24.0	1.000	0.020	0.323	16.00	64.70	30.16	68.20	3.341	
196		24.0	0.750	0.020	0.308	18.00	64.70	30.82	111.60	3.625	( 6 )
197		24.0	0.750	0.020	0.308	17.00	64.70	30.01	108.00	3.929	
198		24.0	0.750	0.020	0.308	7.00	64.70	15.00	118.80	3.157	
199		24.0	0.750	0.020	0.308	8.00	64.70	15.00	108.00	2.830	
200		24.0	0.750	0.028	0.308	34.00	64.70	45.31	41.40	3.071	( 1 )
201		24.0	0.750	0.028	0.308	40.00	64.70	45.31	77.40	3.411	( 6 )
202		24.0	0.750	0.020	0.308	19.00	64.70	30.16	109.80	3.888	
203		24.0	0.750	0.020	0.308	15.50	64.70	14.86	108.18	2.563	( 4 )
204		24.0	0.750	0.028	0.308	16.20	64.70	30.23	90.54	3.672	
205		24.0	0.750	0.020	0.308	16.50	64.70	14.86	87.30	2.151	
206		24.0	0.750	0.020	0.308	37.00	64.70	44.64	36.36	2.223	( 1 )
207		24.0	0.750	0.020	0.308	36.00	64.70	44.79	62.64	2.857	( 6 )
208		24.0	0.750	0.020	0.308	35.40	64.70	44.94	77.22	3.472	( 6 )
209		24.0	0.750	0.020	0.308	36.00	64.70	44.94	91.26	4.046	( 6 )
210		24.0	0.750	0.020	0.308	37.00	64.70	44.87	60.48	3.362	
211		24.0	0.750	0.020	0.308	38.00	64.70	44.94	45.36	2.873	
212		24.0	0.750	0.020	0.308	36.00	64.70	44.94	114.30	4.448	( 3 )
214		24.0	1.000	0.020	0.323	13.70	64.70	29.77	87.30	2.801	( 4 )
215		24.0	1.000	0.020	0.323	13.30	64.70	29.99	83.88	2.848	( 4 )
216		24.0	0.750	0.035	0.308	16.00	64.70	30.08	109.80	3.798	( 6 )
217		24.0	0.750	0.035	0.308	16.00	64.70	30.08	90.54	3.281	
218		24.0	0.750	0.035	0.308	15.50	64.70	30.23	80.64	3.033	
219		24.0	0.750	0.035	0.308	15.80	64.70	15.30	82.98	2.299	
220		24.0	0.750	0.035	0.308	15.20	64.70	15.00	98.64	2.594	
221		24.0	0.750	0.035	0.308	33.20	64.70	45.24	77.58	3.645	( 6 )
222		24.0	0.750	0.035	0.308	38.50	60.50	45.24	34.56	2.687	( 1 )
223		24.0	0.750	0.035	0.308	14.50	64.70	30.30	104.94	4.108	
242		24.0	0.750	0.035	0.308	4.50	64.70	15.30	109.98	2.299	( 6 )
243		24.0	0.750	0.035	0.308	5.00	64.70	15.08	71.64	2.241	
244		24.0	0.750	0.035	0.308	4.50	64.70	15.30	110.18	2.907	
245		24.0	0.750	0.035	0.308	4.50	64.70	15.30	110.88	3.146	
246		24.0	0.750	0.035	0.308	6.00	64.70	15.08	45.36	1.586	
247		24.0	0.750	0.035	0.308	6.00	64.70	15.00	45.36	1.656	
248		24.0	0.750	0.035	0.308	5.00	64.70	15.08	90.54	2.691	
249		24.0	0.750	0.035	0.308	6.00	64.70	15.00	62.64	2.119	
250		24.0	0.750	0.035	0.308	5.50	64.70	15.08	113.40	3.366	
252		24.0	0.750	0.028	0.308	49.00	64.70	60.31	89.64	4.304	( 6 )
253		24.0	0.750	0.028	0.308	48.50	64.70	59.35	71.64	3.836	( 6 )
254		24.0	0.750	0.020	0.308	50.00	64.70	44.55	73.44	3.733	

TABLE B-6 (CONTINUED)  
 CRITICAL HEAT FLUX DATA  
 ALUMINUM -LIGHT WATER COLUMBIA UNIVERSITY

RUN NUMBER	ID	HEATER LENGTH IN.	HEATER DIA. IN.	HEATER THICK. IN.	COOLANT CHANNEL EQUIV. DIA. IN.	PRESSURE DROP PSI	LOCAL COOLANT PRESSURE PSIA	COOLANT VELOCITY FT/SEC	CONDITIONS AT BURNOUT SUBCOOLING DEG F	CRITICAL HEAT FLUX 10 <sup>6</sup> BTU/HR-SOFT	COMMENTS
255		24.0	0.750	0.035	0.308	29.00	64.70	44.87	89.64	4.325	
256		24.0	0.750	0.035	0.308	29.50	64.70	44.72	70.74	3.814	
257		24.0	0.750	0.035	0.308	30.30	64.70	44.64	59.76	3.406	
258		24.0	0.750	0.028	0.308	14.00	64.70	29.86	73.08	3.157	
259		24.0	0.750	0.028	0.308	31.00	64.70	44.79	89.64	4.556	
260		24.0	0.750	0.028	0.308	33.00	64.70	44.42	56.52	3.366	
261		24.0	0.750	0.035	0.308	4.50	64.70	15.96	53.64	1.496	
262		24.0	0.750	0.028	0.308	5.00	64.70	14.95	78.84	2.074	
263		24.0	0.750	0.028	0.308	5.00	64.70	15.10	53.64	1.514	
264		24.0	0.750	0.028	0.308	4.80	64.70	15.03	106.20	2.570	( 6 )
265		24.0	0.750	0.028	0.308	14.00	64.70	30.05	53.64	2.119	
266		24.0	0.750	0.020	0.308	15.00	64.70	15.10	110.88	2.461	( 4 )
267		24.0	0.750	0.035	0.308	14.50	64.70	15.03	78.84	2.054	
268		24.0	0.750	0.035	0.308	14.50	64.70	14.95	107.64	2.637	
269		24.0	0.750	0.020	0.308	14.50	64.70	15.10	80.64	2.047	
270		24.0	0.750	0.020	0.308	14.50	64.70	15.03	53.64	1.505	
271		24.0	0.750	0.020	0.308	13.00	64.70	29.97	80.64	2.916	( 6 )
272		24.0	0.750	0.020	0.308	12.50	64.70	29.89	54.18	2.142	
273		24.0	0.750	0.020	0.308	30.00	64.70	30.28	109.08	3.739	( 6 )
274		24.0	0.750	0.020	0.308	27.50	64.70	44.99	80.64	3.929	
275		24.0	0.750	0.020	0.308	28.00	64.70	44.84	54.54	2.736	
276		24.0	0.750	0.020	0.308	4.50	64.70	15.18	108.18	2.628	
277		24.0	0.750	0.020	0.308	38.00	64.70	54.07	108.90	4.927	( 6 )
278		24.0	0.750	0.020	0.308	38.00	64.70	45.31	108.18	4.948	
279		24.0	0.750	0.020	0.308	5.00	64.70	14.95	53.64	1.553	
280		24.0	0.750	0.020	0.308	4.80	64.70	15.26	81.36	2.245	
281		24.0	0.750	0.020	0.308	4.50	64.70	15.34	107.64	2.729	
282		24.0	0.750	0.020	0.308	14.00	64.70	30.05	53.64	2.232	
283		24.0	0.750	0.020	0.308	13.50	64.70	29.89	80.64	3.085	
284		24.0	0.750	0.020	0.308	13.50	64.70	30.05	108.00	3.895	
285		24.0	0.750	0.020	0.308	27.80	64.70	44.68	54.18	2.938	
286		24.0	0.750	0.020	0.308	27.50	64.70	44.92	82.80	4.070	
287		24.0	0.750	0.020	0.308	28.00	64.70	45.07	115.20	5.107	
288		24.0	0.750	0.023	0.308	15.30	64.70	30.12	54.54	2.326	
289		24.0	0.750	0.028	0.308	15.00	64.70	29.97	83.34	3.123	
290		24.0	0.750	0.028	0.308	15.00	64.70	29.89	108.18	3.931	
291		24.0	0.750	0.028	0.308	31.50	64.70	44.99	54.00	2.893	
292		24.0	0.750	0.028	0.308	32.00	64.70	44.99	83.70	4.135	
293		24.0	0.750	0.020	0.308	12.50	64.70	30.28	80.64	3.134	

TABLE B-7  
 CRITICAL HEAT FLUX DATA  
 COLUMBIA UNIVERSITY

ALUMINUM OXIDE -

RUN NUMBER	ID	HEATER			COOLANT CHANNEL		PRESSURE DROP PSI	LOCAL COOLANT CONDITIONS AT BURNOUT			CRITICAL HEAT FLUX 10 <sup>6</sup> BTU/HR-SQFT	COMMENTS
		LENGTH IN.	DIA. IN.	THICK. IN.	EQUIV. DIA. IN.	PRESSURE PSIA		VELOCITY FT/SEC	SUBCOOLING DEG F			
1		24.0	0.750	0.035	0.308	0.0	64.70	30.00	127.80	0.810	H <sub>2</sub> O; 2.4 - 3.6 mil Al <sub>2</sub> O <sub>3</sub>	
2		24.0	0.750	0.035	0.308	0.0	64.70	30.00	201.24	1.980		
3		24.0	0.750	0.035	0.308	0.0	64.70	30.00	198.36	2.518		
4		24.0	0.750	0.035	0.308	0.0	64.70	30.00	248.22	2.790		
251		24.0	0.750	0.020	0.308	22.50	64.30	30.16	187.02	5.452	D <sub>2</sub> O; 1.4 mil Al <sub>2</sub> O <sub>3</sub>	
261		24.0	0.750	0.020	0.308	18.00	63.70	30.08	178.20	5.890		
291		24.0	0.750	0.020	0.308	16.70	64.70	29.94	138.06	5.209		
311		24.0	0.750	0.020	0.308	19.30	65.20	30.05	90.36	4.484		
327		24.0	0.750	0.020	0.308	20.10	65.20	29.97	245.34	5.265		
372		24.0	0.750	0.020	0.308	5.80	66.70	15.09	137.34	3.492		

TABLE B-8  
 CRITICAL HEAT FLUX DATA  
 ALUMINUM -HEAVY WATER COLUMBIA UNIVERSITY

RUN NUMBER	ID	HEATER			COOLANT CHANNEL EQUIV. DIA. IN.	PRESSURE DROP PSI	LOCAL PRESSURE PSIA	COOLANT CONDITIONS AT BURNOUT			CRITICAL HEAT FLUX 10 <sup>6</sup> BTU/HR-SQFT	COMMENTS
		LENGTH IN.	DIA. IN.	THICK. IN.				VELOCITY FT/SEC	SUBCOOLING DEG F			
803		24.0	0.750	0.035	0.308	15.40	65.70	30.18	79.02	3.299	( 2)	
804		24.0	0.750	0.035	0.308	16.80	65.70	29.97	48.96	2.572	( 2)	
806		24.0	0.750	0.035	0.308	15.50	64.70	30.17	52.26	3.317		
151		24.0	0.750	0.020	0.308	18.60	64.70	30.10	75.24	3.391		
201		24.0	0.750	0.028	0.308	18.60	64.70	29.98	104.94	4.392	( 2)	
202		24.0	0.750	0.028	0.308	18.20	64.70	30.16	88.02	3.910	( 2)	
203		24.0	0.750	0.028	0.308	17.50	64.70	30.19	61.02	2.956	( 2)	
204		24.0	0.750	0.028	0.308	17.80	64.70	30.09	74.88	3.451	( 2)	
205		24.0	0.750	0.028	0.308	6.10	64.70	14.98	103.36	3.226		
221		24.0	0.750	0.028	0.308	20.90	64.70	30.15	94.68	4.403		
271		24.0	0.750	0.020	0.308	16.60	64.70	30.31	108.90	2.945	( 4)	
301		24.0	0.750	0.020	0.308	2.10	64.70	5.07	60.94	1.832		





## REFERENCES

1. J. L. Crandall, J. A. Smith, and O. A. Towler. *A Description of the Savannah River High Flux Charge*. USAEC Report DP-999, Savannah River Laboratory, E. I. du Pont de Nemours & Co., Aiken, S. C. (1965).
2. S. Mirshak, W. S. Durant, and R. H. Towell. *Heat Flux at Burnout*. USAEC Report DP-355, Savannah River Laboratory, E. I. du Pont de Nemours & Co., Aiken, S. C. (1959).
3. R. L. Menegus. *Burnout of Heating Surfaces in Water*. USAEC Report DP-363, Savannah River Laboratory, E. I. du Pont de Nemours & Co., Aiken, S. C. (1959).
4. S. Mirshak and R. H. Towell. *Heat Transfer Burnout of a Surface Contacted by a Spacer Rib*. USAEC Report DP-562, Savannah River Laboratory, E. I. du Pont de Nemours & Co., Aiken, S. C. (1961).
5. W. R. Gambill. "Burnout in Boiling Heat Transfer — Part II: Subcooled Forced Convection Systems." *Nuclear Safety* 9, 467 (1968).
6. B. H. Butler. *Parallel Operation of Welding Generators*. USAEC Report DP-482, Savannah River Laboratory, E. I. du Pont de Nemours & Co., Aiken, S. C. (1960).
7. E. J. Thorgerson. *Hydrodynamic Aspects of the Critical Heat Flux in Subcooled Convection Boiling*. Ph.D. Thesis, University of South Carolina, Columbia, South Carolina (1969).
8. P. I. Povarnin and S. T. Semenov. "Investigation of the Abrupt Change in Boiling of Water Heated Under The Saturation Temperature at High Flow Rates Through Pipes." *Teploenergetika* 4, 72 (1959).
9. J. Griffel. *Forced Convection Boiling Burnout for Water in Uniformly Heated Tubular Test Sections*. USAEC Report NYO-187-7, New York Operations Office, New York (1965).
10. F. Tachibana, M. Akiyama, and H. Kawamura. "Non-Hydrodynamic Aspects of Pool Boiling Burnout." *Journal of Nuclear Science and Technology* 4, 121 (1967).

11. E. K. Averin. *Izv. Acad. Nauk. SSSR, Otdel, Tekh. Nauk.* 3, 116 (1954); AERE-LIB/Trans. 562, Harwell, Berkshire, England (1955).
12. L. Bernath. "A Theory of Local-Boiling Burnout and Its Application to Existing Data." *Chem. Eng. Prog. Sym. Ser. 56* (30), 95 (1960).
13. Y. P. Chang. *An Analysis of the Criticality Conditions and Burnout in Boiling Heat Transfer.* USAEC Report TID-14004, Oak Ridge National Laboratory, Oak Ridge, Tenn. (1961).

TML:sce