

ASSESSMENT OF THE POTENTIAL FOR HYDROGEN GENERATION DURING GROUTING OPERATIONS IN C-REACTOR DISASSEMBLY BASIN

B. J. WIERSMA

Savannah River National Laboratory
Materials Science and Technology Directorate

Publication Date: July 2011

This document was prepared in conjunction with work accomplished under Contract No. DE-AC09-08SR22470 with the U. S. Department of Energy

We Put Science To Work

The Savannah River National Laboratory is managed and operated for the U.S. Department of Energy by

SAVANNAH RIVER NUCLEAR SOLUTIONS, LLC

AIKEN, SC USA 29808 • SRNL.DOE.GOV

DISCLAIMER

This report was prepared under an agreement with and funded by the U. S. Government. Neither the U. S. Government or its employees, nor any of its contractors, subcontractors or their employees, makes any express or implied: 1. warranty or assumes any legal liability for the accuracy, completeness, or for the use of results of such use of any information, product or process disclosed; or 2. representation that such use or results of such use would not infringe privately owned rights; or 3. endorsement or recommendation of any specifically identified commercial product, process or service. Any views and opinions of authors expressed in this work do not necessarily state or reflect those of the United States Government, or its contractors, or subcontractors.

DOCUMENT: SRNS-STI-2011-00364

<u>TITLE:</u> Assessment of the Potential for Hydrogen Generation During Grouting Operations in C-Reactor Disassembly Basin

<u>APPROVALS</u>	
B. J. Wiersma, Author	
Materials Performance and Corrosion Technology Materials Science and Technology	
B. Garcia-Diaz, Technical Reviewer Materials Performance and Corrosion Technology Materials Science and Technology Directorate	
Date: K. E. Zeigler, Manager Materials Performance and Corrosion Technology Materials Science and Technology Directorate	
Date: J. K. Blankenship, Customer SDD Decommisioning Engineering	

SRNL-STI-2011-00364

Table of Contents

Executive Summary
Introduction
Approach
Determination of Cross-Sectional Area of the Basin
Determination of Actual Aluminum Surface Area
Determination of Minimum Ventilation Rate
Results
Conclusions and Recommendations
References
APPENDIX 1
APPENDIX 2
List of Figures
Figure 1. Universal Sleeve Housing located in the Vertical Tube Storage region of the
basin.
Figure 2. Aluminum Areal Density Ratio for Flammable Condition in Grout1
Figure 3. Aluminum Areal Density Ratio for Flammable Condition in Ca(OH) ₂
Figure 4. Time dependence of temperature at the center of a mortar form for various
cementitious materials
Figure 5. Assessment of Flammability Condition for Grout at 50 °C14
Figure 6. Assessment of Flammability Condition for Ca(OH) ₂ at 40 °C
Figure 7. Assessment of Hydrogen Accumulation as a Function of Building Ventilation for
Aluminum Exposed to Grout at 50 °C
Figure 8. Assessment of Hydrogen Accumulation as a Function of Building Ventilation for
Aluminum Exposed to Ca(OH) ₂ at 62 °C
Aluminum Exposed to Ca(Ori)2 at 02 C
List of Tables
Table 1. Cross-Sectional Area of the Disassembly Basin Regions and Aluminum
Component Surface Area7

Assessment of the Potential for Hydrogen Generation During Grouting Operations in C-Reactor Disassembly Basin

Executive Summary

C-reactor disassembly basin is being prepared for deactivation and decommissioning (D&D). D&D activities will consist primarily of immobilizing contaminated scrap components and structures in a grout-like formulation. The disassembly basin will be the first area of the C-reactor building that will be immobilized. The scrap components contain aluminum alloy materials. Any aluminum will corrode very rapidly when it comes in contact with the very alkaline grout (pH>13), and as a result would produce hydrogen gas. To address this potential deflagration/explosion hazard, Savannah River National Laboratory (SRNL) reviewed and evaluated existing experimental and analytical studies of this issue to determine if any process constraints are necessary.

The risk of accumulation of a flammable mixture of hydrogen above the surface of the water during the injection of grout into the C-reactor disassembly area is low if the assessment of the aluminum surface area is reliable. Conservative calculations estimate that there is insufficient aluminum present in the basin areas to result in significant hydrogen accumulation in this local region. The minimum safety margin (or factor) on a 60% LFL criterion for a local region of the basin (i.e., Horizontal Tube Storage) was greater than 3. Calculations also demonstrated that a flammable situation in the vapor space above the basin is unlikely. Although these calculations are conservative, there are some measures that may be taken to further minimize the risk of developing a flammable condition during grouting operations.

- 1. Minimize the initial temperature of the water and grout as much as practical. Lower temperatures will mean lower hydrogen generation rates.
- 2. Ventilate the building above the basin rim as much as practical (e.g., leave doors open and operate fans) to further disperse hydrogen.
- 3. Minimize interruptions to the grout placement process as much as possible. Interruptions will result in higher water temperatures and hence higher hydrogen evolution rates.
- 4. Grout areas where the actual areal density ratios are the highest (e.g., Horizontal Tube Storage and Vertical Tube Storage) first. Thus, the areas that will produce the highest volume of hydrogen will have the maximum building volume in which to expand.

Introduction

The C-Reactor building is being prepared for deactivation and decommissioning (D&D). D&D activities will consist primarily of immobilizing contaminated components and structures in a grout-like formulation. The disassembly basin will be the first area of the C-reactor building that will be immobilized. The disassembly basin may be divided into

six primary areas: Horizontal Tube Storage, Vertical Tube Storage, Dry Cave, D&E Canal, Machine Basin (including the Monitor Basin) and the Transfer Station.

Currently contaminated scrap components from the reactor and basin are scattered across the basin floor in a random fashion (see Figure 1). Furthermore, the basin is filled with water to within 79 inches of the 0'-0" elevation. The current plan is to inject grout beneath the water in order to immobilize the scrap components and any sludge material on the basin floor.

The scrap components contain aluminum alloy materials [1]. Aluminum corrodes very rapidly when it comes in contact with the very alkaline grout (pH>13), and as a result will produce hydrogen gas [2]. If the areal density ratio (i.e. surface area of aluminum to cross-sectional area of basin floor) exceeds a critical value, the volume percentage of hydrogen at the water surface could exceed the lower flammability limit (i.e., 4 vol.%). To address this potential deflagration/explosion hazard, Savannah River National Laboratory (SRNL) reviewed and evaluated existing experimental and analytical studies of this issue to determine if any process constraints are necessary.




Figure 1. Universal Sleeve Housing (USH) located in the Vertical Tube Storage region of the basin.

Approach

Pacific Northwest National Laboratory (PNNL) developed a methodology for assessment of hydrogen generation during grouting operations at the K basins at the Hanford Site [3]. Likewise, similar analyses were performed for the R and P reactor Disassembly Basins at

SRS [4, 5]. These documents were reviewed and applied to the situation for C-basin. The approach is as follows:

- 1) Aluminum corrodes upon exposure to the high pH grout.
- 2) Hydrogen is generated as a consequence of the corrosion reaction.
- 3) The gas rises to the surface of the water in the form of bubbles.
- 4) The bubbles will burst at the water surface releasing H₂ gas into the stagnant air layer.

This process was modeled by formulating a kinetic law for hydrogen production as a function of the grout temperature and combining it with a model for vertical turbulent diffusion of a light fluid (H₂) through a heavier miscible fluid medium (air). Vertical turbulent diffusion is a process analogous to molecular diffusion. However, the diffusion coefficient is several orders of magnitude larger than the molecular diffusion coefficient for the H₂/air mixture, because vertical diffusion of the lighter gas is due to buoyancy rather than molecular motion. This model has been confirmed experimentally and has been shown to be effective for predicting diffusion layers that are broader than they are tall (i.e., similar to the basin floor [6]).

The assumptions used in the analysis were:

- The aluminum metal sources are situated on the bottom of the basin pool and are not covered by or contained within structures where hydrogen could accumulate.
- Once the hydrogen reaches the floor of the basin (i.e., 0'-0" elevation), there is sufficient advection to disperse the hydrogen within the building superstructure.

Based on these assumptions the most likely location for hydrogen accumulation is in the region between the water surface and the 0'-0" elevation.

The first part of the model involved developing a kinetic law for the generation of hydrogen during the corrosion of aluminum. Laboratory tests were performed at PNNL to measure the hydrogen generation rate of non-corroded aluminum metal coupons immersed in both grout and in saturated Ca(OH)₂ solution. Ca(OH)₂ solution is formed when water is added to the grout. The key results from the tests were:

- The initial hydrogen generation rate of non-corroded aluminum metal in a grout mixture at 25 °C is 0.3 cm³/min.
- The initial hydrogen generation rate of non-corroded aluminum metal in Ca(OH)₂ solution at 25 °C is 1.1 cm³/min.
- The initial hydrogen generation rate of non-corroded aluminum metal in Ca(OH)₂ solution at 50 °C is 5.4 cm³/min.
- The hydrogen generation rate of non-corroded aluminum metal in grout decreases to approximately 0.15 cm³/min after 2 to 3 hours of exposure to the grout mixture at 25 °C. Likewise, the hydrogen generation rate of non-corroded aluminum metal in Ca(OH)₂ decreases to approximately 0.27 cm³/min at 25 °C and approximately 0.18 cm³/min at 50 °C. The decrease in corrosion rate is due to the

formation of a corrosion product (principally tricalcium aluminum hydroxide and hydrocalumite) layer on the surface of the aluminum metal.

The Arrhenius equation for the hydrogen generation rate was derived previously for grout and Ca(OH)₂ [4]. For grout, the volumetric hydrogen generation rate per unit area of aluminum (Q') is:

$$Q' = 55.68 \exp(-5339/T)$$
 (1)

where T is the temperature in °K. Similarly, for Ca(OH)₂ Q' is:

$$Q' = 262.1 \exp(-5339/T)$$
 (2)

The following conservatisms and uncertainties were considered when applying the data to the C-basin situation.

- The experimentally measured hydrogen generation rate was determined on clean or non-corroded aluminum metal. The surface of the aluminum metal in the basins is corroded. The aluminum metal in the basins has been there for many years and the surface is protected by either a natural thin hydroxide film or a corrosion product layer. In either case, the rate of hydrogen generation from corrosion would be lower than that measured for the non-corroded aluminum metal coupons in the laboratory tests.
- The hydrogen generation rate due to aluminum metal corroding in grout is based on only one relevant gas generation test. However, four tests were conducted in a Ca(OH)₂ solution and the results were consistent based on chemical engineering fundamentals (i.e., mass transfer conditions in the grout are poorer than those in the Ca(OH)₂ solution). Additionally, the hydrogen gas generation rate for the aluminum in grout was also comparable to other values in the literature. Matsuo et al. measured a rate of 0.105 cm³/min for aluminum exposed to Portland cement at room temperature [7, 8].
- The hydrogen generation rate for aluminum metal in grout was performed at 27 °C. Extrapolation of this result to hydrogen generation rates for higher grout temperatures was made using the test results from aluminum exposed to Ca(OH)₂ solution. However, the five-fold increase in hydrogen generation rate with a 30 °C increase in the Ca(OH)₂ solution temperature is consistent with literature values for hydrogen generation in grout. Matsuo et al. observed a 3 fold increase in hydrogen generation rate with a 30 °C increase in an inhibited grout mixture [9].

While the last two bullets do indicate that there is uncertainty in the experimental data due to the limited number of laboratory tests, it is unlikely that this is significant relative to other conservatisms in the analysis.

The mass transport equation was also derived previously [4]. The superficial velocity, u_0 , was expressed as:

$$u_0 = \beta^2 [gH (1 - (M_L/M_H) X_{LFL}^3]^{1/2}$$
 (3)

where β is a proportionality constant equal to 1.64, g is the gravitational acceleration, H is the distance from the water-air interface to the basin's 0'-0" elevation, M_L is the molecular weight of hydrogen, M_H is the molecular weight of air, and X_{LFL} is the volume fraction of hydrogen at the lower flammability limit (LFL).

The following conservatisms and uncertainties were considered when applying the diffusion model to C-basin.

- 1) The analysis does not account for dissipation of hydrogen between the surface of the water and the 0'-0" elevation of the basin due to advection. Accounting for this phenomenon would minimize the accumulation of hydrogen in this region.
- 2) The analysis assumed that the hydrogen bubble plume does not expand laterally from the aluminum metal source. In reality, local concentrated sources of aluminum metal will produce a bubble plume which expands laterally as it rises through the water. Thus, the potential for a local deflagration/explosion is overestimated in this analysis.

The incipient flammability condition occurs when the gas generation rate due to corrosion equals the flux of hydrogen through air. The critical condition occurs at the water-air interface when the hydrogen gas concentration exceeds the LFL. The LFL for hydrogen in air is 4% by volume. To assess safety margins, the calculations were also performed with a criterion of 60% of the LFL. This value is utilized for safety class operations that involved the handling of radioactive storage vessels [10].

The critical areal density ratio can be derived by equating the kinetic law for hydrogen generation rate to the vertical turbulent diffusion rate of hydrogen when the hydrogen concentration at the surface of the water is the LFL. This derivation was also performed previously [4]. The critical areal density ratio is defined as:

$$(A_{Al}/A_{floor})c = u_0/Q'$$
 (1)

where A_{Al} is the surface area of the aluminum, A_{floor} is the cross-sectional surface area hydrogen will diffuse through, u₀ is the superficial velocity of the hydrogen gas as it diffuses toward the 0'-0" elevation of the basin, and Q' is generation rate of hydrogen due to corrosion of aluminum. The actual areal density ratio will be compared to the calculated critical ratio. If the actual ratio is greater than the critical calculated ratio, there is risk that the concentration of hydrogen gas at the surface of the water in the basin is greater than the lower flammability limit (LFL). Further precautions would be necessary if this condition exists. Two cases were considered, 1) aluminum exposed to grout only and 2) aluminum exposed to Ca(OH)₂ solution. The latter case is considered in grouting operations where there are interruptions for operational or other reasons. In this situation the water is assumed to become saturated with Ca(OH)₂.

Figure 2 shows a plot of the critical areal density ratio as a function of temperature for aluminum exposed to grout. The ratio decreases with temperature as expected due to the increase in corrosion rate, and hence hydrogen generation rate, with temperature. The plot also shows the critical areal density ratio for both 100% and 60% LFL.

Figure 3 shows a similar plot for aluminum exposed to Ca(OH)₂. The critical areal density ratios are lower than those for the grout, which reflects the higher aluminum corrosion rate. Again the plot also shows the critical areal density ratio for both 100% and 60% LFL.

Heat is added to the system during the grout curing process through the heat of hydration. The heat of hydration is the heat evolved due to chemical reactions with water and is dependent upon the constituents present in the cement mix. Experimental data from the literature suggests that the maximum temperature does not occur until 10-20 hours after the curing process begins (See Figure 4 [9]). During the first 3 hours, when hydrogen generation is at a maximum, the temperature is expected to be less than 50 °C [9]. Since the corrosion reaction decreases significantly after 3 hours due to the formation of corrosion products on the aluminum surface, it is the first 3 hours that are the most critical from the standpoint of hydrogen evolution. Thus, for this evaluation it will be assumed that the maximum temperature of the grout is 50 °C.

One concern is that the grout placement will be interrupted for operational or other reasons. If this is the case, the temperature of the water above the concrete will begin to increase due to the heat of hydration. An energy balance was performed to estimate the maximum temperature rise of the Ca(OH)₂ solution. The conservatisms built into the analysis include:

- The energy balance assumed that the grout and basin water were a closed system and there was no thermal losses to the basin structure or to the air above the basin. Only heat conduction from the grout to the basin water was assumed, completely ignoring heat loss via natural convection.
- The quantity of heat generated by the heat of hydration used for the PNNL thermal analysis was for a cumulative 7 day period. This input is extremely conservative given that the critical time period of interest is the first 3 hours after exposure to Ca(OH)₂. For the C-basin the heat released during the first day was assumed to be 25% of the heat released during the 7 days. This assumption takes into account that the heat generation rate is high initially; however, heat generation is not significant to the hydrogen generation rate after the first 3 hours. Therefore, it is less than the cumulative heat generated that is assumed in the PNNL analysis.

The calculations are shown in Appendix 1. The calculation was performed for various grout pour heights, in order to simulate different interruption scenarios. The temperature rise also depends on the depth of the water. The depth of the water in the Horizontal Tube Storage (HTS) area was approximately 10 feet, while in the remaining areas the depth is approximately 23 feet. Therefore, for HTS, the maximum calculated

temperature was 62 °C, while for the other areas the maximum temperature was 40 °C. This evaluation is conservative as it assumes that operations were interrupted near the conclusion of the initial five foot lift.

Determination of Cross-Sectional Area of the Basin and Actual Aluminum Surface Area

The assessment was performed to ensure that hydrogen does not accumulate within a local region of the disassembly basin. As mentioned previously, the disassembly basin is divided into five primary regions. Drawings of these areas were studied to determine the cross-sectional area that the hydrogen will diffuse through during the grouting operation [11]. The localized area where most of the aluminum components were located was determined in consultation with D&D Engineering (see Appendix 2). The calculations are shown in the Appendix 1, and are summarized in Table 1.

Table 1. Cross-Sectional Area of the Disassembly Basin Regions and Aluminum Component Surface Area

Region of the Basin	Cross-Sectional Area (ft ²)	Aluminum Surface Area (ft ²)
D&E Canal	256	51
Horizontal Tube Storage	2180	9202
Vertical Tube Storage	664	1847
Machine Basin	1989	77
Dry Cave	735	394

D&D Engineering personnel performed a field walk-down to determine the configuration of the aluminum components [1]. Aluminum components that were identified include: universal sleeve housing (USH), safety rod thimble, target bundle, harp, and aluminum scrap. D&D Engineering performed calculations to estimate the total surface area of aluminum in each region of the basin [12]. These values are summarized in Table 2. The assessment was performed under the assumption that the aluminum components were uniformly distributed in a local region of the basin floor.

Determination of Minimum Ventilation Rate

If the building was not properly ventilated, conceivably hydrogen could accumulate in the building vapor space at concentrations greater than the LFL. To evaluate this risk, the building was modeled as continuous stirred tank reactor (CSTR). The derivation of the model equations are shown in Appendix 1. The model predicts the accumulation of hydrogen as a function of time and assumed ventilation rate.

Two bounding cases were evaluated. The first case assumes that the aluminum is exposed to grout at a temperature of 50 °C, while the second case assumes that the

aluminum is exposed to $Ca(OH)_2$ at 62 °C. Two criteria were used to assess the ventilation rates.

- 1) The ventilation rate needed to keep the hydrogen concentration less than 60% LFL and LFL for the first day was determined. Given that the corrosion rate decreases significantly after the first day, most of the hydrogen will accumulate during this time.
- 2) The time necessary for the hydrogen concentration to exceed 60% LFL and LFL was calculated. For this analysis the gas generation rate will be assumed to be constant and equal to the time averaged, one day hydrogen generation rate. This assumption is conservative for two reasons. First, the generation rate is known to decrease significantly due to passivation of the corrosion reaction. Secondly, the analysis will assume an infinite supply of aluminum in the basin, which clearly is not the case. Nevertheless, this criterion should show the benefits of providing ventilation during the operations.

Results

Figure 5 summarizes the flammability assessment for each of the basin regions for the condition where the aluminum is exposed to grout. The grout was assumed to be at the maximum temperature of 50 °C. The highest actual areal density ratios were observed for the Horizontal Tube Storage, 4.22, and the Vertical Tube Storage, 2.78. The critical areal density ratio for the 60% and 100% criteria is 116 and 249, respectively. The margins of safety for Horizontal Tube Storage and Vertical Tube Storage are a factor of 27 and 42, for the 60% and 100% criteria, respectively. This margin of safety was considered adequate (i.e., one to two orders of magnitude) when considering the usage of calcium aluminate sulfate grout for the P-reactor grouting operations [13]. At the 100% criterion these margins of safety increase to 59 for the Horizontal Tube Storage region and 89 for the Vertical Tube Storage region.

For perspective, in order to achieve the critical areal density ratio for the 60% criterion, the Horizontal Tube Storage region would need to contain approximately 3800 USH's. This value more than doubles to 8150 USH's if the 100% criterion is utilized. For the Vertical Tube Storage area, the critical areal density ratio for the 60% criterion could be achieved if there are more than 1160 USH's present; 2470 USH's would need to be present for the 100% criterion to be exceeded. Therefore, if the D&D Engineering is confident in the results of the field observations [1, 12], the development of a flammable situation in the basin is unlikely.

Figure 6 summarizes the flammability assessment for each of the basin regions, except Horizontal Tube Storage, for the condition where the aluminum is exposed to Ca(OH)₂. The Ca(OH)₂ was assumed to be at a temperature of 40 °C. The critical areal density for the 60% and 100% criteria for these regions is 42 and 90, respectively. The margins of safety for the Vertical Tube Storage is a factor of 15 for the 60% criterion. Although this margin is less than for the grouted condition, this margin of safety is also adequate [13]. At the 100% criterion, the safety factor for this region is 32.

In order to achieve the critical areal density ratio for the 60% criterion, the Vertical Tube Storage region would need to contain approximately 420 USH's; for the 100% criterion nearly 900 USH's would need to be present. This result indicates that there is less margin for safety if the operations were to be suspended before the five foot lift was completed. However, if D&D Engineering is confident in the results of the field observations [1, 12], the development of a flammable situation in the basin is unlikely.

Due to the shallower depth of the Horizontal Tube Storage region (i.e., 17 ft), there is less water available to heat. Therefore, the maximum temperature for the Ca(OH)₂ during a five foot lift was calculated to be 62 °C. The critical areal density for the 60% and 100% criteria for these regions is 14 and 29, respectively. The margins of safety for the Horizontal Tube Storage are a factor of 3.3 for the 60% criterion and 6.9 for the 100% criterion. These safety factors are less than an order of magnitude, however, would be equivalent to limiting maximum allowable hydrogen concentration to less than 15% of the LFL. A review of the safety requirements for the Tank Farm Facility indicates that this application would be analogous to a very slow generating tank [14]; that is, a tank where the hydrogen concentration will not achieve the lower flammability limit at steady state. Special controls are required in very slow generating tanks only if the steady state value exceeds 60% LFL. Thus, the calculations indicate that there is a sufficient margin of safety.

In order to achieve the critical areal density ratio for the 60% criterion, the Horizontal Tube Storage region would need to contain approximately 460 USH's; for the 100% criterion nearly 800 USH's would need to be present. This result indicates that there is less margin for safety if the operations were to be suspended before the five foot lift was completed. However, if D&D Engineering is confident in the results of the field observations [1, 12], the development of a flammable situation in the basin is unlikely.

Figures 7 and 8 summarize the results for the assessment of the effect of ventilation on the accumulation of hydrogen within the building above the basin area. For the case where the aluminum is exposed to grout at 50 °C, the accumulation of hydrogen for three ventilation rates is shown in Figure 7. After Day 1 there is little effect of ventilation rate on the hydrogen accumulation. In all three cases, the concentration of hydrogen was on the order of 0.04 vol.%, which is two orders of magnitude less than the LFL and a factor of 60 less than the 60% LFL criterion. These concentrations were observed even when the ventilation rate was on the order of 0.1 cubic foot/min.

The benefit of ventilation can be seen if the operations are extended for more than a day. Figure 7 shows that for a ventilation rate of 5 cubic foot/min, the hydrogen concentration will barely exceed 60% LFL and will never achieve the LFL. At 0.1 cubic foot/min the hydrogen concentration above the basin was calculated to exceed 60% LFL after 60 days and LFL after 100 days. As mentioned before, these concentrations are conservative as they do not account for the decrease in hydrogen generation due to passivation of the aluminum. On the other hand the uncertainties in the surface area of aluminum exposed also factor into this assessment as they did for the assessment of local accumulation of hydrogen. However, if D&D Engineering is confident in the results of the field

observations [1, 12], the development of a flammable situation in the vapor space above the basin is unlikely.

For the case where the aluminum is exposed to Ca(OH)₂ at 62 °C, the accumulation of hydrogen for three ventilation rates is shown in Figure 8. After Day 1, little effect of ventilation rate on the hydrogen accumulation was observed. In all four cases, the concentration of hydrogen was on the order of 0.3 vol.%, which is more than an order of magnitude less than the LFL and a factor of 8 less than the 60% LFL criterion. These concentrations were observed even when the ventilation rate was on the order of 0.1 cubic foot/min.

Figure 8 shows that for a ventilation rate of 50 cubic foot/min, the hydrogen concentration was calculated to never exceed 60% LFL, while at 30 cubic foot/min the hydrogen concentration does not achieve the LFL. At 0.1 cubic foot/min the hydrogen concentration is calculated to exceed 60% LFL after 7.5 days and LFL after 12.5 days. As mentioned before, these concentrations are conservative as they do not account for the decrease in hydrogen generation due to passivation of the aluminum. On the other hand the uncertainties in the surface area of aluminum exposed also factor into this assessment as they did for the assessment of local accumulation of hydrogen. However, if D&D Engineering is confident in the results of the field observations [1, 12], the development of a flammable situation in the vapor space above the basin is unlikely.

Conclusions and Recommendations

The risk of accumulation of a flammable mixture of hydrogen above the surface of the water during the injection of grout into the C-reactor disassembly area is low if the assessment of the aluminum surface area is reliable. Conservative calculations estimate that there is insufficient aluminum present in the basin areas to result in significant hydrogen accumulation in this local region. The minimum safety margin (or factor) on a 60% LFL criterion for a local region of the basin (i.e., Horizontal Tube Storage) was greater than 3. Calculations also demonstrated that a flammable situation in the vapor space above the basin is unlikely. Although these calculations are conservative, there are some measures that may be taken to further minimize the risk of developing a flammable condition during grouting operations.

- 1. Minimize the initial temperature of the water and grout as much as practical. Lower temperatures will mean lower hydrogen generation rates.
- 2. Ventilate the building above the basin rim as much as practical (e.g., leave doors open and operate fans) to further disperse hydrogen.
- 3. Minimize interruptions to the grout placement process as much as possible. Interruptions will result in higher water temperatures and hence higher hydrogen evolution rates.
- 4. Grout areas where the actual areal density ratios are the highest (e.g., Horizontal Tube Storage and Vertical Tube Storage) first. Thus, the areas that will produce the highest volume of hydrogen will have the maximum building volume in which to expand.




Figure 2. Aluminum Areal Density Ratio for Flammable Condition in Grout.




Figure 3. Aluminum Areal Density Ratio for Flammable Condition in Ca(OH)2.

Figure 4. Time dependence of temperature at the center of a mortar form for various cementitious materials. [7]




Figure 5. Assessment of Flammability Condition for Grout at 50 °C.




Figure 6. Assessment of Flammability Condition for Ca(OH)2 at 40 °C.




Figure 7. Assessment of Hydrogen Accumulation as a Function of Building Ventilation for Aluminum Exposed to Grout at 50 °C.




Figure 8. Assessment of Hydrogen Accumulation as a Function of Building Ventilation for Aluminum Exposed to Ca(OH)₂ at 62 °C.

References

- 1. W. B. Griffin, et.al., "Building 105-C Disassembly Basin (DB) Engineering Guidance for Scrap Relocation", SDD-2011-00058, Rev. 0, May 17, 2011.
- 2. S.-M. Moon and S.-I. Pyun, "The corrosion of pure aluminium during cathodic polarization in aqueous solutions", Corrosion Science, Vol. 39, pp. 399-408, 1997.
- 3. S. M. Short and B. M. Parker, "Potential for Generation of Flammable Mixtures of Hydrogen from Aluminum-Grout Interaction During Basin Grouting", PNNL-15156, April 2005.
- 4. B. J. Wiersma, "Assessment of the Potential for Hydrogen Generation During Grouting Operations in R-reactor Disassembly Basin" SRNL-STI-2009-00278, April, 2009.
- 5. B. J. Wiersma, "Assessment of the Potential for Hydrogen Generation During Grouting Operations in P-reactor Disassembly Basin" SRNL-STI-2009-00364, June, 2009.
- 6. M. Epstein and J. P. Burelbach, "Transient Vertical Mixing by Natural Convection in a Wide Layer", Int. J. Heat Mass Transfer, Vol. 43, pp. 321-325.
- 7. T. Matsuo, T. Nishi, and M. Matsuda, "LiNO₃ Addition to Prevent Hydrogen Gas Generation from Cement-Solidified Aluminum Wastes", J. Nuclear Science Technology, Vol. 32, No. 9, pp. 912-920, 1995.
- 8. T. Matsuo, et al., "LiNO₃ Effect on Corrosion Prevention of Aluminum with Complex Shapes", J. Nuclear Science and Technology, Vol. 34, No. 8, pp. 823-828, 1997.
- 9. T. Matsuo, et al., "Influence of Increased Temperature from Cement Hydration on Aluminum Corrosion Prevention when LiNO₃ is Added to the Cement", Nuclear Technology, Vol. 125, pp. 332-336, March 1999.
- 10. B. J. Wiersma, "Assessment of the Potential for Hydrogen Generation During Grouting Operations in the R- and P-Reactor Vessels" SRNL-STI-2009-00639, Rev. 2, June, 2010.
- 11. C-Basin Drawings

W134454 W134417 W134473 W134486

- 12. W. B. Griffin, "Surface Area of Aluminum Components and Material in 105-C Disassembly Basin", SDD-2011-00072, June 20, 2011.
- 13. B. J. Wiersma, "Compatibility of Stainless Steel and Aluminum Reactor Components with the Calcium Aluminate Sulfate Mix Design Utilized for Grouting of the P-Reactor Vessel", SRNL-STI-2010-00600, October, 2010.
- 14. B. C. Landeene, "CSTF Flammability Control Program", WSRC-TR-2003-00087, Rev. 17, December 2010.

APPENDIX 1

ENGINEERING COMPUTATION SHEET P. A 1 -2

C Reactor Disassembly Basin H2 Project No.	SR
Works	Thoot No.
4 5 6 7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27	Sheet No.
ckground	
the Creator discess by her There are find	
areas in the basin: Dry caves, Horizontal Tube Storage	
Vertical Tube Storage, Machine Basin, and D&E Carel.	
· Location and number of components were determined du	ring
a ficial walkard by DAD Engineering personnel (Ref	
· Surface area of immersed aluminum were calculated	R
by D\$D Engineering personnel (Ref. 2).	
level. During growting appretions the water will avaparate	
such that the water level remain constant.	
· The depth of the Horizontal Tube Storage area is	
with the exception of small isplated areas that	
have a depth of 50 feet	
· Aluminum materials are located on the floor of the	he
Dasin.	
. The grout will be poured in 5 foot lifts. Most o	, f
the componets will be covered by the first lift.	
1) W.B. Griffing et.al., Building 105-C Disassembly Basin (DB)	
Engineering Guidance for Scrap Relocation", SDD-2011-00058,	Rev. 8
1,7,7,011	
Z) W.P. Gritting Jurtace Area of Aluminum Components and I	Jateria 011
	ckground Aluminum component debris is located near the bottom of the C reactor disassembly basin. There are five local areas in the basin: Dry caves, Horizontal Tube Storage, Vertical Tube Storage, Machin Basin, and D&& areal. Location and number of components were determined due a field walkdown by DAD Engineering personnel (Ref. 2). Surface area of immuscul aluminum were calculated by DAD Engineering personnel (Ref. 2). The water level in the basin is 79" below floor level. During grouting operations the water will evaporate such that the water level remain constant. The depth of the Horizontal Tube Storage area is 17 feet. The depth of all remaining areas is 30ft, with the exception of small isolated areas that have a depth of 50 feet Aluminum materials are located on the floor of the basin. The grout will be poured in 5 foot lifts. Most of the components will be covered by the first lift.

Fitle of Project	C-Reactor	Disassembly	Basin H2	Project No.	\ SRS
Subject	3 4 5 6 7	Computer	BJ Wiersma 15 16 17	Works Date 6/16/11	Sheet No. 7
В	ackground (c	cont.)			
3					
4				e water and grow with time. due to	
5				s suspended, these	
7	assume	that the	huminum	is exposed to Cal	(DH)2
9	Calculation	determines	whether or	not hydrogen ac	cumulates
	at the	Surface of	the water	not hydrogen ac during grouting	operations.
11 12 Mo	60% LFL	criterion w	ill be used	to determine margin	on safety (ref
14 D	etermination	of Superfici	al Velocity	(u _o) (ref. 3)	
	See Spread	Isheet C-ba	sin Hz ger	neration. Xls, work	sheet VTD calc
18	u0 = 1	B= [g H (1-	(M_/MH) X 1	FL] 1/2	
20-	β=	proportionality	constant = c). 164	
22	ġ =	gravity = 9.5	3 m/s2	()	7.0
23		Molecular wei		floor = 79 inches = .	2.0 meters
25	MH=	Molecular n	reight of air	= 29 g/mole	
		0.04	for calculati	ons assume 60%	LFL will
27			provide Sate	ety margin XL	= 0.02+ (ret
28	uo =	4.27 × 104 m3/	้ที่-ร		
	Reference				
34	3) B.J. Wiersr	na, "Assessme	ent of the f	Potential for Hydrogen R-Reactor Disassem	Generation
	SRNL STT	- 2009 - 002	10 April 20	09	Diy Dasin

ENGINEERING COMPUTATION SHEET

			Computer BJ		Works Date 6/16	14	Shee
1 2	3 4 5 6	7 8 9	10 11 12 13	14 15 16 17	18 19 20 21	22 23 24	25 26 27 28
	Determi	nation	of Critica	1 Areal D	ensity R	atio	
		(A)					
		(HAI	= U0 Q'H2				
		At 100r/	QH2				
	Deter,	nine	AAI/Afloor a	s a function	of tem	perature	
	See	"C-basi	n H2 Gei	nevation" s	precdsheet	, workst	ect VTD cal
	٨		'1 0 1 C		0 1		
	Area	. 1 Vens	ity Ratio for		Avea	Donsity	Ratio for (
	TO	°C)	(A A /AHOPI		7/	(5)	AAI/AGIO
		0	2393	/6		0	508
		10	1199			10	255
		20	1630			20	134
		30	345			30	73
		35	259			35 40	55
		40 50	197			50	42
		60	176			60	15
		70	44			70	9
		80 90	28			80	6
		90	19			90	4
		100	/3	_		100	3
			24 or 68				
			mount of A	lluminum			
	Summary		rence 2	Acai (H	2)		
			al Tube Storage				
			ine Basin	77			
			Cave	394			
		Dry Co	ive-Center Pen	394			
			ial Tube Stora				
		DEE	Canal	70			

SRNL-STI- 2011-00364 OSR 25-10 (Rev 6-18-92) **ENGINEERING COMPUTATION SHEET** P. A1-4 Title of Project C- Reactor Disassembly Basin H2 Project No. Subject Works 6/16/11 BJWiersma Computer Date Corrosion Rate Hydrogen Generation Rate (see ref.3) For Grout Q'HZ = 55.68 exp (-5339/T) T = Temperature in K For Ca(OH) Q'H = 262.1 exp (-5339/T) Calculate Q'Hz as a function of T. Shown in spreadsheet "C-basin H2 generation" on worksheets
"Mol Diffusion Calcs" and "VTD calcs" Hz Generation for grout Hz Generation for Ca (OH). Q'uz (m3/2-s) X1 QH2 (m3/25) X107 T (°K) T (°K) 273 8.42 273 3.57 283 16.8 283 6.79 293 293 32,0 12.4-303 58.4 303 308 16.5 77.7 308 21.7 102 313 313 323 36.9 323 17A 60.6 333 333 285 343 96.7 455 343 353 353 708 150 363 363 228 1070 338 1590 373 373 Reference 4) BJ. Wiersma, "Assessment of the Potential for Hydrogen Generation During Grouting Operations in the R- and P-Reactor Vessels", SRN2-STI-7009-00639, Rev2

May 2010.

ENGINEERING COMPUTATION SHEET

SRNL-STI -2011-00364

P. 41-5

Project No. Title of Project C Reactor Disassembly Basin Hz Works Subject 6/16/11 Date Computer BJWiersma Determination of Critical Areal Density Ratio Determine AAI/Afroor as a function of temperature. The values for 60% LFL and 100% LFL will be compared for grout and Ca(OH)2. See "C-basin Hz Generation" spreadsheet, Worksheet VTD cales. Areal Density Ratio for Ca(ON)2 Areal Density Ratio for Ground (AAI/Alloar)c (AAI/Aspor)c T(0c) (AAI/ACIDOT)C T(°C) 100% LFL 60% LFL 60% LFL 100% LFL Determination of Amount of Aluminum Summary of Reference 2 A A1 (f+2) * All of Al is in Horizontal Tube Storage the center pen adjucent Machine Basin 394* to the Dry Cave Dry Cave Vertical Tube Storage D&E Canal

D. A1-6

Title of Projec	engineering computation sheet p. 21-0 C- Reactor Disassembly Basin H2 Project No.	SRS
Subject	Works	Sheet No.
	Computer B.J. Wiersma Date 6/26/11	26 27 28 29
,	Cross- Sectional Areas [See Appendix 2 for e-mail from W.B. Gri	Ain]
3	Vertical Tube Storage (YTS)	
6	Drawing W134454 & W134417; AR +0 0; 101 +0 102	
	AR to 0 is 32 ft; 101	to 102 is 20.
10	- Control Rods located in to area; Represents 76.2% of area (202,718 in out of 266,016	surface
13	- 2 of 3 USA'S Jocaded in a 18,912 sg. inches - Estimated 25 orifice Sleeves (~2	area
16	Area = $32' \times 20.75'$ in all VTS); 8133 in^2 $= 664 \text{ ft}^2 - \text{Estimated } 24'9, 275 \text{ in}^2 \text{ in area}$ $- \text{Assume all aluminum in th}$; ~ 9 4 70
	Machine Basin (MB)	
21	Drawing 134454 10' south of AR to 0; 105 to 108	
23	AR +0 0 is 32 ft; 105 to 10	08 is 62.17;
25 26 27	- Safety Rod Thimble and Seq located in this region	,titoi)
	Area = 32×62.17 = $1989 ft^2$	
51		

ENGINEERING COMPUTATION SHEET

SRNL-STI-2011-00364

P. A1-7

Proje t	ct C- Reactor Disassembly Basin	Project No. Works	1
	Computer B.J. Wie	Date 6/26/11	She
1	2 3 4 5 6 7 8 9 10 11 12 13 14	15 16 17 18 19 20 21 22 23 24 25 26 27	28
	Cross- Sectional Areas (cont.)		
	57033- Sections 1 Myeas (Cont.)		
	Horizontal Tube Storage (HTS)		
	, and the second		
-	Drawing W134454 & W134473	AL to 20' North of AL; 101 to 10	7
	,20	- Slotted Rack in this area;	
		1,222,144 sq. in represents 92%	of.
	AL	in HTS	
		- A - 	
		- Assume all aluminum is in the region of the HTS	15
		region of the title	
	Area = 20'x 109'		
	= 2/80 ft ²		
	Dry Cave (DC)		
	Drawing W134454 & W134486	30 foot (south of AR); 102 +	0/
	103 102 101 AR		
		- 6: 45H's located in Center pen area	
	30'	Center pen arez	
		Area = 30' x 24.5'	
		= 735 f+ ⁸	
	3° 3 17 17 17 17 17 17 17 17 17 17 17 17 17		

ENGINEERING COMPUTATION SHEET

SRNL-STI-2011-00364 P. A1-8

Computer BJ Wessense Date 6/26/11 Delie Canal Density W134.484, W134417) Actual Area G4 ft in length Actual Area Density Area G4 ft in length Actual Area Density Area G4 ft x 4 ft = 256 ft² Diff Canal Density At Actual Area Density At Malarea D. 27 Vertical Tube Stronge 2.78 Dry Care O.54 Horizontal Tube Stronge 4.22 Machine Bisin 0.04 Heat Transfer Calculations Determine the final temperature of the Water and grout after five foot lift has been powed. Mass of grout and water Pa Density of grout 125 lb/ft² reference 3 Pepends on pour height, h Mass of Depends on pour height, h Mass of Brownizonth Tube Storage (Note: Depth = 1747 - 6.5835 10.41874) Tor all others Depth = 30 ft - 6.5833 = 23.416744 and After Depth = 30 ft - 6.5833 = 23.416744	Title of Project	C-	Reactor	Disassem	ly Busi	n Hz	Project N		. A1-8		SRS
DIE Canal Oranings W134954, W134417) 64 ft in length VTS DIE I ft Area = 64 ft × 4 ft = 256	Subject						Works	6/24/11	/		Sheet No.
Actual Areal Density Area = 64ft x 4ft = 256ft² Area Density Area Den	1 2	3 4	5 6 7 8	Computer	DJ W/	15 16	17 18 19	20 21 22	23 24	25 26 27	28 29 30
Actual Areal Density Area = 64ft x 4ft = 256ft² Area Density Area Den	0										
Actual Areal Density Atea = 64ft × 4ft = 256 ft² Actual Areal Density All Affinor Difficial Tube Storage 0.27 Vertical Tube Storage 0.54 Horizontal Tube Storage 4.22 Machine Basin Determine the final temperature of the water and grout after five foot 11ft has been powed. Mass of grout and water Pa Density of grout 125 1b/6+3 Pepends on pour height, h Mass Depends on pour height, h Mass Depth = 30ft - 6.5833 = 23.4167ft For all others Depth = 30ft - 6.5833 = 23.4167ft	2	DIE	Canal	Drawi	ings W13	4:454	W1344/	7)			
Area = 64++ × 4++ = 256 ft² Actual Areal Density Asi /Athor Difficance Difficance Difficance Difficance Difficance Difficance Difficance Asi /Athor Difficance Difficance Difficance Difficance Asi /Athor Difficance Difficance Difficance Asi /Athor Difficance Di	3		7643		64 f	t in	length	1 -	7.		
Actual Areal Density Area Difficance Difficance O.27 Vertical Tube Storage Dry Cave O.54 Horizontal Tube Storage O.04 Heat Transfer Calculations Determine the final Temperature of the water and ground after five foot lift has been powed. Mass of ground and water Pa Density of ground 125 1b/6+3 Pepends on power height, h Mass of Grown has been powed. Mass of ground and water Pa Density of water 62,4 1b/6+3 Pepends on power height, h Mass of Grown has been power height and has been power has been power has been power and has	5	VIS	D42	J ++	1.	- 66	11+ 1	4 ++			
Actual Areal Density Area Difficance Difficance O.27 Vertical Tube Storage Dry Cave O.54 Horizontal Tube Storage O.04 Heat Transfer Calculations Determine the final Temperature of the water and ground after five foot lift has been powed. Mass of ground and water Pa Density of ground 125 1b/6+3 Pepends on power height, h Mass of Grown has been powed. Mass of ground and water Pa Density of water 62,4 1b/6+3 Pepends on power height, h Mass of Grown has been power height and has been power has been power has been power and has	6				Area	= 25	6 f+2				
Ass of grout and water Passity of growt 125 1b/ft3 Pepends on pour height, h Mature Aftor Aftor Action Action Action Mature Aftor Action Action Action Mature Aftor Action Action Mature For All others Depth = 30ff - 6.5833 = 10.4167ff. For all others Depth = 30ff - 6.5833 = 23.4167ff.	8			A.F. T.	ī	X 8 .		800	3		
DIE cencl Vertical Tube Storage 2.78 Dry Cave O.54 Worizontal Tube Storage A.22 Machine Basin Determine the final temperature of the water and grout after five foot lift has been poured. Mass of grout and water Pa Density of growt 125 1b/ft3 Pensity of water 62.4 1b/ft3 Depends on pour height, h magnet = Aflow h x Pa water For All others Depth = 17ft - 6.5833= 10.4167ft For all others Depth = 30ft - 6.5833= 23.4167ft		Actual	1 Area 1	1 Density							
DIE cencl Vertical Tube Storage 2.78 Dry Cave Worizontal Tube Storage 0.54 Worizontal Tube Storage 4.22 Machine Basin Determine the final temperature of the water and grout after five foot lift has been poured. Mass of grout and water Pa Density of grout 125 1b/6+3 Pensity of water 62.4 1b/6+3 Pepends on pour height, h magnet = Afloor h x Pa water For All others Depth = 17++ 6.5833= 10.41674+ For all others Depth = 30++ 6.5833= 23.4167++		1			Δ.	/ .					
Vertical Tube Storage 2.78 Dry Cave 0.54 Horizontal Tube Storage 4.22 Machine Basin 0.04 Heat Transfer Calculations Determine the final Temperature of the water and grout after five foot lift has been poured. Mass of grout and water Pa Density of growt 125 1b/ft3 reference 3 Pu Density of water 62.4 1b/ft3 Depends on pour height, h Mass Depends on pour height, h		200									
Dry Cave Horizontal Tube Storage 4.22 Machine Basin Heat Transfer Calculations Determine the final Temperature of the water and grout after five foot lift has been poured. Mass of grout and water Pa Density of grout 125 1b/42 reference 3 Pw Density of water 62.4 1b/43 Depends on pour height, h Marrat = Afloor h x Pa water For Morizontal Tube Storage (Note: Depth = 17ft - 6.583= 10.41674+ For all others Depth = 30ft - 6.5833 = 23.4/67ft				e Storage				ia is			
Heat Transfer Calculations Determine the final Temperature of the water and grout after five foot lift has been poured. Mass of grout and water Pa Density of growt 125 1b/4+3 reference 3 Pu Density of water 62,4 1b/f+3 Depends on pour height, h Mass of grout 125 loff+3 Papends on pour height, h Mass of grout 125 loff+3 Papends on pour height, h Mass of growt 125 loff+3 Papends on pour height, h Mass of growt 125 loff+3 Papends on pour height, h Mass of growt 125 loff+3 Papends on pour height, h Mass of growt 125 loff+3 Papends on pour height, h Mass of growt 125 loff+3 Papends on pour height, h Mass of growt 125 loff+3 Papends on pour height, h Mass of growt 125 loff+3 Papends on pour height, h Mass of growt 125 loff+3 Papends on pour height, h Mass of growt 125 loff+3 Papends on pour height, h Mass of growt 125 loff+3 Papends on pour height, h Mass of growt 125 loff+3 Papends on pour height, h Mass of growt 125 loff+3 Papends on pour height, h	14										
Machine Basin Heat Transfer Calculations Determine the final Temperature of the water and grout after five foot lift has been poured. Mass of grout and water Pa Density of growt 125 1b/ft3 reference 3 Pw Density of water 62,4 1b/ft3 Depends on pour height, h Magnut = Afloor h x Pa water For Morizontal Tube Storage (Note: Depth = 17ft - 6.5833= 10.4167ft) For all others Depth = 30ft - 6.5833= 23,4167ft	15		Horizonto	al Tube S							
Heat Transfer Calculations Determine the final Temperature of the water and grout efter five foot lift has been poured. Mass of grout and water Pa Density of grout 125 16/6+3 reference 3 Pw Density of water 62.4 16/6+3 Depends on pour height, h magnet = Afloor h x Pa water 10.41574 For Morizontal Tube Storage (Note: Depth = 17ft - 6.5833= 10.41676+ For all others Depth = 30ft - 6.5833= 23.4167ft					V	0.04					
Determine the final Temperature of the water and grout after five foot lift has been poured. Mass of grout and water Pa Density of grout 125 16/ft3 reference 3 Pew Density of water 62,4 16/ft3 Depends on pour height, h Mass of grout 125 16/ft3 reference 3 Water For Morizontel Tube Storage (Note: Depth = 17ft - 6.5833= 10.4167ft) For all others Depth = 30ft - 6.5833 = 23,4167ft			1								
Mass of grout and water Pa Density of growt 125 16/ft3 reference 3 Pew Density of water 62.4 16/ft3 Depends on pour height, h Mass of growt and water	19	Heat	Transfe	er Gleu	lations						
Mass of grout and water Pa Density of growt 125 16/ft3 reference 3 Pew Density of water 62.4 16/ft3 Depends on pour height, h Mass of growt and water	21	7			+ ,	1	1/ 0			-	-Chair
Mass of grout and water Pa Density of growt 125 16/ft3 reference 3 Pew Density of water 62.4 16/ft3 Depends on pour height, h Mass of growt and water		five	foot li	e tinal	been po	oured.	THE	Don't es	and.	growi	
Pa Density of growt 125 $1b/ft^3$ reference 3 Paper Density of water 62.4 $1b/ft^3$ Depends on pour height, h Magrint = Afloor h x Pag Water For Horizontel Tube Storage (Note: Depth = 17ft - 6.583)= 10.4167ft For all others Depth = $30ft - 6.5833 = 23.4167ft$											
Depends on pour height, h Magnet = Afloor h x Pg water For horizontel Tube Storage (Note: Depth = 17ft - 6.5833= 10.4167ft For all others Depth = 30ft - 6.5833 = 23,4167ft	25	Mass	of gro	out and	water						
Depends on pour height, h Magnet = Afloor h x Pg water For horizontel Tube Storage (Note: Depth = 17ft - 6.5833= 10.4167ft For all others Depth = 30ft - 6.5833 = 23,4167ft	27	Pa	Density of Density	of growt of water	125	16/f+3	refere	nce 3			
mgrout = Afloor h x Pg water For horizontal Tube Storage (Note: Depth = 17ft - 6.5833= 10.4167ft For all others Depth = 30ft - 6.5833 = 23,4167ft											
water For horizontal Tube Storage (Note: Depth = 17ft - 6.583)= 10.4101ft. For all others Depth = 30ft - 6.5833 = 23,4167ft	10	Ve	pends o	n pour	height	, h					
water For horizontal Tube Storage (Note: Depth = 17ft - 6.583)= 10.4101ft. For all others Depth = 30ft - 6.5833 = 23,4167ft			Marout	= Afloor	h x eg						
For all others Depth = 30ft - 6.5833 = 23,4167++		water	For he	orizontel T	Tube Ston	rage	(Note:	Depth =	17f+-	6.5833=	10,4167ft
Dia / n II la I V i	Ja		For	all others	Dep	1th =	30++ -	- 6.5833	= 23,4	161++	

SRNL-STI-2011-00364 ENGINEERING COMPUTATION SHEET

P. A1-9

Title of ProjectSubject	C- Keactor Disassembly	Basin Hz	Project No. Works	ana
	Computer B	JWiersma	. /	Sheet No. 8
0 2	3 4 5 6 7 8 9 10 11 12 13	14 15 16 17	18 19 20 21 22 23 24 25 26	27 28 29 30
2	Cp - Specific Heat Se	e reference	3	
5	Cp, y = 0.25 BTU/11 Cp, w = 1.0 BTU/	,-4 (16-°F)		
7	Temperature			
9	Grant Temperature = Tg =	Assume co	instant @ maximum value o	+ 50°C(120
11	Water Temperature = Tw =	Initial amb	pient temperature of 27°C	(80°F)
	Analysis Methodology			
15	1st Law of Thermodyna	ini		
17	Heat Work	internal energy	Kinetic Potential energy energy	
18	Q - W =	Du +	AXE + APE	
	$Q = \Delta$			
21	$\Delta u = m C_{\rho} (T_{4} - T_{i})$		Tt = Final Temperature	
			T. = Initial Temperature	
25	Q Assumed same h	eat transfe	r as reference 3	
27	$Q = Q \times P_3 \times$			
26				
	$\bar{Q} = 40 \text{ BT}$ V_{growt} $\bar{Q} = \Delta U_{\text{g}}$	4/16m	iter	
	48,000			
	$Q = \Delta U_g$	+ DUW		
24				

ENGINEERING COMPUTATION SHEET

P. A1-10

	C-Keactor		,	Project No. Works		
		Computer	BJW	Date 6	/18/11	Shee
1 2	3 4 5 6 7	8 9 10 11 12	13 14 15 16 17	18 19 20	2) 22 23 24 25	26 27 28
					7 7	
	T. =		CP& Ting		w li, w	
	T _f =	[mg Co	g + mw	CP.W]		
	1					
	Calculations	were perf	ormed on	Spreads	heet "C-bas	sin Tem
	Worksheet			•		
	Results					
	11					
	1	L L	I I Tab Cla		A11 11 - A	
P	our height, A (izontal Tube Sto perature (°C)	rage	All other Are Temperature	
10	0.5		29		28	
	1.0		32		29	
	1,5		35		30	
	2.0		38		32	
	2.5		42		3 3	
	3.0		45		34	
	3.5		49		36	
	4.5		53		37	
	5.0		57 62		38 40	
	3.0		O Lou		70	
	Maximum	Temperatures				
	Grout	- 50°C				
	Water	- Horizon	tal Tube S	storage:	62°C	
		A11 0	ther Areas	: 40	٥٢	

OSR 25-10 (Rev 6-18-92) Title of Project	Reactor		EERING COMPUTATION		t No.	p. Al -11	SRS
Subject			B.J. Wiersm	Works			Sheet No. 10
0 1 2 3 4	5 6 7 6	9 10 11 12	13 14 15 16	17 18 19	20 21 22	23 24 25 26 2	27 28 29 3
Mode	el for I	Detarm in ing	Minimum	1 Bu;	lding Ve	nilation	
5	- Building tank	can be reactor to he vapor :	modeled assess	as a	continaccumula	nous stirred	/
8	CA V	CAO	vo + R	A	= d (CA	\bigvee_{b}	
12		CA = Concer CAANT = CONC RA = My Vo = Ve	tration of centration of drogen gener	Hz floration ra	wing into wing out the due	building = a building to a humin m	Corroslan
15		Vb = Volu	me of v	lapor s	pace abo	ove the be	छोम
17		- CAONT 1	t RA	=	Vb dc	L Cout	
	Re-w	vite equas	flon in e fraction	terms of	of volu 42. Use	metric generalides !	dion aw.
		C April =	CXAout	where	XAOW =	: Volume fra	etton of H
		RA = dr	TI RT	d Va dt	dVA =	Volumetric hydrogun gene rate	nation
		C = = =	PRT			rate-	
						Vb RT dxA	
		$\frac{dx_{A}}{dt}$	Vo X.A	= 0	d Va		
					V6		

		LINGI	JN SHEET	4		
itle of Project _	C-Reactor	Disassembly	Basin	H2	Project No.	P, ~
_						

Subject Works

		Со	mputer <i>B</i> ,	J. Wiers	ma	_ Date _	7/6/11		Sheet No.
0 1 2 3	4 5 6 7	8 9 10	11 12 1	3 14 15	16 17	18 19	20 21 22	23 24 25	26 27 28 29
1	1. (
2	dVA		21.	1,				,	
3	dt ch	anges	WHY	time	due	to	passivati	on of a	a luminum
4		· ·							
5	Assume	d VA	15	consta	nt.	Assum	e the r	ate is .	equal
6		dt							
	to the	hyd	rogen	acuera	ted	in	ne day	divide	d by
			0 -	9					
8	the h	ours 1		day					
9		,	v/ a	Jacy,					
0	_ £.	refere	nce 4						
1	Tram	letere	ince 1		t 1	-2.31	t		
2			V _A		Q42	e-2.31	dt		
,		9	$\frac{v_A}{t} =$	6					
		a.	T			1t			
3		,							
,		2 = Vc	lumetric	Hz	gener	ation	rute pe	v unit h	trea .
		t= th	ne in	hours			•		
							124		
		dVa		Qu.	5	-2,31±			
		dt	=	2.31	Le				
		of .			-	4	7 10		
				01			-2.3/(24)	. —	
				Q,		1 - e	-2.3/(24)		
				7,31 (24)	<u> </u>		» O		
				01					
			-	QHL					
				55.4					
	In orde	r to	obtain	a	volum	netric	flow res	e Qu	must
	be multip	lied b	y the	Surfi	0 01	rea c	of alum	in was re-	ting
		Onser va						umed the	
							: 1	0/	
	ari the	alumin	ush ir	7 1/10	- ba	SIN 1	is reach	ns. heter	rence
	2 indica	tes the	t this	15 Ha=	11,57	2 ++	•		
		71/				\	0.00		
,	R _A	- dva		Q4, 55.4	× /	A, =	209	* OH	
		at		55.4					

SRNL-STI-2011-00364 p. A1-13

ENGINEERING COMPUTATION SHEET

Title of Project	C-Re	actor	Disas	seme	bly	Bu	in	Hz		Projec			,,,,				5	RS
Subject					R	T	+ H			Works		-1,	1				IM Chao	
1 2 3	4 5 6	3 7	8 9	ompute	er <u>B.</u>	13	W 1873	5MC 16	17	Date	20	21	22 23	24	25 28	3 27	28	et No. /
2	For	Ca (он),	+1	he	hi	ghes	t	Qu	Co	ould	0	ccur	in	the	2		
3	horizon																ıld	
5			620															
8	Sheet																	
9	For	gro	ut a	7	ah	7.43	tem	perc	stus	rė	af	50	200	Q	H2 ⁵	= 3,.,	.69,	
12	Solve	2	initial	(V	ra l ue	2	pro	, blen	n									m2-5
13			dx_{h}	1	-	Vo	×	< A	t g		R	A						
15			01+		× _A =							d/						
18												\ .						
20			XA	=	R'	1		- (9	40/1	<i>b</i>)							
22																		
24	Vb =	Volu	me o	f	Vap	or	5	pace	e,	bore	1	Dasin						
28	(rose-	section	na l	A	ca	pei	r d	rawl	ng	W	134	154					
28		ò	203,20 Heic	5 fee	t ~ 20	x 1	30 let	feet	- =	20 +h	,42	3 ft	v lev	0 0	Į,	the	bas	Cia
30			Va l															
32																		
34	- Dete	ermine 1 i:	s t	X _A	as heep	a	f.	unctl le	0A	of the		Vo .	o of	the	LF	L.		

APPENDIX 2

06/22/2011 04:34 PM



Re: 105-C D&E Canal in Process Room

William Griffin to: Bruce Wiersma

John Blankenship, John Musall, Michael Serrato, Christine Langton, Kristine Zeigler, Brenda Garcia-Diaz

History:

This message has been replied to.

See comments in red below; slight variation to yours.

Bill Griffin **D&D** Engineer Office 803-952-6449 Cell 803-761-1338 Pager 31164

Bruce Wiersma

Bill, I thought I would write an e-mail to verify our...

06/22/2011 12:18:59 PM

From: To:

Bruce Wiersma/SRNL/Srs

William Griffin/SRNS/Srs@Srs

Cc:

John Blankenship/SRNS/Srs@Srs, John Musall/SRNS/Srs@Srs, Michael Serrato/SRNL/Srs@Srs,

Christine Langton/SRNL/Srs@Srs. Kristine Zeigler/SRNL/Srs@Srs. Brenda

Garcia-Diaz/SRNL/Srs@Srs

Date:

06/22/2011 12:18 PM

Subject:

Re: 105-C D&E Canal in Process Room

Bill,

I thought I would write an e-mail to verify our discussions from yesterday. We were trying to determine a representative local area for the analysis. That is what is the cross-sectional area of the basin that should be considered for the analysis. I have summarized what we said by referring to coordinates that appear on drawing W134454.

Vertical Tube Storage: AR to O by 101 to 102; Control Rods contribute to majority of aluminum surface area. Agree

Machine Basin: AR to O and 106 to 108; Septifoil and Safety Rod Thimble contribute to majority of aluminum surface area. 10' south of AR to O by 105 to 108

Horizontal Tube Storage: AL to 18 feet north of AL by 101 to 107; Racks with USH's contributes to the majority of the surface area. AL to 20' north of AL by 101 to 107

Dry Caves: 28.5 feet by 102 to 103; USH's present. 30' by 102 to 103

D&E Canal: 64 feet by 4 feet; We had agreed on this previously. Agree

If you could let me know if you agree with this.

Thanks.

Bruce J. Wiersma Savannah River National Laboratory Materials Science and Technology Bldg. 773-A, Rm. D-1125

Phone: 725-5439 FAX: 725-7369

e-mail: bruce.wiersma@srnl.doe.gov

William Griffin	l just sent you a copy. Bill Griffin	05/23/2011 04:29:11 PM				
Bruce Wiersma	Bill, Thanks for the photos. I was looking for the	05/23/2011 04:23:46 PM				
William Griffin	Photos for your use and info. Bill Griffin	05/23/2011 04:18:56 PM				