

**Contract No:**

This document was prepared in conjunction with work accomplished under Contract No. DE-AC09-08SR22470 with the U.S. Department of Energy (DOE) Office of Environmental Management (EM).

**Disclaimer:**

This work was prepared under an agreement with and funded by the U.S. Government. Neither the U. S. Government or its employees, nor any of its contractors, subcontractors or their employees, makes any express or implied:

- 1 ) warranty or assumes any legal liability for the accuracy, completeness, or for the use or results of such use of any information, product, or process disclosed; or
- 2 ) representation that such use or results of such use would not infringe privately owned rights; or
- 3) endorsement or recommendation of any specifically identified commercial product, process, or service.

Any views and opinions of authors expressed in this work do not necessarily state or reflect those of the United States Government, or its contractors, or subcontractors.



# **Selection of Glasses in Support of the Sludge Batch 9 Sulfate Solubility Limit for Coupled Operation with the Salt Waste Processing Facility**

**F.C. Johnson**

July 2019

SRNL-STI-2019-00323, Revision 0



## **DISCLAIMER**

This work was prepared under an agreement with and funded by the U.S. Government. Neither the U.S. Government or its employees, nor any of its contractors, subcontractors or their employees, makes any express or implied:

1. warranty or assumes any legal liability for the accuracy, completeness, or for the use or results of such use of any information, product, or process disclosed; or
2. representation that such use or results of such use would not infringe privately owned rights; or
3. endorsement or recommendation of any specifically identified commercial product, process, or service.

Any views and opinions of authors expressed in this work do not necessarily state or reflect those of the United States Government, or its contractors, or subcontractors.

**Printed in the United States of America**

**Prepared for  
U.S. Department of Energy**

**Keywords:** *DWPF, sulfate solubility limit, Frit 803, Frit 625*

**Retention:** *Permanent*

# **Selection of Glasses in Support of the Sludge Batch 9 Sulfate Solubility Limit for Coupled Operation with the Salt Waste Processing Facility**

F.C. Johnson

July 2019

---

Prepared for the U.S. Department of Energy under contract number DE-AC09-08SR22470.



## EXECUTIVE SUMMARY

For Sludge Batches 3 through 8, the sulfate ( $\text{SO}_4^{2-}$ ) solubility limit for the Defense Waste Processing Facility (DWPF) has been determined by laboratory-scale crucible testing. In preparation for Sludge Batch 9 (SB9) processing, a comparison demonstrated that minor compositional differences existed between the Sludge Batch 8 (SB8)-Frit 803 and SB9-Frit 803 glass composition regions for sludge-only and coupled operations with the Actinide Removal Process (ARP) and Modular Caustic Side Solvent Extraction Unit (MCU). Thus, no experimental testing was necessary and the SB8  $\text{SO}_4^{2-}$  limit of 0.65 wt.% was recommended for SB9 processing. This previous SB9 assessment did not address coupled processing with streams from the Salt Waste Processing Facility (SWPF), which is anticipated to start operations in November 2019. These high activity streams will include monosodium titanate (MST) and sludge solids from the Sludge Solids Receipt Tank (SSRT) as well as Cs-containing strip effluent (SE). The incorporation of these SWPF streams is expected to reach  $\text{TiO}_2$  concentrations in glass greater than 2 wt.% based on single and double MST strike scenarios.

In support of coupled operation with SWPF, the DWPF Product Composition Control System was revised and allows a  $\text{TiO}_2$  concentration of up to 6 wt.% (minus measurement uncertainty) in glass. For the SB8-Frit 803  $\text{SO}_4^{2-}$  solubility study, the maximum  $\text{TiO}_2$  concentration evaluated was 0.94 wt.%. Since the influence of increased  $\text{TiO}_2$  on the retention of  $\text{SO}_4^{2-}$  in the SB9 glass region is unknown, a test matrix of ten glass compositions has been proposed to determine whether the 0.65 wt.%  $\text{SO}_4^{2-}$  limit is still appropriate for SB9 coupled operation with SWPF. This report documents the development of a test matrix that will support this study.

## TABLE OF CONTENTS

LIST OF TABLES .....	vii
LIST OF ABBREVIATIONS .....	viii
1.0 Introduction .....	1
2.0 Quality Assurance .....	1
3.0 Glass Selection .....	1
4.0 Recommendation .....	5
5.0 References .....	5

## LIST OF TABLES

Table 3-1. Normalized SB9 Tank 40 Blend Projection .....	2
Table 3-2. SRAT Composition (wt.%) Based on Single and Double MST Strike Scenarios.....	3
Table 3-3. Recommended Glass Compositions (wt.%) for the Sulfate Solubility Study .....	4

## LIST OF ABBREVIATIONS

ARP	Actinide Removal Process
DWPF	Defense Waste Processing Facility
g	gram
L	liter
MAR	Measurement Acceptance Region
MCU	Modular Caustic Side Solvent Extraction Unit
MST	monosodium titanate
PCCS	Product Composition Control System
SB3	Sludge Batch 3
SB4	Sludge Batch 4
SB7b	Sludge Batch 7b
SB8	Sludge Batch 8
SB9	Sludge Batch 9
SE	Strip Effluent
SME	Slurry Mix Evaporator
SMRF	Slurry-Fed Melt Rate Furnace
SRAT	Sludge Receipt and Adjustment Tank
SRNL	Savannah River National Laboratory
SRR	Savannah River Remediation
SS	sludge solids
SSRT	Sludge Solids Receipt Tank
SWPF	Salt Waste Processing Facility
TTR	Technical Task Request
WL	waste loading
wt. %	weight percent



## 1.0 Introduction

To support initial operations at the Defense Waste Processing Facility (DWPF), the original sulfate ( $\text{SO}_4^{2-}$ ) solubility limit for Product Composition Control System (PCCS) Slurry Mix Evaporator (SME) acceptability was defined at 0.4 weight percent (wt.%) in glass based on pilot-scale melter testing.<sup>1-3</sup> This limit signified that 0.4 wt.%  $\text{SO}_4^{2-}$  could be retained in the glass without the formation of a sulfate phase. The utilization of a 0.4 wt.%  $\text{SO}_4^{2-}$  limit in glass for SME acceptability was challenged for Sludge Batch 3 (SB3), which included a Np-based stream projected to contain a significant fraction of ferrous sulfamate.<sup>4</sup> Laboratory-scale crucible testing with both batch chemicals and simulated Sludge Receipt and Adjustment Tank (SRAT) product was performed and a new PCCS SME acceptability limit for  $\text{SO}_4^{2-}$  was established at 0.6 wt.% for SB3, which was confirmed by supplementary Slurry-Fed Melt Rate Furnace (SMRF) testing with simulated SME product.<sup>4</sup> While 0.6 wt.%  $\text{SO}_4^{2-}$  was allowed in the melter feed, it was anticipated that less than 0.6 wt.% would be retained in the glass based on  $\text{SO}_4^{2-}$  volatility during DWPF melter processing, which provides some conservatism with respect to the formation of a sulfate phase. PCCS was not revised to reflect the updated  $\text{SO}_4^{2-}$  limit and DWPF imposed this constraint administratively outside of PCCS.

The 0.6 wt.%  $\text{SO}_4^{2-}$  limit was confirmed for Sludge Batch 4 (SB4) through Sludge Batch 7b (SB7b) by laboratory-scale crucible testing with batch chemicals.<sup>5-10</sup> For Sludge Batch 8 (SB8), the limit was defined at 0.65 wt.%.<sup>11,12</sup> In preparation for SB9 processing, a comparison demonstrated that minor compositional differences existed between the SB8-Frit 803 and SB9-Frit 803 glass composition regions for sludge-only and coupled operations with the Actinide Removal Process (ARP) and Modular Caustic Side Solvent Extraction Unit (MCU).<sup>13</sup> Thus, no experimental testing was necessary and the 0.65 wt.%  $\text{SO}_4^{2-}$  limit was recommended for SB9 processing.

This previous SB9 assessment did not address coupled processing with streams from the Salt Waste Processing Facility (SWPF), which is anticipated to start operations in November 2019. These SWPF streams will include monosodium titanate (MST) and sludge solids from the Sludge Solids Receipt Tank (SSRT) as well as Cs-containing strip effluent (SE). The incorporation of these SWPF streams is expected to reach  $\text{TiO}_2$  concentrations in glass greater than 2 wt.% based on single and double MST strike scenarios.<sup>14</sup>

In support of coupled operation with SWPF, PCCS was revised and allows a  $\text{TiO}_2$  concentration of up to 6 wt.% (minus measurement uncertainty) in glass.<sup>3</sup> For the SB8-Frit 803  $\text{SO}_4^{2-}$  solubility study, the maximum targeted  $\text{TiO}_2$  concentration evaluated was 0.94 wt.%.<sup>11,12</sup> Since the impact of increased  $\text{TiO}_2$  on the retention of  $\text{SO}_4^{2-}$  in the SB9 glass region is unknown, experimental testing has been proposed to determine whether the 0.65 wt.%  $\text{SO}_4^{2-}$  limit is still appropriate for SB9 coupled operation with SWPF. This report documents the development of a test matrix that will support this study.

## 2.0 Quality Assurance

This work was requested via a Technical Task Request (TTR)<sup>15</sup> and directed by a Task Technical and Quality Assurance Plan.<sup>16</sup> The TTR indicated the portion of the work scope covered by this report is classified as Safety Class and not subject to RW-0333P requirements. Requirements for performing reviews of technical reports and the extent of review are established in Manual E7, Procedure 2.60.<sup>17</sup> This document, including all calculations, was reviewed by a Design Check. SRNL documents the extent and type of review using the SRNL Technical Report Design Checklist contained in WSRC-IM-2002-00011.<sup>18</sup>

## 3.0 Glass Selection

Using the SB9 Tank 40 blend projection on a calcine basis received from Savannah River Remediation (SRR),<sup>14</sup> the elemental concentrations were converted to oxides and normalized to 100 wt.% as shown in Table 3-1.

**Table 3-1. Normalized SB9 Tank 40 Blend Projection**

Oxide	Concentration (wt.%)	Oxide	Concentration (wt.%)
Al <sub>2</sub> O <sub>3</sub>	17.50	MnO	9.42
B <sub>2</sub> O <sub>3</sub>	0.06	Na <sub>2</sub> O	24.40
BaO	0.10	NiO	2.02
CaO	1.86	PbO	0.05
Ce <sub>2</sub> O <sub>3</sub>	0.16	SO <sub>4</sub> <sup>2-</sup>	1.02
Cr <sub>2</sub> O <sub>3</sub>	0.15	SiO <sub>2</sub>	3.80
CuO	0.09	ThO <sub>2</sub>	1.25
Fe <sub>2</sub> O <sub>3</sub>	32.11	TiO <sub>2</sub>	0.05
K <sub>2</sub> O	0.13	U <sub>3</sub> O <sub>8</sub>	4.99
La <sub>2</sub> O <sub>3</sub>	0.06	ZnO	0.05
Li <sub>2</sub> O	0.15	ZrO <sub>2</sub>	0.08
MgO	0.50		

Based on the guidance and assumptions provided by SRR,<sup>14,19</sup> SRNL performed subsequent calculations to estimate compositions of SE<sup>20</sup> and the SSRT effluent stream for the following two cases:<sup>21,22</sup>

- Case 1: Single MST strike operation (nominal 0.4 g MST/L of salt solution). This case represents the baseline.
- Case 4: Double MST strike operation (i.e., two sequential contactings of salt solution in SWPF with a nominal 0.4 g MST/L of salt solution in each).

Other pertinent assumptions from SRR-WSE-2018-00025 include:

- 0.7M Na (total Na) wash endpoint for the SSRT stream
- DWPF receives 5700 gallons of sludge slurry from Tank 40 per SRAT batch
- DWPF receives 12,800 gallons of SE per SRAT batch based on the baseline BOBCalixC6 solvent<sup>a</sup>
- DWPF receives 2800 gallons of the SSRT effluent stream (MST and sludge solids (SS)) per SRAT batch for single strike operation and 4200 gallons for double strike operation

Estimates for the composition in the SRAT resulting from the addition of streams from SWPF that represent single and double MST strike scenarios are shown in Table 3-2. Using the compositions in Table 3-2, the SO<sub>4</sub><sup>2-</sup> concentration was fixed at 0.65 wt.% in glass at 32% and 40% waste loading (WL). The TiO<sub>2</sub> concentration was also held constant and the remainder of the oxides in Table 3-2 were renormalized.

Glass compositions were developed using both Frit 803 and Frit 625.<sup>b</sup> Frit 803 was recommended for SB9 coupled operation with ARP-MCU and could be used during initial SWPF startup operations at lower processing rates.<sup>22-24</sup> Frit 625 was recommended for operational flexibility during coupled operation with SWPF at design-basis processing rates.<sup>22</sup>

<sup>a</sup> BOBCalixC6 is calix[4]arene-bis(tert-octylbenzo-crown-6), which uses a nitric acid strip solution.

<sup>b</sup> The composition of Frit 803 is 8B<sub>2</sub>O<sub>3</sub>-6Li<sub>2</sub>O-8Na<sub>2</sub>O-78SiO<sub>2</sub> (wt.%) and the composition of Frit 625 is 1Al<sub>2</sub>O<sub>3</sub>-8B<sub>2</sub>O<sub>3</sub>-7Li<sub>2</sub>O-6Na<sub>2</sub>O-78SiO<sub>2</sub> (wt.%).

An additional glass composition was selected from the variability study to maximize the TiO<sub>2</sub> concentration.<sup>c,22</sup> At 40% WL, the PCCS constraint for maximum TiO<sub>2</sub> concentration failed, which occurs when the TiO<sub>2</sub> concentration in glass is greater than 6 wt.% minus measurement uncertainty. Thus, the WL for this glass was reduced to 38% WL so that the glass composition would pass the PCCS measurement acceptance region (MAR) constraints.

Target compositions for the recommended glass compositions are shown in Table 3-3.

**Table 3-2. SRAT Composition (wt.%) Based on Single and Double MST Strike Scenarios**

	<b>Case #1</b> <b>2800 gallons MST/SS</b> <b>Single MST Strike</b> <b>12,800 gallons SE</b>	<b>Case #4</b> <b>4200 gallons MST/SS</b> <b>Double MST Strike</b> <b>12,800 gallons SE</b>
<b>Al<sub>2</sub>O<sub>3</sub></b>	15.207	13.939
<b>B<sub>2</sub>O<sub>3</sub></b>	0.053	0.048
<b>BaO</b>	0.083	0.075
<b>CaO</b>	1.538	1.386
<b>Ce<sub>2</sub>O<sub>3</sub></b>	0.136	0.122
<b>Cr<sub>2</sub>O<sub>3</sub></b>	0.121	0.109
<b>Cs<sub>2</sub>O</b>	1.564	1.410
<b>CuO</b>	0.072	0.065
<b>Fe<sub>2</sub>O<sub>3</sub></b>	26.594	23.958
<b>K<sub>2</sub>O</b>	0.291	0.288
<b>La<sub>2</sub>O<sub>3</sub></b>	0.048	0.044
<b>Li<sub>2</sub>O</b>	0.125	0.112
<b>MgO</b>	0.411	0.371
<b>MnO</b>	7.803	7.030
<b>Na<sub>2</sub>O</b>	27.669	28.054
<b>NiO</b>	1.673	1.507
<b>PbO</b>	0.045	0.040
<b>SO<sub>4</sub><sup>2-</sup></b>	0.880	0.805
<b>SiO<sub>2</sub></b>	3.148	2.836
<b>ThO<sub>2</sub></b>	1.035	0.932
<b>TiO<sub>2</sub></b>	7.263	13.048
<b>U<sub>3</sub>O<sub>8</sub></b>	4.133	3.724
<b>ZnO</b>	0.041	0.037
<b>ZrO<sub>2</sub></b>	0.067	0.060

<sup>c</sup> The variability study glass identification is SRNL-SB9b-08.

**Table 3-3. Recommended Glass Compositions (wt.%) for the Sulfate Solubility Study**

Glass ID	SB9b-S10	SB9b-S11	SB9b-S12	SB9b-S13	SB9b-S14	SB9b-S15	SB9b-S16	SB9b-S17	SB9b-S18	SB9b-S19
<b>Case</b>	#1	#1	#1	#1	#4	#4	#4	#4	Max TiO <sub>2</sub>	Max TiO <sub>2</sub>
<b>WL</b>	32%	40%	32%	40%	32%	40%	32%	40%	38%	38%
<b>Frit ID</b>	625	625	803	803	625	625	803	803	625	803
<b>Al<sub>2</sub>O<sub>3</sub></b>	5.485	6.633	4.805	6.033	5.077	6.123	4.397	5.523	5.702	5.082
<b>B<sub>2</sub>O<sub>3</sub></b>	5.457	4.821	5.457	4.821	5.455	4.819	5.455	4.819	4.977	4.977
<b>BaO</b>	0.026	0.033	0.026	0.033	0.024	0.030	0.024	0.030	0.027	0.027
<b>CaO</b>	0.486	0.610	0.486	0.610	0.437	0.549	0.437	0.549	0.502	0.502
<b>Ce<sub>2</sub>O<sub>3</sub></b>	0.043	0.054	0.043	0.054	0.039	0.048	0.039	0.048	0.044	0.044
<b>Cr<sub>2</sub>O<sub>3</sub></b>	0.038	0.048	0.038	0.048	0.034	0.043	0.034	0.043	0.039	0.039
<b>Cs<sub>2</sub>O</b>	0.494	0.621	0.494	0.621	0.445	0.559	0.445	0.559	0.560	0.560
<b>CuO</b>	0.023	0.029	0.023	0.029	0.021	0.026	0.021	0.026	0.024	0.024
<b>Fe<sub>2</sub>O<sub>3</sub></b>	8.403	10.551	8.403	10.551	7.557	9.492	7.557	9.492	8.682	8.682
<b>K<sub>2</sub>O</b>	0.092	0.115	0.092	0.115	0.091	0.114	0.091	0.114	0.111	0.111
<b>La<sub>2</sub>O<sub>3</sub></b>	0.015	0.019	0.015	0.019	0.014	0.017	0.014	0.017	0.016	0.016
<b>Li<sub>2</sub>O</b>	4.799	4.249	4.119	3.649	4.795	4.244	4.115	3.644	4.381	3.761
<b>MgO</b>	0.130	0.163	0.130	0.163	0.117	0.147	0.117	0.147	0.134	0.134
<b>MnO</b>	2.466	3.096	2.466	3.096	2.217	2.785	2.217	2.785	2.547	2.547
<b>Na<sub>2</sub>O</b>	12.823	14.578	14.183	15.778	12.930	14.715	14.290	15.915	14.230	15.470
<b>NiO</b>	0.529	0.664	0.529	0.664	0.475	0.597	0.475	0.597	0.546	0.546
<b>PbO</b>	0.014	0.018	0.014	0.018	0.013	0.016	0.013	0.016	0.015	0.015
<b>SO<sub>4</sub><sup>2-</sup></b>	0.650	0.650	0.650	0.650	0.650	0.650	0.650	0.650	0.650	0.650
<b>SiO<sub>2</sub></b>	54.035	48.049	54.035	48.049	53.935	47.924	53.935	47.924	49.388	49.388
<b>ThO<sub>2</sub></b>	0.327	0.411	0.327	0.411	0.294	0.369	0.294	0.369	0.338	0.338
<b>TiO<sub>2</sub></b>	2.324	2.905	2.324	2.905	4.176	5.219	4.176	5.219	5.702	5.702
<b>U<sub>3</sub>O<sub>8</sub></b>	1.306	1.640	1.306	1.640	1.175	1.475	1.175	1.475	1.349	1.349
<b>ZnO</b>	0.013	0.016	0.013	0.016	0.012	0.015	0.012	0.015	0.013	0.013
<b>ZrO<sub>2</sub></b>	0.021	0.027	0.021	0.027	0.019	0.024	0.019	0.024	0.022	0.022

## 4.0 Recommendation

Since the influence of increased  $\text{TiO}_2$  concentrations on the retention of  $\text{SO}_4^{2-}$  in the SB9 glass region is unknown, a test matrix of ten glass compositions has been proposed to determine whether the 0.65 wt.%  $\text{SO}_4^{2-}$  limit is still appropriate for SB9 coupled operation with SWPF.

## 5.0 References

1. D.F. Bickford and C.M. Jantzen, "Inhibitor Limits for Washed Precipitate Based on Glass Quality and Solubility Limits," DPST-86-00546, Rev. 0, 1986.
2. H.L. Hull, "Test Report: Battelle Pacific Northwest Laboratory Slurry-Fed Melter Tests June, August, October 1983," DPST-84-00518, Rev. 0, 1984.
3. T.B. Edwards, "SME Acceptability Determination for DWPF Process Control," Savannah River National Laboratory, Aiken, SC, WSRC-TR-95-00364, Rev. 6, 2017.
4. D.K. Peeler, C.C. Herman, M.E. Smith, T.H. Lorier, D.R. Best, T.B. Edwards, and M.A. Baich, "An Assessment of the Sulfate Solubility Limit for the Frit 418-Sludge Batch 2/3 System," WSRC-TR-2004-00081, Rev. 0, 2004.
5. T.H. Lorier, I.A. Reamer, and R.J. Workman, "Initial Sulfate Solubility Study for Sludge Batch 4 (SB4)," WSRC-TR-2005-00213, Rev. 0, 2005.
6. K.M. Fox, T.B. Edwards, and D.K. Peeler, "Sulfate Retention in High Level Waste (HLW) Sludge Batch 4 Glasses: A Preliminary Assessment," WSRC-STI-2006-00038, Rev. 0, 2006.
7. F.C. Raszewski, D.R. Best, and D.K. Peeler, "An Assessment of the applicability of the 0.6 wt%  $\text{SO}_4^{2-}$  PCCS limit for the Frit 418-SB5 system," Savannah River National Laboratory, Aiken, SC, SRNL-L3100-2008-00023, Rev. 0, September 2008.
8. A.L. Billings, "DWPF Sulfate Limit Verification for SB6," SRNL-STI-2010-00191, Rev. 0, 2010.
9. A.L. Billings, "Sulfate Solubility Limit Verification for DWPF Sludge Batch 7a," SRNL-STI-2011-00197, Rev. 0, 2011.
10. A.L. Billings and K.M. Fox, "Sulfate Solubility Limit Verification for DWPF Sludge Batch 7b," SRNL-STI-2011-00482, Rev. 0, 2011.
11. W.K. Kot and I.L. Pegg, "Determination of Sulfate Solubility Limit for Defense Waste Processing Facility (DWPF) Sludge Batch 8," VSL-13L2580-3, Rev. 0, 2013.
12. W.K. Kot and I.L. Pegg, "Sulfur Solubility Limit Determination for Defense Waste Processing Facility (DWPF) Sludge Batch 8 Glasses," VSL-13L2580-1, Rev. 0, 2013.
13. F.C. Johnson, "Recommendation for the Sludge Batch 9 Sulfate Solubility Limit," Savannah River National Laboratory, Aiken, SC, SRNL-L3100-2016-00044, Rev. 0, 2016.
14. A. Samadi, H.B. Shah, J.D. Ledbetter, J.W. Ray, K.M. Brotherton, R. McNew, and T.L. Fellingner, "Integration of the Defense Waste Processing Facility (DWPF) and Salt Waste Processing Facility

- (SWPF): Assumptions and Guidance to Support Measurement Acceptance Region (MAR) Assessments for Sludge Batch 9 (SB9),” Savannah River Remediation, Aiken, SC, SRR-WSE-2018-00025, Rev. 0, 2018.
15. A. Samadi-Dezfouli, “Variability Study for Sludge Batch 9 Coupled Operation with the Salt Waste Processing Facility,” Savannah River Remediation, Aiken, SC, X-TTR-S-00070, Rev. 0, 2018.
  16. F.C. Johnson, “Task Technical and Quality Assurance Plan for Variability Study for Sludge Batch 9 Coupled Operation with the Salt Waste Processing Facility,” Savannah River National Laboratory, Aiken, SC, SRNL-RP-2018-01085, Rev. 0, 2018.
  17. “Technical Reviews,” Savannah River Site, Aiken, SC, Manual E7, Procedure 2.60, Rev. 17, 2016.
  18. “Savannah River National Laboratory Technical Report Design Check Guidelines,” Westinghouse Savannah River Company, Aiken, SC, WSRC-IM-2002-00011, Rev. 2, 2004.
  19. A. Samadi, J. Windham, L. Jamison, and V. Kmiec, “Integration of the Defense Waste Processing Facility (DWPF) and Salt Waste Processing Facility (SWPF): Assumptions and Guidance to Support Measurement Acceptance Region (MAR) Assessments for Sludge Batch 9 (SB9),” Savannah River Remediation, Aiken, SC, SRR-WSE-2017-00042, Rev. 0, 2017.
  20. M.E. Stone, “Calculation of Inputs for SB9 and SB10 SWPF-Coupled MAR Assessments,” Savannah River National Laboratory, Aiken, SC, SRNL-L3300-2017-00050, Rev. 0, 2017.
  21. M.E. Stone, “SSRT Effluent Composition Estimate for SB9/SB10 MAR Assessments,” Savannah River National Laboratory, Aiken, SC, SRNL-L3300-2018-00063, Rev. 1, 2018.
  22. F.C. Johnson and T.B. Edwards, “Frit Recommendation for Sludge Batch 9 Coupled Operation with the Salt Waste Processing Facility,” Savannah River National Laboratory, Aiken, SC, SRNL-STI-2019-00004, Rev. 0, 2019.
  23. F.C. Johnson, T.B. Edwards, and D.K. Peeler, “Confirmation of Frit 803 for Sludge Batch 9,” Savannah River National Laboratory, Aiken, SC, SRNL-L3100-2015-00155, Rev. 0, 2015.
  24. F.C. Johnson and T.C. Edwards, “Reconfirmation of Frit 803 Based on the January 2016 Sludge Batch 9 Reprojection,” Savannah River National Laboratory, Aiken, SC, SRNL-L3100-2016-00010, Rev. 0, 2016.