## Contract No:

This document was prepared in conjunction with work accomplished under Contract No. DE-AC09-08SR22470 with the U.S. Department of Energy (DOE) Office of Environmental Management (EM).

## **Disclaimer:**

This work was prepared under an agreement with and funded by the U.S. Government. Neither the U.S. Government or its employees, nor any of its contractors, subcontractors or their employees, makes any express or implied:

- 1) warranty or assumes any legal liability for the accuracy, completeness, or for the use or results of such use of any information, product, or process disclosed; or
- 2) representation that such use or results of such use would not infringe privately owned rights; or
- 3) endorsement or recommendation of any specifically identified commercial product, process, or service.

Any views and opinions of authors expressed in this work do not necessarily state or reflect those of the United States Government, or its contractors, or subcontractors.



# Characterization Results for the 2020 Tank Farm 2H and 3H Evaporator Overhead Samples

S. C. Lucatero March 2021 SRNL-STI-2021-00076, Revision 0

SRNL.DOE.GOV

#### DISCLAIMER

This work was prepared under an agreement with and funded by the U.S. Government. Neither the U.S. Government or its employees, nor any of its contractors, subcontractors or their employees, makes any express or implied:

- 1. warranty or assumes any legal liability for the accuracy, completeness, or for the use or results of such use of any information, product, or process disclosed; or
- 2. representation that such use or results of such use would not infringe privately owned rights; or
- 3. endorsement or recommendation of any specifically identified commercial product, process, or service.

Any views and opinions of authors expressed in this work do not necessarily state or reflect those of the United States Government, or its contractors, or subcontractors.

#### Printed in the United States of America

#### Prepared for U.S. Department of Energy

SRNL-STI-2021-00076 Revision, 0

*Keywords: Effluent Treatment Project, WAC limits,* <sup>137</sup>*Cs,* <sup>90</sup>*Sr,* <sup>129</sup>*I.* 

Retention: Permanent

# **Characterization Results for the 2020 Tank Farm 2H and 3H Evaporator Overhead Samples**

S. C. Lucatero

March 2021



OPERATED BY SAVANNAH RIVER NUCLEAR SOLUTIONS

Prepared for the U.S. Department of Energy under contract number DE-AC09-08SR22470.

## **REVIEWS AND APPROVALS**

## AUTHOR:

S. C. Lucatero, Separation Sciences & Engineering

TECHNICAL REVIEWER:

M. S. Hay, Separation Sciences & Engineering

APPROVALS:

B. J. Wiedenman, Manager, Separation Sciences & Engineering

S. D. Fink, Director, Chemical Processing Sciences

P. W. Norris, Manager, Tank Farm Facility Engineering - ETP

## **EXECUTIVE SUMMARY**

The 2020 annual 2H and 3H Evaporator overhead samples were received at Savannah River National Laboratory (SRNL) on December 22, 2020. The delivered samples were analyzed for concentration of cesium-137 (<sup>137</sup>Cs), strontium-90 (<sup>90</sup>Sr) and iodine-129 (<sup>129</sup>I) to validate compliance with the Effluent Treatment Project Waste Acceptance Criteria (ETP WAC, Rev. 7).<sup>1</sup> The concentration of all three radionuclides, <sup>137</sup>Cs, <sup>90</sup>Sr, and <sup>129</sup>I, in the 2H Evaporator overhead sample were found to be less than the corresponding ETP WAC limits. Radiochemical analysis of the 3H Evaporator overhead sample indicated a <sup>137</sup>Cs content about an order of magnitude higher than the acceptable threshold value, and <sup>90</sup>Sr and <sup>129</sup>I concentrations within the acceptance limits.

## TABLE OF CONTENTS

LIST (	LIST OF TABLESvii			
1.0	Introduction1			
2.0	Experimental Procedure			
3.0	Results and Discussion			
3.1	Quality Assurance			
4.0	Conclusions			
5.0	References			
Appendix A. Total mercury and anion determinations of 2H and 3H Evaporator overhead samplesA-1				

## LIST OF TABLES

Table 3-1 Results of radiochemical	analysis of 2H and 3H Evaporator	overhead samples2

## LIST OF ABBREVIATIONS

- ARD Analytical Research and Development
- ELN Electronic Laboratory Notebook
- ETP Effluent Treatment Project
- %RSD percent relative standard deviation
- SRNL Savannah River National Laboratory
- WAC Waste Acceptance Criteria
- WCP Waste Compliance Plan

## **1.0 INTRODUCTION**

The purpose of the H-Tank Farm evaporator system is to reduce the amount of liquid volume (e.g., water) in high-level radioactive waste by means of a boiling process. The vapor phase in the overhead space of evaporators is circulated through a condensation unit and the generated liquid streams are sent to ETP for further decontamination and eventual release. The condensed overhead streams are analyzed for contaminant content, and species exceeding ETP WAC limits<sup>1</sup> are returned to the feed tank and recycled back to the evaporator, as directed per the Waste Compliance Plan (WCP).<sup>2</sup> In fulfilling such regulatory requirements, annual samples of the 2H and 3H Evaporator overhead streams were submitted to SRNL on December 22, 2020, for radiochemical characterization. The concentrations of cesium-137 (<sup>137</sup>Cs), strontium-90 (<sup>90</sup>Sr) and iodine-129 (<sup>129</sup>I) were measured in the as received samples.

## 2.0 EXPERIMENTAL PROCEDURE

The 2H and 3H annual evaporator overhead samples were delivered at E-wing of SRNL on December 22, 2020 in disposable plastic containers. Both samples looked visually clear, although the 3H sample exhibited a slightly stronger yellowish color than the 2H sample, which showed a paler tone. The total volume of each sample was approximately 200 mL. Owing to the relatively low radioactivity of the as received samples, undiluted aliquots were submitted to Analytical Research and Development (ARD) in green shielded bottles for pertinent radiochemical analyses. De-ionized water blank samples were processed in parallel for Quality Assurance purposes and to evaluate potential sample contamination.

The characterization techniques for duplicate analysis of <sup>137</sup>Cs, <sup>90</sup>Sr and <sup>129</sup>I applied are specified in the Task Technical and Quality Assurance Plan for the Annual Overheads Sample Analysis for 2H/3H Evaporators.<sup>3</sup> The <sup>137</sup>Cs concentration in the samples was measured via gamma spectrometry, whereas the <sup>90</sup>Sr (<sup>129</sup>I) content was determined by first undertaking a radiochemical separation followed by liquid scintillation counting (low energy gamma photon spectroscopy).

The density of as received 2H/3H Evaporator overhead samples was determined at 25°C using 2 mL graduated glass vials, which were tare weighed using an analytical balance. Each vial was filled with sample to the 2 mL mark, the weight was then determined by difference and recorded for density calculations. These steps were repeated three times and average values along with percent relative standard deviation (%RSD) calculated afterwards. The density of de-ionized water was also measured using the same procedure.

As per waste disposal requirements for the High Activity Drain and Quality Assurance assessment purposes, the total mercury and anion concentrations were analyzed in the 2H and 3H samples by direct mercury analysis and ion chromatography for anions. Appendix A provides a summary of these results.

## **3.0 RESULTS AND DISCUSSION**

A summary of the analytical results along with the applicable ETP WAC limits for <sup>137</sup>Cs, <sup>90</sup>Sr and <sup>129</sup>I is provided in Table 3-1. The average concentration values listed therein were calculated from duplicate determinations performed by ARD. The percent relative standard deviation (%RSD, defined as [standard deviation / average] \*100) was calculated only for values that were above the detection limits. All three radionuclide concentrations in the 2H Evaporator overhead sample were found to be less than the corresponding ETP WAC limits. However, the 3H Evaporator overhead sample exhibited a <sup>137</sup>Cs content equal to 4.61E+03 dpm/mL (5.0% uncertainty), which exceeded the ETP WAC threshold by approximately an order of magnitude. In addition, there is WAC deviation documentation that has moved the point of compliance and limits for <sup>137</sup>Cs,<sup>8</sup> the measured value also exceeded the deviation limit. The facility has a process that procedurally requires recycling overheads back to the feed tank if the results exceed the WAC. Since it was the case with the concentration of <sup>137</sup>Cs in the 3H Evaporator overhead sample, the facility did confirm the transfer of the overheads tank contents to the feed tank. The concentration of <sup>90</sup>Sr and <sup>129</sup>I in the 3H Evaporator overhead sample fell below the acceptance limits; duplicate analysis indicated a <sup>90</sup>Sr

content above and another below the detection levels; hence, the average value listed in Table 3-1 is preceded by a *less than or equal* sign.

The average <sup>137</sup>Cs concentration in the 2H Evaporator overhead sample was approximately half of the ETP WAC value, 1.58E+02 dpm/mL, and was slightly higher than corresponding values reported in recent annual characterizations: 7.04E+01,<sup>4</sup> 6.97E+01<sup>5</sup> and 9.13E+01<sup>6</sup> dpm/mL. Analytical determinations of both the 2H and 3H Evaporator overhead samples indicated that <sup>90</sup>Sr and <sup>129</sup>I were so low in concentration that they fell below the limits of detection and are therefore reported as values preceded by the *less than* symbol. Previous annual characterizations<sup>5-6</sup> have similarly reported <sup>90</sup>Sr and <sup>129</sup>I contents below the detection limits in 2H Evaporator overhead samples. Table 3-1 also includes radionuclide concentrations measured in deionized water blank samples, which all, <sup>137</sup>Cs, <sup>90</sup>Sr and <sup>129</sup>I, were found to be less than the minimum detectable concentrations.

Analyte	2H Evaporator overhead sample (dpm/mL) (%RSD)	3H Evaporator overhead sample (dpm/mL) (%RSD)	De-ionized water sample (dpm/mL)	ETP WAC limits (dpm/mL) <sup>7</sup>
<sup>137</sup> Cs	1.58E+02 (0.45)	4.61E+03(0.00) <sup>a</sup>	<2.64E+00 <sup>b</sup>	3.28E+02 (1.3E+03 <sup>8</sup> )
<sup>90</sup> Sr	<9.49E+00 <sup>b</sup>	$\leq 8.43 E + 00^{b}$	<7.86E+00 <sup>b</sup>	1.76E+02
<sup>129</sup> I	<2.32E-01 <sup>b</sup>	<1.59E-01 <sup>b</sup>	<2.09E-01 <sup>b</sup>	1.00E+00

Table 3-1 Results of radiochemical analysis of 2H and 3H Evaporator overhead samples.

<sup>a</sup>Results of duplicate analysis were identical. <sup>b0</sup>/<sub>8</sub>RSD not applicable.

The density of the 2H and 3H Evaporator overhead samples was closely comparable, 0.992 (%RSD = 0.23%) and 0.997 gr/mL (%RSD = 0.15%), respectively, whereas the measured density of de-ionized water was 1.002 g/mL (%RSD = 0.20%).

## 3.1 <u>Quality Assurance</u>

This report was developed in accordance with the protocols identified in Task Technical and Quality Assurance Plan SRNL-RP-2021-00045.<sup>3</sup> Requirements for performing reviews of technical reports and the extent of review are established in manual the E7 Manual, Procedure 2.60. SRNL documents the extent and type of review using the SRNL Technical Report Design Checklist contained in WSRC-IM-2002-00011, Rev. 2. This review and all the work meets or exceeds the acceptable criteria to comply with the Technical Task Request<sup>7</sup> requesting this work with a functional classification of Production Support. The data from the experiments entailed herein is contained in an Electronic Laboratory Notebook (ELN).<sup>9</sup>

## 4.0 CONCLUSIONS

Characterization results of the 2020 annual overhead samples for 2H and 3H Evaporators summarized in this report compare the radionuclide contents between the as received samples and the ETP WAC limits. The concentration of <sup>137</sup>Cs, <sup>90</sup>Sr, and <sup>129</sup>I in the 2H Evaporator overhead sample exhibited compliance with the ETP WAC. Radiochemical analysis of the 3H Evaporator overhead sample indicated a <sup>137</sup>Cs content about an order of magnitude higher than the acceptable threshold value, and concentrations of <sup>90</sup>Sr and <sup>129</sup>I within the acceptance limits. The radionuclide concentrations measured in these samples were comparable to those reported in previous annual characterizations, except the <sup>137</sup>Cs content of the 3H sample, which exceeded the ETP WAC limit.

## 5.0 REFERENCES

- 1. "F/H Effluent Treatment Facility Waste Acceptance Criteria," X-SD-H-00009, Revision 7, December 16, 2020.
- 2. S. Campbell, "F/H Tank Farms Waste Compliance Plan for Transfers to the Effluent Treatment Project," X-WCP-H-00013, Revision 8, June 8, 2016.
- 3. S. C. Lucatero, "Task Technical and Quality Assurance Plan for the Annual Overheads Sample Analysis for 2H/3H Evaporators," SRNL-RP-2021-00045, Rev. 0, February 2021.
- 4. Nicholson, J. C., "Characterization Results for the March 2016 H-Tank Farm 2H Evaporator Overhead Samples," SRNL-STI-2016-00253, Rev. 1, September 2016.
- 5. T. T. Truong, "Characterization Results for the January 2017 H-Tank Farm 2H Evaporator Overhead Sample", SRNL-STI-2017-00166, Rev. 0, April 10, 2017.
- 6. A. L. Washington, "Characterization Results for the July 2018 H-Tank Farm 2H Evaporator Overhead Samples," SRNL-STI-2019-00069, February 2019.
- 7. P. W. Norris, "2020 Annual Overhead Samples Analysis for 2H/3H Evaporator Overhead Samples," X-TTR-H-00115, Rev. 0, 12/22/2020.
- 8. "Request for Deviation to ETP Waste Acceptance Criteria," X-WDEV-H-00010, Revision 0, December 9, 2020.
- 9. S. C. Lucatero, Radiochemical Analysis of 2H/3H Evaporator Overheads, K7753-00481-01, SRNL E-Notebook (Production), Savannah River National Laboratory, February 2021.

	2H Evaporator overhead sample (one sigma % uncertainty)	3H Evaporator overhead sample (one sigma % uncertainty)
Total mercury, mg/L	1.867 (10)	12.742 (10)
Fluoride, F <sup>-1</sup> , μg/mL	<5 (10)	<5 (10)
Formate, CHO <sub>2</sub> <sup>-1</sup> , µg/mL	<5 (10)	<5 (10)
Chloride, Cl <sup>-1</sup> , µg/mL	<5 (10)	<5 (10)
Nitrite, $NO_2^{-1}$ , $\mu g/mL$	<5 (10)	<5 (10)
Nitrate, NO <sub>3</sub> <sup>-1</sup> , µg/mL	<5 (10)	<5 (10)
Phosphate, PO <sub>4</sub> - <sup>3</sup> , µg/mL	<5 (10)	<5 (10)
Sulfate, SO4 <sup>-2</sup> , µg/mL	<5 (10)	<5 (10)
oxalate, $C_2O_4^{-2}$ , $\mu g/mL$	<5 (10)	<5 (10)
Bromide, Br <sup>-1</sup> , µg/mL	<50 (10)	<50 (10)

## Appendix A. Total mercury and anion determinations of 2H and 3H Evaporator overhead samples.

### **DISTRIBUTION LIST**

cj.bannochie@srnl.doe.gov alex.cozzi@srnl.doe.gov samuel.fink@srnl.doe.gov brenda.garcia-diaz@srnl.doe.gov connie.herman@srnl.doe.gov dennis.jackson@srnl.doe.gov brady.lee@srnl.doe.gov joseph.manna@srnl.doe.gov daniel.mccabe@srnl.doe.gov gregg.morgan@srnl.doe.gov frank.pennebaker@srnl.doe.gov william.ramsey@srnl.doe.gov eric.skidmore@srnl.doe.gov michael.stone@srnl.doe.gov boyd.wiedenman@srnl.doe.gov jocelyn.lampert@srnl.doe.gov mary.whitehead@srnl.doe.gov michael.hay@srnl.doe.gov savidra.lucatero@srnl.doe.gov jeffrey.crenshaw@srs.gov james.folk@srs.gov roberto.gonzalez@srs.gov tony.polk@srs.gov patricia.suggs@srs.gov david02martin@srs.gov celia.aponte@srs.gov kenneth.wells@srs.gov timothy.baughman@srs.gov richard.edwards@srs.gov thomas.huff@srs.gov ryan.mcnew@srs.gov phillip.norris@srs.gov christine.ridgeway@srs.gov azadeh.samadi-dezfouli@srs.gov christie.sudduth@srs.gov vijay.jain@srs.gov arthur.wiggins@srs.gov Records Administration (EDWS)