Contract No:

This document was prepared in conjunction with work accomplished under Contract No. 89303321CEM000080 with the U.S. Department of Energy (DOE) Office of Environmental Management (EM).

Disclaimer:

This work was prepared under an agreement with and funded by the U.S. Government. Neither the U.S. Government or its employees, nor any of its contractors, subcontractors or their employees, makes any express or implied:

- 1) warranty or assumes any legal liability for the accuracy, completeness, or for the use or results of such use of any information, product, or process disclosed; or
- 2) representation that such use or results of such use would not infringe privately owned rights; or
- endorsement or recommendation of any specifically identified commercial product, process, or service.

Any views and opinions of authors expressed in this work do not necessarily state or reflect those of the United States Government, or its contractors, or subcontractors.



A U.S. DEPARTMENT OF ENERGY NATIONAL LAB • SAVANNAH RIVER SITE • AIKEN, SC • USA

Characterization of Infrequent Samples from the Concentration, Storage, and Transfer Facility: Leak Detection Box (LDB) Drain Cell Sample: August 04, 2022 Sample

J. R. Dekarske

September 2022 SRNL-STI-2022-00403, Revision 0

DISCLAIMER

This work was prepared under an agreement with and funded by the U.S. Government. Neither the U.S. Government or its employees, nor any of its contractors, subcontractors or their employees, makes any express or implied:

- 1. warranty or assumes any legal liability for the accuracy, completeness, or for the use or results of such use of any information, product, or process disclosed; or
- 2. representation that such use or results of such use would not infringe privately owned rights; or
- 3. endorsement or recommendation of any specifically identified commercial product, process, or service.

Any views and opinions of authors expressed in this work do not necessarily state or reflect those of the United States Government, or its contractors, or subcontractors.

Printed in the United States of America

Prepared for U.S. Department of Energy

Keywords: Tank Farm

Retention: Permanent

Characterization of Infrequent Samples from the Concentration, Storage, and Transfer Facility: Leak Detection Box (LDB) Drain Cell Sample: August 04, 2022 Sample

J. R. Dekarske

September 2022



ACKNOWLEDGEMENTS

The author acknowledges assistance in the completion of sample transfers and handling tasks by Scott McDonald and the completion of sample analyses tasks by David DiPrete and Sonia Dyer.

EXECUTIVE SUMMARY

Savannah River Mission Completion Engineering (SRMC-E) requested that the Savannah River National Laboratory (SRNL) analyze the Concentration, Storage, and Transfer Facility (CSTF) samples from the following Tank Farm areas: the sump encasement, catch tank, drain cell, and waste tank annulus. In general, these CSTF samples will be analyzed on an infrequent basis and analyses will include detection for total beta/gamma activities, total alpha activity, free hydroxide, and pH measurements.

This report presents characterization results for the leak detection box (LDB) August 04, 2022 drain cell sample. The sample was clear and colorless with no visible particulates. The results are measurements for total gamma, total alpha, total beta, free hydroxide, and pH.

These analyses were performed in triplicate. A summary of the average analytical results for the LDB sample includes the following.

The directly measured pH for the LDB August 04, 2022 "as-received" drain cell sample range was 7.16-7.88, and the free hydroxide concentration was <0.01 M. The total alpha activity for the LDB August 04, 2022 sample is reported as a less than value (MDA) either because of possible spectral interferences or because there is not much alpha activity in the sample. Thus, the total alpha activity averaged <5.17E+02 dpm/mL. This value is less than 4.83E+03 dpm/mL, which is the procedural limit for non-waste determination.

The total beta activity in the LDB August 04, 2022 drain cell sample is above the instrument detection limits and averaged 4.88E+04 dpm/mL. The beta activity of the sample is mostly from Cs-137 which is evidenced by the cesium removed beta activity being two orders of magnitude lower than the total beta activity.

The average measured cesium-137 activity (dominant beta emitter) in the LDB August 04, 2022 drain cell sample is 4.16E+04 dpm/mL, which is slightly lower than the total beta activity. The corresponding Ba-137m (dominant gamma emitter) activity, calculated as 94.6% of the Cs-137 values, is 3.94E+04 dpm/mL.

The total empirical activity of the beta and gamma emitting (represented by the sum of total beta and Ba-137m activities) averaged 8.82E+04 dpm/mL. This value is less than 8.69E+05 dpm/mL, which is the procedural limit for non-waste determination.

TABLE OF CONTENTS

LIST OF TABLES	viii
LIST OF FIGURES	viii
LIST OF ABBREVIATIONS	ix
1.0 Introduction	1
2.0 Experimental Procedure	1
2.1 Quality Assurance	1
3.0 Results and Discussion	1
4.0 Conclusions	3
5.0 References	3

LIST OF TABLES

Table 3-1. Results for August 04, 2022 LDB drain cell sample: Total Alpha, Total Beta, scan, pH, and Free Hydroxide.	
LIST OF FIGURES	
Figure 3-1. Photograph of the LDB drain cell Sample in Plastic Bottle	2

LIST OF ABBREVIATIONS

CSTF Concentration, Storage and Transfer Facility

LDB Leak Detection Box

LSC Liquid Scintillation Counting
MDA Minimum Detectable Activity

ND Not Detected

PMP Polymethyl pentene

SRNL Savannah River National Laboratory

SRMC-E Savannah River Mission Completion-Engineering

TTQAP Task Technical and Quality Assurance Plan

TTR Technical Task Request

ix

1.0 Introduction

On occasion, Savannah River Mission Completion Engineering (SRMC-E) will request Savannah River National Laboratory (SRNL) to perform analysis on Concentration, Storage, and Transfer Facility (CSTF) samples originating from the sump encasement, catch tank, drain cell, or waste tank annulus per the Technical Task Request (TTR) or email. In August 2022, SRMC-E sent SRNL a sample identified as LDB from a leak detection box. Following the specified TTRⁱⁱ, Task Technical and Quality Assurance Plan (TTQAP)ⁱⁱⁱ, and updated request by SRMC-E through email, SRNL tested the sample for Total Alpha and Total Beta by liquid scintillation counting (LSC), Cs-137 by Gamma scan, free hydroxide, and pH.

2.0 Experimental Procedure

The leak detection box (LDB) drain cell sample was received on August 04, 2022 at SRNL. As the "asreceived" sample radiation dose rate was Not Detected (ND) mrem/hr extremity and skin and whole body, the container was moved to a radiological hood for inspection. Less than 100 mL of sample was collected from the stainless-steel receipt vessel and was transferred into a clear polymethyl pentene (PMP) bottle for visual inspection. iv

The sample appearance was clear and colorless with no visible particulates. The sample was not filtered. Aliquots of the sample were directly transferred into shielded bottles and submitted in triplicate preparations each for total gamma/beta/alpha, free hydroxide, and pH analyses by direct measurement using a pH probe. The remaining sample was stored in a plastic bottle.

2.1 Quality Assurance

Requirements for performing reviews of technical reports and the extent of review are established in manual E7 2.60°. SRNL documents the extent and type of review using the SRNL Technical Report Design Checklist contained in WSRC-IM-2002-00011, Rev. 2°. This review, a design verification done by document review, meets the acceptance criteria to comply with the TTRⁱⁱ requesting this work with a functional classification of Safety Class and per guidance in the TTQAP.ⁱⁱⁱ Data are recorded in the electronic laboratory notebook system as Experiment ID M0869-00537-12.

3.0 Results and Discussion

A photograph of the LDB drain cell sample is provided in Figure 3-1. Separate samples were submitted in triplicate for analysis by each of the following methods: 1) radiochemical analysis (total gamma, beta, and Cs-removed beta and alpha), 2) free hydroxide, and 3) pH. Results are provided in Table 3-1.




Figure 3-1. Photograph of the LDB drain cell Sample in Plastic Bottle

Table 3-1. Results for August 04, 2022 LDB drain cell sample: Total Alpha, Total Beta, Total Gamma scan, pH, and Free Hydroxide.

Test	Replicate 1	Replicate 2	Replicate 3	Average	%RSD
Total Alpha (dpm/mL)	*<4.74E02	*<5.17E02	*<4.77E02	*<5.17E02	N/A
(one sigma %uncertainty)	(MDA)	(MDA)	(MDA)	(MDA)	IN/A
Cs-Removed Alpha (dpm/mL)	*<1.76E02	*<1.71E02	*<1.76E02	*<1.76E02	N/A
(one sigma % uncertainty)	(MDA)	(MDA)	(MDA)	(MDA)	N/A
Total Beta (dpm/mL)	4.86E04	4.88E04	4.89E04	4.88E04	0.31
(one sigma % uncertainty)	(11%)	(11%)	(11%)	4.00EU4	0.31
Cs-Removed Beta (dpm/mL)	1.07E03	1.55E03	1.31E03	1.31E03	18.32
(one sigma % uncertainty)	(25%)	(21%)	(22%)	1.51E05	10.32
Cs-137 (dpm/mL)	4.15E04	4.18E04	4.16E04	4.16E04	0.37
(one sigma % uncertainty)	(5.00%)	(5.00%)	(5.00%)	4.10E04	0.57
**Ba-137m (dpm/mL)	3.93E04	3.95E04	3.94E04	3.94E04	0.37
**Sum of Total Beta and Ba-137m	8.79E04	8.83E04	8.83E04	8.82E04	0.29
(dpm/mL)	0.77L04	0.03L04	0.03L04	0.02L04	0.27
pН	7.88	7.35	7.16	***Range: 7.16-7.88	N/A
(one sigma uncertainty)	(10%)	(10%)	(10%)	Kange. 7.10-7.00	1 V / / A
Free Hydroxide (M)	< 0.01	< 0.01	< 0.01	< 0.01	N/A
(one sigma uncertainty)	(10%)	(10%)	(10%)	~0.01	

^{*}Note: Results were below detectable limit for quantification by method, therefore result is the minimum detectable activity based on sensitivity of the analysis method. Thus, the average value reported is the highest "<" result. All one sigma % uncertainties are as reported with the analytical methods. **Note: Ba-137m activity is calculated as 94.6% of the Cs-137 value. ***Note: pH given as a range as it cannot be averaged as a logarithm.

4.0 Conclusions

The LDB drain cell sample characterization indicated low to moderate gamma and beta activity in the sample and no measurable alpha activity/Cs-removed alpha activity. The pH range was 7.16-7.88, and the free hydroxide was <0.01 M. Total alpha (<5.17E02 dpm/mL) and total beta/gamma activities (8.82E04 dpm/mL) are less than the respective values of 4.83E+03 dpm/ml and 8.69E+05 dpm/mL for non-waste determination.

5.0 References

_

ⁱ "Tank Farm Transfer Control Program, Pump Tank Transfer Jet Control Program, and Waste Tank Chemical Cleaning Program", WSRC-TR-2002-00403, Rev. 33, August 2021

ii Technical Task Request, "Infrequent CSTF Samples", X-TTR-H-0101, Rev. 1, June 2021.

iii L. N. Oji, S. C. Lucatero, "Task Technical and Quality Assurance Plan for the Analysis of Infrequent Samples from the Concentration, Storage, and Transfer Facility", SRNL-RP-2020-00565, Rev.1, July 2021.

iv J. R. Dekarske: ELN: M0869-00537-12 (Electronic Notebook (Production)); SRNL, Aiken, SC 29808 (2022).

v "Technical Reviews," E7 Manual, Procedure 2.60, Rev. 18, 2019.

vi "Savannah River National Laboratory Technical Report Design Check Guidelines", WSRC-IM-2002-00011, Rev.2, 2004.

Distribution:

Cj.bannochie@srnl.doe.gov

William.bates@srnl.doe.gov

marion.cofer@srnl.doe.gov

alex.cozzi@srnl.doe.gov

connie.herman@srnl.doe.gov

brady.lee@srnl.doe.gov

Joseph.Manna@srnl.doe.gov

Gregg.Morgan@srnl.doe.gov

frank.pennebaker@srnl.doe.gov

William.Ramsey@srnl.doe.gov

Marissa.Reigel@srnl.doe.gov

eric.skidmore@srnl.doe.gov

michael.stone@srnl.doe.gov

william.swift@srnl.doe.gov

Boyd.Wiedenman@srnl.doe.gov

bill.clark@srs.gov

jeffrey.crenshaw@srs.gov

james.folk@srs.gov

Curtis.Gardner@srs.gov

timothy.littleton@srs.gov

Anna.Murphy@srs.gov

tony.polk@srs.gov

Anthony.Robinson@srs.gov

mark-a.smith@srs.gov

patricia.suggs@srs.gov

thomas.temple@srs.gov

celia.aponte@srs.gov

timothy.baughman@srs.gov

Azikiwe.hooker@srs.gov

Ryan.McNew@srs.gov

phillip.norris@srs.gov

Azadeh.Samadi-Dezfouli@srs.gov

Vijay.Jain@srs.gov

Bruce.wiersma@srnl.doe.gov

Keisha.martin@srs.gov

Matthew.Hoffman@srs.gov

Collins.Geter@srs.gov

Nilesh.Amin@srs.gov

Brady.Speight@srs.gov

Kevin.O'connor@srs.gov

Records Administration (EDWS)