

APT Cooling Water Supply Make-up Trade Study, Revision 1

by

R. W. Reynolds

Westinghouse Savannah River Company

Savannah River Site

Aiken, South Carolina 29808

R. Hink

RECORDS ADMINISTRATION



ABTH

A document prepared for PUBLIC READING ROOM - ACCELERATOR PRODUCTION OF TRITIUM
ENVIRONMENTAL IMPACT STATEMENT REFERENCES at , , from - .

DOE Contract No. **DE-AC09-96SR18500**

This paper was prepared in connection with work done under the above contract number with the U. S. Department of Energy. By acceptance of this paper, the publisher and/or recipient acknowledges the U. S. Government's right to retain a nonexclusive, royalty-free license in and to any copyright covering this paper, along with the right to reproduce and to authorize others to reproduce all or part of the copyrighted paper.

DISCLAIMER

This report was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency thereof, nor any of their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof.

This report has been reproduced directly from the best available copy.

Available to DOE and DOE contractors from the Office of Scientific and Technical Information, P.O. Box 62, Oak Ridge, TN 37831; prices available from (615) 576-8401.

Available to the public from the National Technical Information Service, U.S. Department of Commerce, 5285 Port Royal Road, Springfield, VA 22161.

APT

Cooling Water Supply Make-up

Trade Study

Revision (1)

August 8, 1996

APT Cooling Water Supply/Make-up Trade Study

Revision (1)

Date: August 8, 1996

Prepared By: Accelerator Production of Tritium, Balance of
Plant, Conceptual Design Plant Systems Team
(Steve Cruz/Ron Hink)


DOES NOT CONTAIN
UNCLASSIFIED CONTROLLED
NUCLEAR INFORMATION

Reviewing
Officer:



PRINCIPAL ENGR

Date: 12 AUG 1996

Approved By :  8/8/96
C. G. Kan

APT Cooling Water Supply/Make-up Trade Study

1.0 Objectives:

In the conceptual design of the APT cooling water system, several options exist for the design of the system(s) which serve as the ultimate heat sink. There are basically two approaches which are being considered for APT. The first approach involves the use of cooling towers at the APT site and providing makeup water to account for evaporative losses and blowdown. The second approach involves the use of heat exchangers at the APT and a larger water supply to remove the heat from the heat exchangers and transfer it directly to the ultimate heat sink, the Savannah River via PAR pond or the atmosphere through the K Area natural draft cooling tower.

It is not cost effective or desirable to proceed with the conceptual design without identifying specifically how the heat is to be removed from APT and transmitted to an ultimate heat sink. Thus, this trade study will evaluate several variations of the above methodologies.

2.0 Scope:

This study will evaluate alternative methods of providing an ultimate heat sink to the APT. Specifically, either cooling towers with a source of makeup water, or a once through river water cooling system utilizing PAR pond for the heated effluent will be evaluated. This study will consider APT sites #2 and #8 currently being evaluated for selection (Reference attachment 9.4). All cost and technical discussion is based on Site#2 with a discussion of the relation to Site #8 provided in Section 6.0. Utilization of cooling towers at the APT site and a supply of makeup water from the River Water system (identified as Alternative 1 herein) is the basis for the APT CDR estimate, therefore, it will be the base case for this study. Thus, no cost is presented for Alternative #1, and the other alternatives present a cost delta relative to the base cost.

All alternatives will include the structures and equipment that form the portion of the heat removal system that extends from the cooling or makeup water source through the tertiary cooling loops to the APT secondary cooling loops up to the primary heat exchangers or chillers. Piping costs are included up to the general location of APT. The general intra-area pipe routing is considered equivalent for all options. Blowdown is considered in every case. The cost differential between each alternative's control system is not considered significant and therefore has not been included in this evaluation. Additionally, none of the alternatives include surge tanks for flow control. Although it is probable that additional provisions for flow control will be required, this requirement would effect all alternatives and is not considered in this evaluation.

APT Cooling Water Supply/Make-up Trade Study

All alternatives will utilize existing SRS systems and structures where possible. Specific assumptions related to each alternative are identified in Section 5.0. This study will rank all alternatives on direct equipment costs, operating and maintenance costs, and permitting risks.

3.0 Alternatives:

Several alternative methods of providing the process cooling water are described as follows:

1. River Water Makeup: Supply makeup water from the existing river water system (originally used to supply cooling water makeup to the reactors) to the APT mechanical draft cooling towers. Heated effluent is discharged to the atmosphere and continuous blowdown is directed to PAR Pond.
2. River Water Once Through: Provide heat exchangers at the APT site with cooling water supplied from the existing river water system using either the 681-1G or 681-3G pump house. Heated effluent and continuous blowdown is directed to PAR Pond.
3. Well Field Makeup: Supply makeup water from a new well field to APT mechanical draft cooling towers. Heated effluent is discharged to the atmosphere and continuous blowdown is directed to PAR Pond.
4. K Area Cooling Tower: Use the K Area cooling tower to remove heat from the cooling water. This alternative makes use of portions of the existing river water system in order to minimize new runs of large diameter concrete pipe. Heated effluent is discharged to the atmosphere and continuous blowdown is directed to the K-area outfall.

All alternatives have been simplified to focus on the primary cost drivers. A judicious effort has been made to maintain a fair comparison between each alternative.

Several variations on the above alternatives exist, and were not specifically evaluated. These include:

- * Supply cooling water to the APT heat exchangers from the existing river water system using 681-6G pump house at PAR pond. This option was not evaluated due to the fact that the 681-6G pump house has not been maintained, and thus the equipment condition was suspect. The cost and feasibility associated with this option is essentially identical to Alternative 2 above. The primary difference would be the additional cost in restoring the

APT Cooling Water Supply/Make-up Trade Study

pump house, and the lower operating cost due to lower horse power pumps.

- * Make use of a new cooling pond to remove heat from the APT heat exchangers. This option was not evaluated due to the fact that preliminary estimates of the retention pond size indicated that the pond would have to be extremely large to remove the required heat. Thus, this option was not considered technically feasible.
- * A once through cooling system utilizing well water supply. This alternative is not considered feasible as the number of wells required to meet the demand would be cost prohibitive and the permitting risk associated with this production rate was considered to be extremely high.

These alternatives cover the most common and frequently used types of systems. Other alternatives or variations may exist, but were not considered in this report.

4.0 Basis for Evaluation and Selection:

Alternatives are evaluated on technical feasibility, direct capital costs, operating and maintainability costs, and permitting risks. Technical feasibility is evaluated on a go/no go basis, and all of the alternatives evaluated herein are technically feasible in that they can provide the required cooling given that the proper equipment (either new or modified) is in place. The remaining criteria will be assigned a numerical value or score based on a performance scale of 0 to 5 such that 3 is the rating of the base alternative (Alternative 2) with higher numbers increasingly better than the base and lower numbers increasingly worse. For the purpose of this study the criteria were weighted as: direct capital cost - 20%, operating and maintainability costs - 30%, and permitting risk - 50%.

5.0 Evaluation of Alternatives for APT Site #2:

5.1 River Water Makeup (Alternative #1)


Description of System:

This scenario relies on mechanical draft cooling towers as the primary means of transferring heat from APT to the atmosphere. Makeup water is required to account for evaporative losses and continuous blowdown. Preliminary calculations indicate that approximately 6000 gpm of makeup water will satisfy the peak demand for APT. This 6000 gpm could be supplied using a portion of the existing river water system. The modified system would consist of 2 replacement pumps (one is utilized as a spare) in

APT Cooling Water Supply/Make-up Trade Study

either the 681-1G or the 681-3G pump house, use of the existing "R-Normal" river water header, and the addition of approximately 18,000 ft of 18" PVC pipe. Additionally, approximately 24,000 ft of 10" PVC pipe would be required along with pumps for continuous blowdown to PAR pond. Figure 1 shows a rough schematic of the proposed system.

Figure 1: 6000 gpm Makeup from RWS



The specific equipment and modifications required for this alternative include:

- Remove 2 existing RWS pumps in the 681-1-G or 681-3G pump house.
- Add two 12" Schedule 40 carbon steel pump suction lines, each with a 12" suction isolation gate valve.
- Add 2 new and smaller river water centrifugal pumps (one to be utilized as a spare). These pumps should be rated at 6000 gpm @ 420 ft TDH.
- Add two 10" Schedule 40 carbon steel pump discharge lines, each with a 10" check valve and a 10" discharge isolation gate valve, and a tie in to the existing 66" header in 681-1-G.
- Add 18" carbon steel tie in connection to existing 84" RWS header between C Area and H Area including an 18" isolation gate valve.
- Add 18,000 ft of 18" PVC pipe - bell and spigot type.
- Add 18" carbon steel line to connect to the APT cooling tower. The line should include an 18" isolation gate valve as well as a flow control valves at the APT site cooling towers.
- Add 24,000 ft of 10" PVC pipe - bell and spigot type and pumps for continuous blowdown to PAR Pond.

APT Cooling Water Supply/Make-up Trade Study

Significant Assumptions:

- It is assumed that the existing outfall structure at PAR pond may be utilized. Site Services Engineering has indicated that the outfall is in good condition, and was sized to handle in excess of 200,000 gpm.
- The piping lengths are based on a rough straight line estimate from the river water system to the APT site.
- The existing river water intake structure can be permitted for use by APT.
- It is assumed that the cooling tower basins have adequate inlet surge capacity for system flow stability. No additional cooling water capacity is provided for pump start-up or other system operational transients.
- One spare supply header pump has been considered sufficient to maintain the required system operability requirements. Additional pumps may be required but were not considered in this evaluation.

Advantages:

This type of system is very common and provides a stable and predictable source of makeup water.

The existing river water system is permitted to remove significantly more water than the 6000 gpm required for makeup to APT, and the ability to outfall to PAR pond has been evaluated and found acceptable in Reference 9.2. Also, the required equipment is common and should be readily available.

Disadvantages:

A possible disadvantage of this system is that the existing river water system is beyond its original design life, and to continue to rely on the integrity of the piping and components could be a concern. However, this has been addressed in Reference 9.1 (River Water System Shutdown: Lay-up Requirements (U), EFR-ENG-950067) which concluded that the river water system is in exceptional condition and should be usable for many years to come. The only real disadvantage of this system is that there is a potential for stagnation or biological fouling problems to result from the very low water velocity in the large river water pipes. This results from the fact that the existing river water system was designed for flows on the order of 150,000 gpm. There is only limited experience to predict how the pipe will respond to the very low flows required by APT. The fouling may be eliminated by chemical treatment at the river water pump house.

(

1

1

1

1

1

1

APT Cooling Water Supply/Make-up Trade Study

The specific equipment and modifications required for this alternative include:

- Add approximately 18,000 linear ft of 128" internal diameter concrete pipe rated at roughly 80 psig to connect from "R Normal Header" to APT Site #2. This line should include 2 isolation valves (one at either end).
- Add four 42" Schedule 10 carbon steel pump suction lines, each with a 42" suction isolation gate valve.
- Add four new pumps rated at 50,000 gpm at 80 ft TDH.
- Add four 36" Schedule 10 carbon steel pump discharge lines, each with a 36" check valve and a 36" discharge isolation gate valve.
- Add approximately 24,000 linear ft of 100" internal diameter concrete pipe rated at 80 psig to connect APT Site #2 to Pond 2 which will outfall into PAR Pond. This line should include 2 isolation valves (one at either end).
- Eliminate the cooling station cooling towers.
- Replace the existing primary heat exchangers with heat exchangers designed for the once through cooling system operation.

Significant Assumptions:

- It is assumed that the use of the existing outfall structure at PAR pond may be utilized. Site Services Engineering has indicated that the outfall is in good condition, and was sized to handle in excess of 200,000 gpm.
- The piping lengths are based on a rough straight line estimate from the river water system to the APT site.
- It is assumed that the river water system may be operated close to its design capacity for the life of the APT. This may be possible given the good condition of the pipe as reported in Reference 9.1.
- It is assumed that the existing river water pumps can produce sufficient head to supply the flow requirements of APT. Significant head loss can be expected in the existing river water lines and the new lines to APT. Detailed head loss data for the existing lines is not available, and this may affect the usability of the river water pumps though some margin appears to exist based on preliminary analysis.

APT Cooling Water Supply/Make-up Trade Study

- It is assumed that no inlet flow surge capacity is required for system flow stability. No additional cooling water capacity is provided for pump start-up or other system operational transients. Proper system control may require the addition of a surge tank but these costs have not been included in this evaluation.
- One spare supply header pump has been considered sufficient to maintain the required system operability requirements. Additional pumps may be required but were not considered in this evaluation.
- The control system required by this alternative is assumed to be of equivalent cost and complexity to other alternatives being evaluated. This system, in fact, may require a more complex control system due to the complexity and size of the pumping system.
- The once through heat exchangers are assumed to be of equal cost when compared to the base case primary heat exchangers. Further analysis is required to determine the actual surface area and flow rates required. This assumptions should provide a reasonable basis for order of magnitude cost comparisons.

Advantages:

This type of system also is very common and provides a very stable and predictable source of makeup water.

The existing river water system is permitted to remove significantly more water than the 125,000 gpm required for APT, and the ability to outfall to PAR pond has been evaluated and found acceptable in Reference 9.2.

Disadvantages:

A possible disadvantage of this system is that the existing river water system is beyond its original design life, and to continue to rely on the integrity of the pumps, piping, and components could be a concern. However, this has been addressed in Reference 9.1 (River Water System Shutdown: Lay-up Requirements (U), EFR-ENG-950067) which concluded that the river water system is in exceptional condition and should be usable for many years to come. One real disadvantage of this system is that it requires special order equipment such as very large diameter pipe, large pumps, and many large heat exchangers. There is also a substantial and difficult installation associated with the long runs of large diameter pipe. Additionally, the electrical power requirements are large due to the energy required to move 125,000 gpm from the river to the APT site (~ 10MW).

APT Cooling Water Supply/Make-up Trade Study

It is not certain at this time how favorable this option is for SCDHEC permitting. Should the intake structure require a new permit, the facility may also be required to upgrade to new design standards.

Cost:

The additional capital cost of the above described modifications and additions relative to Alternative 1 has been estimated at \$21.2M. (Referenced the attached cost estimate)


The estimated costs of this option has been credited for the elimination of the cooling towers.

5.3 Well Field Makeup (Alternative #3)

Description of System:

This scenario relies on mechanical draft cooling towers as the primary means of transferring heat from APT to the atmosphere. Makeup water is required to account for evaporative losses and continuous blowdown. Preliminary calculations indicate that approximately 6000 gpm of makeup water will satisfy the maximum heat load conditions for APT. This 6000 gpm could be supplied using a well field located as close to the APT site as practical. Current estimates indicate that this system would include 18 production wells rated for approximately 500 gpm each, and a distribution system to deliver the water to the APT site. Figure 3 shows a schematic of the proposed system. Location of a well field has not been determined and thus assumptions are used to estimate piping lengths required.

Figure 3: 6000 gpm Makeup from Wells



APT Cooling Water Supply/Make-up Trade Study

The specific equipment and modifications required for this alternative include:

- Drill 18 production wells rated for 500 gpm
- Add 18 well pumps rated at 500 gpm at approximately 50 ft TDH.
- For each well add 10 ft of 6" Schedule 10 stainless steel pipe to include two 6" isolation gate valves, one 6" control valve, and one flow measuring device.
- For each well add 100 ft of 6" PVC pipe
- Add 1000 ft of 18" PVC pipe to connect all wells to well field tank.
- One well field tank - 50,000 gallon.
- Add two 16" carbon steel pump suction lines, each with a 16" suction isolation valve.
- Add 2 centrifugal pumps. These pumps should be rated at 6000 gpm @ 100 ft TDH (example Goulds model 3415-DV 14x16-18).
- Add two 14" carbon steel pump discharge lines, each with a 14" check valve and a 14" discharge isolation valve.
- 5000 ft of 18" PVC pipe - bell and spigot type (example J-M Pipe, Big Blue large diameter PVC pressure pipe).
- Add 24,000 ft of 10" PVC pipe - bell and spigot type (example J-M Pipe, Big Blue large diameter PVC pressure pipe) for continuous blowdown to PAR Pond.

Significant Assumptions:

- It is assumed that the use of the existing outfall structure into PAR pond may be used. Site Services Engineering has indicated that the outfall is in good condition, and was sized to handle in excess of 200,000 gpm.
- The piping lengths are based on assumptions that the wells are located within approximately 500 ft of one another, and that the well field is not more than 5000 ft from the APT site.
- It is assumed that production wells can be developed to provide the required 500 gpm per well. Estimates from the geotechnical group indicate that this is the maximum flow that can be expected from a deep well at SRS (Reference 9.3).
- It is assumed that 12 wells is sufficient to provide the required 6000 gpm. An additional 6 wells are included in the estimate to account for any problems associated with the wells (e.g. degradation, plugging, etc.). This provides a reasonable degree of conservatism as the 6000 gpm requirement is a peak load requirement.

APT Cooling Water Supply/Make-up Trade Study

- It is assumed that ground water use permits will be granted by SCDHEC and that ground water flow characteristics will not adversely effect the aquifer.
- A 50,000 gallon collection/surge tank was selected to provide inlet surge capacity for system flow stability. It is assumed that this capacity is adequate to accommodate well pump start-up and other system operational transients.
- No costs have been included for well controls or field housing of instrumentation and equipment. It is not believed that these costs are of a magnitude to significantly affect the evaluation's results.

Advantages:

This type of system is very common and provides a reasonably stable source of makeup water. Also, the required equipment is common and should be readily available.

Disadvantages:

A significant disadvantage of this system is that permitting is perceived to be difficult based on preliminary evaluations by the site geotechnical services department (Reference 9.3). This is due to the evaluation that removal of 6000 gpm may result in the SRS seriously impacting the affected aquifer system.

Cost:

The additional cost of the above described modifications and additions relative to Alternative 1 has been estimated at \$1.1M. (Reference the attached cost estimate)

5.4 K Area Cooling Tower (Alternative #4)


Description of System:

This scenario relies on heat exchangers (used in lieu of cooling towers) as the primary means of transferring heat from the APT site. The heat is dissipated to the atmosphere using the K Area (natural draft) cooling tower. Preliminary calculations indicate that approximately 125,000 gpm supply of cooling water to the heat exchangers will satisfy the maximum heat load for APT. This 125,000 gpm could be supplied using the existing K Area Cooling Tower pumps and approximately 40,000 ft of 80" concrete pipe. The return leg would require additional pumps, approximately 18,000 ft of 80" concrete pipe, and would make use of a portion of the existing river water system to minimize the amount of new pipe required. Additionally, a source of makeup water would need to provide

APT Cooling Water Supply/Make-up Trade Study

approximately 6000 gpm to account for evaporative losses and continuous blowdown. Figure 4 shows a rough schematic of the proposed system.

Figure 4: 125000 gpm K Cooling Tower



The specific equipment and modifications required for this alternative include:

- Add approximately 40,000 linear ft of 80" internal diameter concrete pipe rated at roughly 125 psig to connect from K Area Cooling Tower to APT Site #2. This line should include 2 isolation valves (one at either end).
- Add four 42" Schedule 10 carbon steel pump suction lines, each with a 42" suction isolation gate valve.
- Add four new pumps rated at 50,000 gpm at 130 ft TDH (example Goulds model 3420 36x42-48 High Q).
- Add four 36" Schedule 10 carbon steel pump discharge lines, each with a 36" check valve and a 36" discharge isolation gate valve.
- Add piping and valves associated with the heat exchangers that will serve as the ultimate heat sink for APT
- Add approximately 18,000 linear ft of 80" internal diameter concrete pipe rated at roughly 100 psig to connect APT Site #2 to the "R Normal Header" which will then deliver flow back to K Area Cooling Tower. This new line should include 2 isolation valves (one at either end of the new portion) if possible.
- Modify R Area and P Area lines to allow flow to K Area. This should require approximately 300 ft of 78" ID concrete pipe.

APT Cooling Water Supply/Make-up Trade Study

- Tie in to 84" ID "P Normal Header" to branch off to K Area Cooling Tower for return line. This should require approximately 300 ft of 80" ID concrete pipe.
- Provide makeup water supply using a method similar to Alternative 1 except routing the makeup water flow to the K Area Cooling Tower which would require only a few hundred feet of 18" PVC pipe in lieu of the 18,000 ft required by Alternative 1. If permitting does not allow discharge to the K-area outfall, additional cost will be incurred as a result of routing to an alternate outfall such as PAR Pond.
- Eliminate the cooling towers at the APT site cooling stations.

Significant Assumptions:

- It is assumed that the existing K Area outfall may be utilized for system blowdown.
- The piping lengths are based on a rough straight line estimate from the river water system to the APT site.
- It is assumed that portions of the river water system may be operated close to its design capacity for the life of the APT. This may be possible given the good condition that the pipe is reported to be in Reference 9.1.
- It is assumed that the existing K Area Cooling Tower pumps can produce sufficient head to supply the flow requirements of APT, and that the pumps are in usable condition. There were known problems associated with these pumps, of which most are reported have been resolved.
- K-cooling tower is assumed to be in tact and in good condition. No costs have been included for any modification, repairs, or upgrades to the structure. Although some portions of the cooling tower system have been removed for use elsewhere, it is not believed that the resulting equipment repair/replacement costs will significantly affect the results of this evaluation.
- It is assumed for this evaluation that the cooling tower will function in all modes of APT operation. It has not been determined if the conditions of operation are adequate to induce a natural draft in the tower, nor has it been determined that a draft would be required to provide the required cooling. A detailed engineering study is required to determine the technical adequacy of the cooling tower.

APT Cooling Water Supply/Make-up Trade Study

Advantages:

This type of system also is very common and provides a stable and predictable source of makeup water. The existing river water system is permitted to remove significantly more water than the 6,000 gpm required for APT makeup. The ability to outfall at K Area does not appear to be a problem as the outfall is currently permitted for a larger flow.

Disadvantages:

A possible disadvantage of this system is that the existing river water system is beyond its original design life, and to continue to rely on the integrity of the piping and components could be a concern. However, this has been addressed in Reference 9.1 (River Water System Shutdown: Lay-up Requirements (U), EFR-ENG-950067) which concluded that the river water system is in exceptional condition and should be usable for many years to come. One real disadvantage of this system is that it requires special order equipment such as very large diameter pipe, large pumps, and many large heat exchangers. There is also a substantial and difficult installation associated with the long runs of large diameter pipe. Additionally, the electrical power requirements are large due to the energy required to move 125,000 gpm from the K Area to the APT site and back.

It is not certain at this time how favorable this option is for SCDHEC permitting. The cooling tower facilities may be required to upgrade to new design standards prior to permit approval.

Cost:

The additional capital cost of the above described modifications and additions relative to Alternative 1 has been estimated at \$15.7M. (Reference the attached cost estimate)

6.0 Evaluation of Alternatives for APT Site #8:

The alternatives for APT Site #8 are identical to those for APT Site #2. The advantages and disadvantages are the same; however, the costs associated with each alternative may fluctuate due to the different site location. Specifically, APT Site #8 is further from the existing River Water system lines than APT Site #2. This will result in higher costs for Alternatives 1, 2, and 4. Alternative 3 (Well Field Makeup) may or may not be affected dependent on where the actual well fields can be located for the respective sites.

APT Cooling Water Supply/Make-up Trade Study

7.0 Assignment of Scores:

Assignment of Scores for Capital Costs		
Alternative	Score	Basis
1. River Water Make-up	3	Base Alternative
2. River Water Once Thru	1	Significantly more expensive than the base case (by \$21.2M)
3. Well Field Make-up	3	Expense is only marginally higher (by \$1.1M)
4. K-Cooling Tower	1	More expensive than the base case (by \$15.7M)

Assignment of Scores for Operating and Maintenance Costs		
Alternative	Score	Basis
1. River Water Make-up	3	Base Alternative
2. River Water Once Thru	1	Old pumps require more maintenance. Very high operating costs are expected due to large power requirements
3. Well Field Make-up	2	More expensive than the base case due to the large number of wells to be maintained.
4. K-Cooling Tower	2	More and larger pumps require additional maintenance. Very high operating costs due to greater power requirements

Assignment of Scores for Permitting Risk		
Alternative	Score	Basis
1. River Water Make-up	3	Base Alternative
2. River Water Once Thru	2	Increased permitting risk due to large water demand from the river.
3. Well Field Make-up	1	Significant permitting risk due to large demand on the Cretaceous aquifer
4. K-Cooling Tower	2	Permitting risk associated with permitting the cooling tower.

APT Cooling Water Supply/Make-up Trade Study

8.0 Conclusions:

While the descriptions and information presented above are not detailed, they do provide enough information to make a selection of an alternative based on the identified criteria. Clearly, the costs associated with running long lines of large diameter concrete pipe is not cost effective relative to providing makeup water where smaller diameter PVC pipe can be used. The following is a summary of all alternatives and their ranking:

Criteria	Weighting (%)	River Water Make-up	River Water Once Thru	Well Field Make-up	K-Cooling Tower
Capital Costs	20	3	1	3	1
Ops & Maint Costs	30	3	1	2	2
Permitting Risks	50	3	2	1	2
Ranking Factor		3	1.5	1.7	1.8

Based on the above, Alternative 1: River Water Makeup is the favorable alternative. This alternative has the lowest cost, and no disadvantages that appear insurmountable.

9.0 References:

- 9.1 River Water System Shutdown: Lay-up Requirements (U), EFR-ENG-950067
- 9.2 Study on allowable temp of discharge to PAR pond
- 9.3 IOM from Dale E. Stephenson to Elizabeth Topp, "Preliminary Evaluation of Proposed Well Field for APT", dated 7 May 1996. (Attachment 1)
- 9.4 APT Siting Map (Attachment 2)
- 9.5 Trade Study Estimate (Attachment 3)

APT Cooling Water Supply/Make-up Trade Study

Attachment (1)

“Proposed Well Field for APT IOM”

[This page intentionally left blank]

INTER-OFFICE MEMORANDUM
WESTINGHOUSE SAVANNAH RIVER COMPANY

7 May 1996

TO: Elizabeth G. Topp, 730-2B

FROM: Dale E. Stephenson, 730-2B

DRAFT

PRELIMINARY EVALUATION OF PROPOSED WELL FIELD FOR APT

A very preliminary analysis of requirements for supplying groundwater at the rate of 6000 gpm (gallons per minute) for the APT was made at the request of Jeff England. The assumption was made that the wells will pump from the Cretaceous aquifer and the 6000 gpm is continuous. This equals 8.64×10^6 gpd (gallons per day) total production to support the APT operation.

Most Dublin-Midville aquifer system production well drilled at SRS in recent years were designed to produce 500 gpm, even though a few in the early years could produce 1500 gpm maximum. Assuming that any new wells will be designed to produce 500 gpm a well field to supply 6000 gpm will require 12 well that will operate continuously. To provide backup a minimum of 24 well should be constructed to supply groundwater for the operation of the ATP. To control the amount of drawdown to no more than approximately one-half the aquifer thickness the wells should be placed one per acre. This will result in about 25 feet of drawdown at the mid-point between the wells. The last estimate of the cost of a production well that will produce 500 gpm from the Dublin-Midville aquifer system was \$500,000.00 per well.


The concerns of this proposed well field to supply 6000 gpm or 8.64 Mgpd is that this will result in the SRS seriously impacting the aquifer system. Marine and Routt (1975) calculated the flux in the aquifer system at the SRS as at least 19.4 Mgpd and maybe as high as 42 Mgpd. Hubbard et al (1988) calculated the groundwater flow through the Dublin-Midville system to be about 25 Mgpd and Aadland et al (1996) estimate a value of 16 Mgpd for the flow through the system. As of 1993 the groundwater pumpage at SRS was 6.4 Mgpd under normal operating conditions with this being mostly from the Dublin-Midville aquifer system. If the ATP requirements are added to the current groundwater use the SRS will be extracting about 15 Mgpd from the aquifer system which will be approaching the total flux within the system. If any other demands are placed on the system the SRS could start to mine the aquifer. For this reason it is my opinion that obtaining a permit from the State will be difficult.

APT Cooling Water Supply/Make-up Trade Study

Attachment (2)

APT Siting Map

[This page intentionally left blank]



Attachment (3)

Trade Study Estimate

[This page intentionally left blank]

FILE: APTCOOL
PROJECT NAME: PROJECT NAME

ENGINEERING & CONSTRUCTION SERVICES DIVISION
SITE PROJECT ESTIMATING
DETAIL LINE ITEMS

PAGE # 1
TIME: 08:35:58
DATE 09-Aug-1996
REPORT NAME: APT Detail WBS EXCEL FORMAT

PRICING: PRE 95 OR POST 94 RATES

WBS	TWC	DESCRIPTION	QUANTITY	UOM	UNIT MATL	UNIT MHRS	TTL HOURS	ADJ FACT CREW	\$/MH	CONST. EQUIP.	ENGR'D EQUIP.	MAT'L	CRAFT LABOR	CONTRACT SERVICES	TOTAL COST
GROUP : NO APT GROUP IDENTIFIED															
ACCOUNT CODE:															
WBS1.2.1.01 SITE #2, COOLING OPTION #1															
1940		REMOVE EXISTING RWS PUMPS [25000 GPM @ 3000 HP]	2.0	EA	0.00	940.000	1,880	1.00	SRSX01 17.60	0	0	0	33,088	0	33,088
1310		INSTALL NEW RWS PUMPS [6000 GPM @ 300 HP]	2.0	EA	180000.00	180.000	360	1.00	SRSX01 17.60	0	360,000	0	6,336	0	366,336
4270		MODIFY INLET CONN. - 46"x 36"x 1/4" STEEL PLATE [75#]	2.0	EA	45.00	11.250	23	1.00	SRSX01 17.60	0	0	90	396	0	486
8317		36"x 12" CS REDUCER	2.0	EA	720.00	35.000	70	1.00	SRSX25 17.60	0	0	1,440	1,232	0	2,672
8313		12" PIPE, CS, STD	20.0	LF	29.20	0.770	15	1.00	SRSX25 17.60	0	0	584	271	0	855
8313		12" ELL, 90	2.0	EA	205.00	13.000	26	1.00	SRSX25 17.60	0	0	410	458	0	868
8313		12" FLANGE, WN, 150#	6.0	EA	150.00	8.300	50	1.00	SRSX25 17.60	0	0	900	876	0	1,776
8714		12" GATE VALVE, FLG, CS	2.0	EA	4000.00	4.800	10	1.00	SRSX25 17.60	0	0	8,000	169	0	8,169
8313		12" BOLT-UP W/ B&G SET	6.0	EA	32.00	3.500	21	1.00	SRSX25 17.60	0	0	192	370	0	562
8912		12" HYDROTEST	20.0	LF	0.00	0.340	7	1.00	SRSX25 17.60	0	0	0	120	0	120
4569		12" PIPE - PRIME & PAINT 20LF	70.0	SF	0.70	0.108	8	1.00	SRSX14 15.60	0	0	49	118	0	167
8313		10" WELDOLET, CS [66" PIPE TIE-IN] - ALLOWANCE	2.0	EA	100.00	19.400	39	1.00	SRSX25 17.60	0	0	200	683	0	883
8313		10" PIPE, CS, STD	20.0	LF	24.00	0.660	13	1.00	SRSX25 17.60	0	0	480	232	0	712
8313		10" FLANGE, WN, 150#	10.0	EA	100.00	7.000	70	1.00	SRSX25 17.60	0	0	1,000	1,232	0	2,232
8714		10" CHECK VALVE, FLG, CS	2.0	EA	2400.00	3.600	7	1.00	SRSX25 17.60	0	0	4,800	127	0	4,927
8714		10" GATE VALVE, FLG, CS	2.0	EA	3100.00	3.600	7	1.00	SRSX25 17.60	0	0	6,200	127	0	6,327
8313		10" BOLT-UP W/ B&G SET	10.0	EA	30.00	3.500	35	1.00	SRSX25 17.60	0	0	300	616	0	916
8653		10" PIPE, PVC	24,000.0	LF	12.20	0.220	5,280	1.00	SRSX25 17.60	0	0	292,800	92,928	0	385,728
8912		10" HYDROTEST	20.0	LF	0.00	0.310	6	1.00	SRSX25 17.60	0	0	0	109	0	109
4569		10" PIPE - PRIME & PAINT 20LF	15.0	SF	0.70	0.108	2	1.00	SRSX14 15.60	0	0	11	25	0	36
3940		84" CONCRETE PIPE, D&R 8" THK CONCRETE [18" TIE-IN]	1.0	LS	100.00	24.000	24	1.00	SRSX26 17.10	0	0	100	410	0	510
8315		18" WELDOLET, CS [84" PIPE TIE-IN]	1.0	EA	140.00	32.700	33	1.00	SRSX25 17.60	0	0	140	576	0	716
8315		18" PIPE, CS, STD	20.0	LF	51.50	0.950	19	1.00	SRSX25 17.60	0	0	1,030	334	0	1,364
8315		18" FLANGE, WN, 150#	7.0	EA	480.00	12.700	89	1.00	SRSX25 17.60	0	0	3,360	1,565	0	4,925
8315		18" ELL, 90	2.0	EA	490.00	20.500	41	1.00	SRSX25 17.60	0	0	980	722	0	1,702
8714		18" GATE VALVE, FLG, CS	2.0	EA	12400.00	6.700	13	1.00	SRSX25 17.60	0	0	24,800	236	0	25,036
8714		18" FLOW CONTROL VALVE, FLG, CS	1.0	EA	30000.00	15.000	15	1.00	SRSX25 17.60	0	0	30,000	264	0	30,264
8313		18" BOLT-UP W/ B&G SET	7.0	EA	68.00	6.600	46	1.00	SRSX25 17.60	0	0	476	813	0	1,289
8912		18" HYDROTEST	20.0	LF	0.00	0.510	10	1.00	SRSX25 17.60	0	0	0	180	0	180
8654		18" PIPE, PVC, BIG BLUE	18,000.0	LF	28.00	0.260	4,680	1.00	SRSX25 17.60	0	0	504,000	82,368	0	586,368
8240		18" ELL, 90, MJ,	18.0	EA	660.00	9.800	176	1.00	SRSX25 17.60	0	0	11,880	3,105	0	14,985
WBS1.2.1.01 SITE #2, COOLING OPTION #1 SUBTOTAL							13,075		17.60	0	360,000	894,222	230,084	0	1,484,306
=====															
WBS1.2.1.02 SITE #2, COOLING OPTION #2															
1310		INSTALL NEW COOLING WATER PUMPS [50,000 GPM @ 1,500 HP]	4.0	EA	300000.00	420.000	1,680	1.00	SRSX01 17.60	0	1,200,000	0	29,568	0	1,229,568
1400		COOLING EQUIPMENT COST ADJUSTMENT (DELETE CT)	(10.0)	EA			0	1.00	SRSX01	0	(5,620,000)	0	0	0	(5,620,000)

6

FILE: APTCOOL

PROJECT NAME: PROJECT NAME

PRICING: PRE 95 OR POST 94 RATES

ENGINEERING & CONSTRUCTION SERVICES DIVISION

SITE PROJECT ESTIMATING

DETAIL LINE ITEMS

PAGE # 2

TIME: 08:35:58

DATE: 09-Aug-1996

REPORT NAME: APT Detail WBS EXCEL FORMAT

WBS	TWC	DESCRIPTION	QUANTITY	UOM	UNIT MATL	UNIT MHR	TTL HOURS	ADJ FACT CREW	\$/MH	CONST. EQUIP.	ENGR'D EQUIP.	MAT'L	CRAFT LABOR	CONTRACT SERVICES	TOTAL COST
GROUP : NO APT GROUP IDENTIFIED															
ACCOUNT CODE:															
WBS 1.2.1.02 SITE #2, COOLING OPTION #2															
8673		126" ID CONCRETE PIPE	18,000.0	LF	575.00	3.500	63,000	1.00	SRSX25 17.60	0	10,350,000	0	1,108,800	0	11,458,800
8673		126" ID PIPE JOINTS (GROUT & GASKET-12" OD @ 37.7LF)	450.0	EA	0.00	62.000	27,900	1.00	SRSX25 17.60	0	0	0	491,040	0	491,040
8673		126" x 84" CONCRETE REDUCER	1.0	EA	41000.00	20.000	20	1.00	SRSX25 17.60	0	41,000	0	352	0	41,352
3940		84" CONCRETE PIPE, D&R 8" THK CONCRETE (84" TIE-IN)	1.0	LS	1000.00	180.000	180	1.00	SRSX26 17.10	0	0	1,000	3,078	0	4,078
8673		126" FLANGE ADAPTERS	4.0	EA	32000.00	60.000	240	1.00	SRSX25 17.60	0	128,000	0	4,224	0	132,224
8673		126" GATE VALVE, FLG [ALLOWANCE]	2.0	EA	40000.00	80.000	160	1.00	SRSX25 17.60	0	80,000	0	2,816	0	82,816
8673		126" ID PNEUMATIC PIPE JOINT TEST	450.0	EA	0.00	2.400	1,080	1.00	SRSX25 17.60	0	0	0	19,008	0	19,008
8673		102" ID CONCRETE PIPE	24,000.0	LF	388.00	2.800	67,200	1.00	SRSX25 17.60	0	9,312,000	0	1,182,720	0	10,494,720
8673		102" ID PIPE JOINTS (GROUT & GASKET-9.75" OD @ 30.6LF)	600.0	EA	0.00	50.000	30,000	1.00	SRSX25 17.60	0	0	0	528,000	0	528,000
8673		102" x 36" CONCRETE REDUCER	1.0	EA	4500.00	16.000	16	1.00	SRSX25 17.60	0	4,500	0	282	0	4,782
8673		102" ID FLANGE ADAPTERS	4.0	EA	17000.00	48.000	192	1.00	SRSX25 17.60	0	68,000	0	3,379	0	71,379
8714		102" ID GATE VALVE, FLG [ALLOWANCE]	2.0	EA	32000.00	64.000	128	1.00	SRSX25 17.60	0	64,000	0	2,253	0	66,253
8912		102" ID PNEUMATIC PIPE JOINT TEST	600.0	EA	0.00	2.000	1,200	1.00	SRSX25 17.60	0	0	0	21,120	0	21,120
8317		42" CS PIPE, SCH 10	120.0	LF	102.00	1.600	192	1.00	SRSX25 17.60	0	12,240	0	3,379	0	15,619
8317		42" TEE	3.0	EA	2200.00	68.000	204	1.00	SRSX25 17.60	0	6,600	0	3,590	0	10,190
8317		42" ELL, 90	4.0	EA	1300.00	48.000	192	1.00	SRSX25 17.60	0	5,200	0	3,379	0	8,579
8317		42" FLANGE, WN	12.0	EA	1000.00	26.000	312	1.00	SRSX25 17.60	0	12,000	0	5,491	0	17,491
8714		42" GATE VALVE, FLG	4.0	EA	37000.00	48.000	192	1.00	SRSX25 17.60	0	148,000	0	3,379	0	151,379
8520		42" PIPE SUPPORT [ALLOWANCE]	8.0	EA	100.00	30.000	240	1.00	SRSX25 17.60	0	0	800	4,224	0	5,024
4569		42" PIPE - PRIME & PAINT - 120 LF	1,320.0	SF	0.60	0.100	132	1.00	SRSX14 15.60	0	0	792	2,059	0	2,851
8912		42" PIPE HYDROTEST	120.0	LF	0.00	0.600	72	1.00	SRSX25 17.60	0	0	0	1,267	0	1,267
8317		36" CS PIPE, SCH 10	140.0	LF	95.00	1.500	210	1.00	SRSX25 17.60	0	13,300	0	3,696	0	16,996
8317		36" TEE	3.0	EA	2100.00	59.000	177	1.00	SRSX25 17.60	0	6,300	0	3,115	0	9,415
8317		36" ELL, 90	8.0	EA	1200.00	42.000	336	1.00	SRSX25 17.60	0	9,600	0	5,914	0	15,514
8317		36" FLANGE, WN	20.0	EA	940.00	24.000	480	1.00	SRSX25 17.60	0	18,800	0	8,448	0	27,248
8714		36" GATE VALVE, FLG	4.0	EA	35000.00	34.000	136	1.00	SRSX25 17.60	0	140,000	0	2,394	0	142,394
8714		36" CHECK VALVE, FLG	4.0	EA	30000.00	34.000	136	1.00	SRSX25 17.60	0	120,000	0	2,394	0	122,394
8520		36" PIPE SUPPORT [ALLOWANCE]	6.0	EA	75.00	25.000	150	1.00	SRSX25 17.60	0	0	450	2,640	0	3,090
4569		36" PIPE - PRIME & PAINT - 1300 LF	1,320.0	SF	0.60	0.100	132	1.00	SRSX14 15.60	0	0	792	2,059	0	2,851
8912		36" PIPE HYDROTEST	140.0	LF	0.00	0.368	52	1.00	SRSX25 17.60	0	0	0	907	0	907
3211		MACHINE EXCAVATE FOR SITE	220,409.0	CY	0.00	0.030	6,612	1.00	SRSX05 16.20	202,776	0	0	107,119	0	309,895
3212		HAND EXCAVATE FOR SITE	4,500.0	CY	0.00	4.000	18,000	1.00	SRSX04 11.80	0	0	0	212,400	0	212,400
3221		FURNISH & PLACE PIPE BEDDING SAND	8,834.0	CY	8.00	0.830	7,332	1.00	SRSX04 11.80	0	0	70,672	86,520	0	157,192

7

FILE: APTCOOL

PROJECT NAME: PROJECT NAME

PRICING: PRE 95 OR POST 94 RATES

ENGINEERING & CONSTRUCTION SERVICES DIVISION

SITE PROJECT ESTIMATING

DETAIL LINE ITEMS

PAGE # 3

TIME: 08:35:58

DATE 09-Aug-1996

REPORT NAME: APT Detail WBS EXCEL FORMAT

WBS	TWC	DESCRIPTION	QUANTITY	UOM	UNIT MATL	UNIT MHRS	TTL HOURS	ADJ FACT	CREW	\$/MH	CONST. EQUIP.	ENGR'D EQUIP.	MAT'L	CRAFT LABOR	CONTRACT SERVICES	TOTAL COST
GROUP : NO APT GROUP IDENTIFIED																
ACCOUNT CODE:																
WBS1.2.1.02 SITE #2, COOLING OPTION #2																
3221		TRENCH BACKFILL & COMPACTION	107,627.0	CY	0.00	0.060	6,458	1.00	SRSX05	16.20	88,254	0	0	104,613	0	192,868
3216		HAUL & DUMP (EXCESS)	117,294.0	CY	0.00	1.200	140,753	1.00	SRSX05	16.20	0	0	0	2,280,195	0	2,280,195
4160		CONCRETE FOR PUMP PADS	20.0	CY	60.00	2.500	50	1.00	SRSX10	12.20	0	0	1,200	610	0	1,810
4140		REBAR FOR FOR PUMP PADS	1.0	TON	600.00	20.000	20	1.00	SRSX08	17.30	0	0	600	346	0	946
4120		FORMWORK FOR PUMP PADS	164.0	SFCA	0.75	0.500	82	1.00	SRSX07	14.60	0	0	123	1,197	0	1,320
4140		FURNISH FAB & PLACE COVER/ GRATING	800.0	SF	8.35	0.093	74	1.00	SRSX12	17.50	1,296	0	6,680	1,302	0	9,278
WBS1.2.1.02 SITE #2, COOLING OPTION #2 SUBTOTAL							375,722			16.63	292,326	16,119,540	83,109	6,249,278	0	22,744,254
WBS1.2.1.03 SITE #2, COOLING OPTION #3																
3720		6" DIA WELL CASING W/ PUMP [500 GPM @ 15 HP]	18.0	EA	0.00	0.000	0	1.00			0	0	0	0	900,000	900,000
		WELL FIELD TANK [23.5' DIA x 15.5' HIGH - 50000 GAL]	1.0	EA	0.00	0.000	0	1.00			0	0	0	0	55,000	55,000
		6" PIPE, STN STL	180.0	LF	32.00	0.390	70	1.00	SRSX25	17.60	0	0	5,760	1,236	0	6,996
		6" ELL, 90	36.0	EA	95.00	9.400	338	1.00	SRSX25	17.60	0	0	3,420	5,956	0	9,376
		6" FLANGE, WN	144.0	EA	167.00	9.200	1,325	1.00	SRSX25	17.60	0	0	24,048	23,316	0	47,364
		6" GATE VALVE, FLG	36.0	EA	3000.00	3.100	112	1.00	SRSX25	17.60	0	108,000	0	1,964	0	109,964
		6" CHECK VALVE, FLG	18.0	EA	2100.00	3.100	56	1.00	SRSX25	17.60	0	37,800	0	982	0	38,782
		6" CONTROL VALVE, FLG	18.0	EA	19000.00	6.000	108	1.00	SRSX25	17.60	0	342,000	0	1,901	0	343,901
		6" PIPE SUPPORT, STN STL	36.0	EA	75.00	16.000	576	1.00	SRSX25	17.60	0	0	2,700	10,138	0	12,838
		6" HYDROTEST	180.0	LF	0.00	0.250	45	1.00	SRSX25	17.60	0	0	0	792	0	792
		6" PIPE, PVC	1,800.0	LF	1.60	0.140	252	1.00	SRSX25	17.60	0	0	2,880	4,435	0	7,315
		6" HYDROTEST	1,800.0	LF	0.00	0.150	270	1.00	SRSX25	17.60	0	0	0	4,752	0	4,752
		10" PIPE, PVC	24,000.0	LF	12.20	0.150	3,600	1.00	SRSX25	17.60	0	0	292,800	63,360	0	356,160
		10" HYDROTEST	24,000.0	LF	0.00	0.310	7,440	1.00	SRSX25	17.60	0	0	0	130,944	0	130,944
		18" PIPE, PVC	6,000.0	LF	13.50	0.250	1,500	1.00	SRSX25	17.60	0	0	81,000	26,400	0	107,400
		18" HYDROTEST	6,000.0	LF	0.00	0.250	1,500	1.00	SRSX25	17.60	0	0	0	26,400	0	26,400
		14" PIPE, CS	10.0	LF	25.80	0.830	8	1.00	SRSX25	17.60	0	0	258	146	0	404
		14" TEE	1.0	EA	430.00	23.000	23	1.00	SRSX25	17.60	0	0	430	405	0	835
		14" ELL, 90	2.0	EA	280.00	15.000	30	1.00	SRSX25	17.60	0	0	560	528	0	1,088
		14" GATE VALVE, FLG	2.0	EA	7500.00	5.100	10	1.00	SRSX25	17.60	0	15,000	0	180	0	15,180
		14" CHECK VALVE, FLG	2.0	EA	4800.00	5.100	10	1.00	SRSX25	17.60	0	9,600	0	180	0	9,780
		14" FLANGE, WN	10.0	EA	220.00	6.200	62	1.00	SRSX25	17.60	0	0	2,200	1,091	0	3,291
		14" PIPE SUPPORT, CS	4.0	EA	40.00	12.000	48	1.00	SRSX25	17.60	0	0	160	845	0	1,005
		18" X 14" REDUCER	1.0	EA	260.00	17.000	17	1.00	SRSX25	17.60	0	0	260	299	0	559
		14" HYDROTEST	10.0	LF	0.00	0.380	4	1.00	SRSX25	17.60	0	0	0	67	0	67
		14" PIPE - PRIME & PAINT - 10 LF	40.0	SF	0.70	0.108	4	1.00	SRSX14	15.60	0	0	28	67	0	95
		16" PIPE, CS	10.0	LF	30.80	0.890	9	1.00	SRSX25	17.60	0	0	308	157	0	465
		16" TEE	1.0	EA	520.00	26.000	26	1.00	SRSX25	17.60	0	0	520	458	0	978
		16" ELL, 90	2.0	EA	380.00	18.000	36	1.00	SRSX25	17.60	0	0	760	634	0	1,394
		16" GATE VALVE, FLG	2.0	EA	10200.00	5.900	12	1.00	SRSX25	17.60	0	20,400	0	208	0	20,608

FILE: APTCOOL
PROJECT NAME: PROJECT NAME

ENGINEERING & CONSTRUCTION SERVICES DIVISION
SITE PROJECT ESTIMATING
DETAIL LINE ITEMS

PAGE # 4
TIME: 08:35:58
DATE 09-Aug-1996
REPORT NAME: APT Detail WBS EXCEL FORMAT

PRICING: PRE 95 OR POST 94 RATES

WBS	TWC	DESCRIPTION	QUANTITY	UOM	UNIT MAT'L	UNIT MHR'S	TTL HOURS	ADJ FACT CREW	\$/MH	CONST. EQUIP.	ENGR'D EQUIP.	MAT'L	CRAFT LABOR	CONTRACT SERVICES	TOTAL COST
GROUP : NO APT GROUP IDENTIFIED															
ACCOUNT CODE:															
WBS1.2.1.03 SITE #2, COOLING OPTION #3															
		16" FLANGE, WN	6.0	EA	350.00	6.900	41	1.00	SRSX25 17.60	0	0	2,100	729	0	2,829
		16" PIPE SUPPORT, CS	4.0	EA	50.00	15.000	60	1.00	SRSX25 17.60	0	0	200	1,056	0	1,256
		16" HYDROTEST	10.0	LF	0.00	0.440	4	1.00	SRSX25 17.60	0	0	0	77	0	77
		16" PIPE - PRIME & PAINT - 10 LF	40.0	SF	0.60	0.100	4	1.00	SRSX14 15.60	0	0	24	62	0	86
3211		MACHINE EXCAVATE FOR SITE	12,024.0	CY	0.00	0.030	361	1.00	SRSX05 16.20	11,062	0	0	5,844	0	16,906
3212		HAND EXCAVATE FOR SITE	4,008.0	CY	0.00	4.000	16,032	1.00	SRSX04 11.80	0	0	0	189,178	0	189,178
3221		FURNISH & PLACE PIPE BEDDING SAND	1,629.0	CY	8.00	0.830	1,352	1.00	SRSX04 11.80	0	0	13,032	15,954	0	28,986
3221		TRENCH BACKFILL & COMPACTION	13,139.0	CY	0.00	0.060	788	1.00	SRSX05 16.20	10,774	0	0	12,771	0	23,545
3216		HAUL & DUMP (EXCESS)	3,360.0	CY	0.00	1.200	4,032	1.00	SRSX05 16.20	0	0	0	65,318	0	65,318
8315		18" PIPE, CS, STD	20.0	LF	51.50	0.950	19	1.00	SRSX25 17.60	0	0	1,030	334	0	1,364
8315		18" FLANGE, WN, 150#	7.0	EA	480.00	12.700	89	1.00	SRSX25 17.60	0	0	3,360	1,565	0	4,925
8315		18" ELL, 90	2.0	EA	490.00	20.500	41	1.00	SRSX25 17.60	0	0	980	722	0	1,702
8714		18" GATE VALVE, FLG, CS	2.0	EA	12400.00	6.700	13	1.00	SRSX25 17.60	0	0	24,800	236	0	25,036
8714		18" FLOW CONTROL VALVE, FLG, CS	1.0	EA	30000.00	15.000	15	1.00	SRSX25 17.60	0	0	30,000	264	0	30,264
8313		18" BOLT-UP W/ B&G SET	7.0	EA	68.00	6.600	46	1.00	SRSX25 17.60	0	0	476	813	0	1,289
WBS1.2.1.03 SITE #2, COOLING OPTION #3 SUBTOTAL							40,390	14.92	21,836	532,800	494,094	602,762	955,000		2,606,492
=====															
WBS1.2.1.04 SITE #2, COOLING OPTION #4															
3211		MACHINE EXCAVATE FOR SITE	225,957.0	CY	0.00	0.030	6,779	1.00	SRSX05 16.20	207,880	0	0	109,815	0	317,696
3212		HAND EXCAVATE FOR SITE	4,600.0	CY	0.00	4.000	18,400	1.00	SRSX04 11.80	0	0	0	217,120	0	217,120
3221		FURNISH & PLACE PIPE BEDDING SAND	10,380.0	CY	8.00	0.830	8,615	1.00	SRSX04 11.80	0	0	83,040	101,662	0	184,702
3221		TRENCH BACKFILL & COMPACTION	123,626.0	CY	0.00	0.060	7,418	1.00	SRSX05 16.20	101,373	0	0	120,164	0	221,538
3216		HAUL & DUMP (EXCESS)	122,981.0	CY	0.00	1.200	147,577	1.00	SRSX05 16.20	0	0	0	2,390,751	0	2,390,751
4160		CONCRETE PUMP PADS	20.0	CY	60.00	2.500	50	1.00	SRSX10 12.20	0	0	1,200	610	0	1,810
4140		REBAR FOR PUMP PADS	1.0	TON	600.00	20.000	20	1.00	SRSX08 17.30	0	0	600	346	0	946
4120		FORMWORK FOR PUMP PADS	164.0	SFCA	0.75	0.500	82	1.00	SRSX07 14.60	0	0	123	1,197	0	1,320
4140		FURNISH FAB & PLACE COVER/ GRATING	800.0	SF	8.35	0.093	74	1.00	SRSX12 17.50	1,296	0	6,680	1,302	0	9,278
1310		COOLING WATER PUMPS [50000GPM @ 2250 HP]	4.0	EA	400000.00	720.000	2,880	1.00	SRSX01 17.60	0	1,600,000	0	50,688	0	1,650,688
1400		ADJUSTMENT FOR COOLING EQUIPMENT (DELETE CT)	(10.0)	EA			0	1.00		0	0	0	0	(5,620,000)	(5,620,000)
8673		84" ID CONCRETE PIPE	58,300.0	LF	245.00	1.400	81,620	1.00	SRSX25 17.60	0	14,283,500	0	1,436,512	0	15,720,012
8673		84" ID PIPE JOINT [GROUT & GASKET-8.25' OD @ 25.9 LF]	1,458.0	EA	0.00	42.000	61,236	1.00	SRSX25 17.60	0	0	0	1,077,754	0	1,077,754
3940		84" CONCRETE PIPE, D&R 8" THK CONCRETE [84" TIE-IN]	2.0	EA	1180.00	180.000	360	1.00	SRSX26 17.10	0	360	2,000	6,156	0	8,516
8673		84" ID FLANGE ADAPTERS	8.0	EA	8000.00	54.000	432	1.00	SRSX25 17.60	0	64,000	0	7,603	0	71,603

FILE: APTCOOL

PROJECT NAME: PROJECT NAME

PRICING: PRE 95 OR POST 94 RATES

ENGINEERING & CONSTRUCTION SERVICES DIVISION

SITE PROJECT ESTIMATING

DETAIL LINE ITEMS

PAGE # 5

TIME: 08:35:58

DATE 09-Aug-1996

REPORT NAME: APT Detail WBS EXCEL FORMAT

WBS	TWC	DESCRIPTION	QUANTITY	UOM	UNIT MATL	UNIT MHRS	TTL HOURS	ADJ FACT CREW	\$/MH	CONST. EQUIP.	ENGR'D EQUIP.	MAT'L	CRAFT LABOR	CONTRACT SERVICES	TOTAL COST
GROUP : NO APT GROUP IDENTIFIED															
ACCOUNT CODE:															
WBS1.2.1.04 SITE #2, COOLING OPTION #4															
8714		84" ID GATE VALVE, FLG [ALLOWANCE]	4.0	EA	28000.00	56.000	224	1.00	SRSX25 17.60	0	112,000	0	3,942	0	115,942
3940		84" CONCRETE PIPE D & R	48.0	LF	0.00	2.600	125	1.00	SRSX25 17.60	0	0	0	2,196	0	2,196
8673		84" CONCRETE PIPE CAP	8.0	EA	8800.00	42.000	336	1.00	SRSX25 17.60	0	70,400	0	5,914	0	76,314
8912		84" ID PNEUMATIC PIPE JOINT TEST	1,458.0	EA	0.00	1.800	2,624	1.00	SRSX25 17.60	0	0	0	46,189	0	46,189
8673		78" ID CONCRETE PIPE	600.0	LF	233.00	1.400	840	1.00	SRSX25 17.60	0	139,800	0	14,784	0	154,584
8673		78" ID PIPE JOINT [GROUT & GASKET - 7.5" @ 23.6 LF]	15.0	EA	0.00	39.000	585	1.00	SRSX25 17.60	0	0	0	10,296	0	10,296
8673		78" ID CONCRETE TIE-IN	4.0	EA	950.00	170.000	680	1.00	SRSX25 17.60	0	3,800	0	11,968	0	15,768
8912		78" ID PNEUMATIC PIPE JOINT TEST	15.0	EA	1.60	1.600	24	1.00	SRSX25 17.60	0	24	0	422	0	446
8317		42" CS PIPE, SCH 10	120.0	LF	102.00	1.600	192	1.00	SRSX25 17.60	0	12,240	0	3,379	0	15,619
8317		42" TEE	3.0	EA	2200.00	68.000	204	1.00	SRSX25 17.60	0	6,600	0	3,590	0	10,190
8317		42" ELL, 90	4.0	EA	1300.00	48.000	192	1.00	SRSX25 17.60	0	5,200	0	3,379	0	8,579
8317		42" FLANGE, WN	12.0	EA	1000.00	26.000	312	1.00	SRSX25 17.60	0	12,000	0	5,491	0	17,491
8714		42" GATE VALVE, FLG	4.0	EA	37000.00	48.000	192	1.00	SRSX25 17.60	0	148,000	0	3,379	0	151,379
8520		42" PIPE SUPPORT [ALLOWANCE]	8.0	EA	100.00	30.000	240	1.00	SRSX25 17.60	0	0	800	4,224	0	5,024
4569		42" PIPE - PRIME & PAINT - 120 LF	1,320.0	SF	0.60	0.100	132	1.00	SRSX14 15.60	0	0	792	2,059	0	2,851
8912		42" PIPE HYDROTEST	120.0	LF	0.00	0.600	72	1.00	SRSX25 17.60	0	0	0	1,267	0	1,267
8317		36" CS PIPE, SCH 10	140.0	LF	95.00	1.500	210	1.00	SRSX25 17.60	0	13,300	0	3,696	0	16,996
8317		36" TEE	3.0	EA	2100.00	59.000	177	1.00	SRSX25 17.60	0	6,300	0	3,115	0	9,415
8317		36" ELL, 90	8.0	EA	1200.00	42.000	336	1.00	SRSX25 17.60	0	9,600	0	5,914	0	15,514
8317		36" FLANGE, WN	20.0	EA	940.00	24.000	480	1.00	SRSX25 17.60	0	18,800	0	8,448	0	27,248
8714		36" GATE VALVE, FLG	4.0	EA	35000.00	34.000	136	1.00	SRSX25 17.60	0	140,000	0	2,394	0	142,394
8714		36" CHECK VALVE, FLG	4.0	EA	30000.00	34.000	136	1.00	SRSX25 17.60	0	120,000	0	2,394	0	122,394
8520		36" PIPE SUPPORT [ALLOWANCE]	6.0	EA	75.00	25.000	150	1.00	SRSX25 17.60	0	0	450	2,640	0	3,090
4569		36" PIPE - PRIME & PAINT - 1300 LF	1,320.0	SF	0.60	0.100	132	1.00	SRSX14 15.60	0	0	792	2,059	0	2,851
8912		36" PIPE HYDROTEST	140.0	LF	0.00	0.368	52	1.00	SRSX25 17.60	0	0	0	907	0	907
WBS1.2.1.04 SITE #2, COOLING OPTION #4 SUBTOTAL							344,326		16.48	310,550	16,765,924	96,477	5,675,728	(5,620,000)	17,228,679
WBS1.2.1.05 SITE #8, COOLING OPTION #1															
1940		REMOVE EXISTING RWS PUMPS [25000 GPM @ 3000 HP]	2.0	EA	0.00	940.000	1,880	1.00	SRSX01 17.60	0	0	0	33,088	0	33,088
1310		INSTALL NEW RWS PUMPS [6000 GPM @ 850 HP]	2.0	EA	180000.00	250.000	500	1.00	SRSX01 17.60	0	360,000	0	8,800	0	368,800
4270		MODIFY INLET CONN. - 46"x 36"x 1/4" STEEL PLATE [75#]	2.0	EA	45.00	11.250	23	1.00	SRSX01 17.60	0	0	90	396	0	486
8317		36"x 12" CS REDUCER	2.0	EA	720.00	35.000	70	1.00	SRSX25 17.60	0	0	1,440	1,232	0	2,672
8313		12" PIPE, CS, STD	20.0	LF	29.20	0.770	15	1.00	SRSX25 17.60	0	0	584	271	0	855
8313		12" ELL, 90	2.0	EA	205.00	13.000	26	1.00	SRSX25 17.60	0	0	410	458	0	868
8313		12" FLANGE, WN, 150#	6.0	EA	150.00	8.300	50	1.00	SRSX25 17.60	0	0	900	876	0	1,776

10

FILE: APTCOOL

PROJECT NAME: PROJECT NAME

ENGINEERING & CONSTRUCTION SERVICES DIVISION

SITE PROJECT ESTIMATING

DETAIL LINE ITEMS

PAGE # 6

TIME: 08:35:58

DATE 09-Aug-1996

REPORT NAME: APT Detail WBS EXCEL FORMAT

PRICING: PRE 95 OR POST 94 RATES

WBS	TWC	DESCRIPTION	QUANTITY	UOM	UNIT MATL	UNIT MHR	TTL HOURS	ADJ FACT CREW	\$/MH	CONST. EQUIP.	ENGR'D EQUIP.	MAT'L	CRAFT LABOR	CONTRACT SERVICES	TOTAL COST
GROUP : NO APT GROUP IDENTIFIED															
ACCOUNT CODE:															
WBS1.2.1.05 SITE #8, COOLING OPTION #1															
8714		12" GATE VALVE, FLG, CS	2.0	EA	4000.00	4.800	10	1.00	SRSX25 17.60	0	0	8,000	169	0	8,169
8313		12" BOLT-UP W/ B&G SET	6.0	EA	32.00	3.500	21	1.00	SRSX25 17.60	0	0	192	370	0	562
8912		12" HYDROTEST	20.0	LF	0.00	0.340	7	1.00	SRSX25 17.60	0	0	0	120	0	120
4569		12" PIPE - PRIME & PAINT 20LF	70.0	SF	0.70	0.108	8	1.00	SRSX14 15.60	0	0	49	118	0	167
8313		10" WELDOLET, CS [66" PIPE TIE-IN] - ALLOWANCE	2.0	EA	100.00	19.400	39	1.00	SRSX25 17.60	0	0	200	683	0	883
8313		10" PIPE, CS, STD	20.0	LF	24.00	0.660	13	1.00	SRSX25 17.60	0	0	480	232	0	712
8313		10" FLANGE, WN, 150#	10.0	EA	100.00	7.000	70	1.00	SRSX25 17.60	0	0	1,000	1,232	0	2,232
8714		10" CHECK VALVE, FLG, CS	2.0	EA	2400.00	3.600	7	1.00	SRSX25 17.60	0	0	4,800	127	0	4,927
8714		10" GATE VALVE, FLG, CS	2.0	EA	3100.00	3.600	7	1.00	SRSX25 17.60	0	0	6,200	127	0	6,327
8313		10" BOLT-UP W/ B&G SET	10.0	EA	30.00	3.500	35	1.00	SRSX25 17.60	0	0	300	616	0	916
8653		10" PIPE, PVC	24,000.0	LF	12.20	0.220	5,280	1.00	SRSX25 17.60	0	0	292,800	92,928	0	385,728
8912		10" HYDROTEST	20.0	LF	0.00	0.310	6	1.00	SRSX25 17.60	0	0	0	109	0	109
4569		10" PIPE - PRIME & PAINT 20LF	15.0	SF	0.70	0.108	2	1.00	SRSX14 15.60	0	0	11	25	0	36
3940		84" CONCRETE PIPE, D&R 8" THK CONCRETE [20" TIE-IN]	1.0	LS	125.00	26.000	26	1.00	SRSX26 17.10	0	0	125	445	0	570
8315		20" WELDOLET, CS [84" PIPE TIE-IN]	1.0	EA	150.00	35.000	35	1.00	SRSX25 17.60	0	0	150	616	0	766
8315		20" PIPE, CS, STD	20.0	LF	57.30	0.990	20	1.00	SRSX25 17.60	0	0	1,146	348	0	1,494
8315		20" FLANGE, WN, 150#	7.0	EA	610.00	14.900	104	1.00	SRSX25 17.60	0	0	4,270	1,836	0	6,106
8315		20" ELL, 90	2.0	EA	715.00	22.700	45	1.00	SRSX25 17.60	0	0	1,430	799	0	2,229
8714		20" GATE VALVE, FLG, CS	2.0	EA	15400.00	7.700	15	1.00	SRSX25 17.60	0	30,800	0	271	0	31,071
8714		20" FLOW CONTROL VALVE, FLG, CS	1.0	EA	32000.00	17.300	17	1.00	SRSX25 17.60	0	32,000	0	304	0	32,304
8313		20" BOLT-UP W/ B&G SET	7.0	EA	100.00	7.500	53	1.00	SRSX25 17.60	0	0	700	924	0	1,624
8912		20" HYDROTEST	20.0	LF	0.00	0.570	11	1.00	SRSX25 17.60	0	0	0	201	0	201
8654		20" PIPE, PVC, BIG BLUE	36,000.0	LF	20.00	0.280	10,080	1.00	SRSX25 17.60	0	0	720,000	177,408	0	897,408
8240		20" ELL, 90, MJ,	18.0	EA	700.00	11.000	198	1.00	SRSX25 17.60	0	0	12,600	3,485	0	16,085

WBS1.2.1.05 SITE #8, COOLING OPTION #1 SUBTOTAL 18,673 17.60 0 422,800 1,057,877 328,613 0 1,809,290

WBS1.2.1.06 SITE #8, COOLING OPTION #2															
1310		INSTALL NEW COOLING WATER PUMPS [50,000 GPM @ 1,500 HP]	4.0	EA	300000.00	420.000	1,680	1.00	SRSX01 17.60	0	1,200,000	0	29,568	0	1,229,568
1400		COOLING EQUIPMENT COST ADJUSTMENT (DELETE CT)	(10.0)	EA			0	1.00	SRSX01	0	(5,620,000)	0	0	0	(5,620,000)
8673		102" ID CONCRETE PIPE	86,000.0	LF	388.00	2.800	240,800	1.00	SRSX25 17.60	0	33,368,000	0	4,238,080	0	37,606,080
8673		102" ID PIPE JOINTS [GROUT & GASKET-9.75" OD @ 30.6LF]	2,150.0	EA	0.00	50.000	107,500	1.00	SRSX25 17.60	0	0	0	1,892,000	0	1,892,000
8673		102"x 84" CONCRETE REDUCER	1.0	EA	38000.00	18.000	18	1.00	SRSX25 17.60	0	38,000	0	317	0	38,317
3940		84" CONCRETE PIPE, D&R 8" THK CONCRETE [84" TIE-IN]	1.0	LS	1000.00	180.000	180	1.00	SRSX26 17.10	0	0	1,000	3,078	0	4,078
8673		102" FLANGE ADAPTERS	8.0	EA	17000.00	48.000	384	1.00	SRSX25 17.60	0	136,000	0	6,758	0	142,758
8673		102" GATE VALVE, FLG [ALLOWANCE]	4.0	EA	40000.00	80.000	320	1.00	SRSX25 17.60	0	160,000	0	5,632	0	165,632

11

FILE: APTCOOL
PROJECT NAME: PROJECT NAME

ENGINEERING & CONSTRUCTION SERVICES DIVISION
SITE PROJECT ESTIMATING
DETAIL LINE ITEMS

PAGE # 7
TIME: 08:35:58
DATE 09-Aug-1996
REPORT NAME: APT Detail WBS EXCEL FORMAT

PRICING: PRE 95 OR POST 94 RATES

WBS	TWC	DESCRIPTION	QUANTITY	UOM	UNIT MATL	UNIT MHRS	TTL HOURS	ADJ FACT CREW	\$/MH	CONST. EQUIP.	ENGR'D EQUIP.	MAT'L	CRAFT LABOR	CONTRACT SERVICES	TOTAL COST
GROUP : NO APT GROUP IDENTIFIED															
ACCOUNT CODE:															
WBS 1.2.1.06 SITE #8, COOLING OPTION #2															
8673		102" ID PNEUMATIC PIPE JOINT TEST	2,150.0	EA	0.00	2.000	4,300	1.00	SRSX25 17.60	0	0	0	75,680	0	75,680
8673		102" x 36 CONCRETE REDUCER	1.0	EA	4500.00	16.000	16	1.00	SRSX25 17.60	0	4,500	0	282	0	4,782
8714		102" ID GATE VALVE, FLG [ALLOWANCE]	4.0	EA	32000.00	64.000	256	1.00	SRSX25 17.60	0	128,000	0	4,506	0	132,506
8317		42" CS PIPE, SCH 10	120.0	LF	102.00	1.600	192	1.00	SRSX25 17.60	0	12,240	0	3,379	0	15,619
8317		42" TEE	3.0	EA	2200.00	68.000	204	1.00	SRSX25 17.60	0	6,600	0	3,590	0	10,190
8317		42" ELL, 90	4.0	EA	1300.00	48.000	192	1.00	SRSX25 17.60	0	5,200	0	3,379	0	8,579
8317		42" FLANGE, WN	12.0	EA	1000.00	26.000	312	1.00	SRSX25 17.60	0	12,000	0	5,491	0	17,491
8714		42" GATE VALVE, FLG	4.0	EA	37000.00	48.000	192	1.00	SRSX25 17.60	0	148,000	0	3,379	0	151,379
8520		42" PIPE SUPPORT [ALLOWANCE]	8.0	EA	100.00	30.000	240	1.00	SRSX25 17.60	0	0	800	4,224	0	5,024
4569		42" PIPE - PRIME & PAINT - 120 LF	1,320.0	SF	0.60	0.100	132	1.00	SRSX14 15.60	0	0	792	2,059	0	2,851
8912		42" PIPE HYDROTEST	120.0	LF	0.00	0.600	72	1.00	SRSX25 17.60	0	0	0	1,267	0	1,267
8317		36" CS PIPE, SCH 10	1,300.0	LF	95.00	1.500	1,950	1.00	SRSX25 17.60	0	123,500	0	34,320	0	157,820
8317		36" TEE	120.0	EA	2100.00	59.000	7,080	1.00	SRSX25 17.60	0	252,000	0	124,608	0	376,608
8317		36" ELL, 90	6.0	EA	1200.00	42.000	252	1.00	SRSX25 17.60	0	7,200	0	4,435	0	11,635
8317		36" FLANGE, WN	252.0	EA	940.00	24.000	6,048	1.00	SRSX25 17.60	0	236,880	0	106,445	0	343,325
8714		36" GATE VALVE, FLG	124.0	EA	35000.00	34.000	4,216	1.00	SRSX25 17.60	0	4,340,000	0	74,202	0	4,414,202
8714		36" CHECK VALVE, FLG	4.0	EA	30000.00	34.000	136	1.00	SRSX25 17.60	0	120,000	0	2,394	0	122,394
8520		36" PIPE SUPPORT [ALLOWANCE]	44.0	EA	75.00	25.000	1,100	1.00	SRSX25 17.60	0	0	3,300	19,360	0	22,660
4569		36" PIPE - PRIME & PAINT - 1300 LF	12,200.0	SF	0.60	0.100	1,220	1.00	SRSX14 15.60	0	0	7,320	19,032	0	26,352
8912		36" PIPE HYDROTEST	1,300.0	LF	0.00	0.368	478	1.00	SRSX25 17.60	0	0	0	8,420	0	8,420
3211		MACHINE EXCAVATE FOR SITE	506,020.0	CY	0.00	0.030	15,181	1.00	SRSX05 16.20	465,538	0	0	245,926	0	711,464
3212		HAND EXCAVATE FOR SITE	10,000.0	CY	0.00	4.000	40,000	1.00	SRSX04 11.80	0	0	0	472,000	0	472,000
3221		FURNISH & PLACE PIPE BEDDING SAND	1,911.0	CY	8.00	0.830	1,586	1.00	SRSX04 11.80	0	0	15,288	18,716	0	34,004
3221		TRENCH BACKFILL & COMPACTION	246,733.0	CY	0.00	0.060	14,804	1.00	SRSX05 16.20	202,321	0	0	239,824	0	442,146
3216		HAUL & DUMP (EXCESS)	27,999.0	CY	0.00	1.200	33,599	1.00	SRSX05 16.20	0	0	0	544,301	0	544,301
4160		CONCRETE FOR PUMP PADS	20.0	CY	60.00	2.500	50	1.00	SRSX10 12.20	0	0	1,200	610	0	1,810
4140		REBAR FOR FOR PUMP PADS	1.0	TON	600.00	20.000	20	1.00	SRSX08 17.30	0	0	600	346	0	946
4120		FORMWORK FOR PUMP PADS	164.0	SFCA	0.75	0.500	82	1.00	SRSX07 14.60	0	0	123	1,197	0	1,320
4140		FURNISH FAB & PLACE COVER/ GRATING	800.0	SF	8.35	0.093	74	1.00	SRSX12 17.50	1,296	0	6,680	1,302	0	9,278
WBS1.2.1.06 SITE #8, COOLING OPTION #2 SUBTOTAL							484,866		16.91	669,155	34,678,120	37,103	8,200,107	0	43,584,486
=====															
WBS 1.2.1.07 SITE #8, COOLING OPTION #3															
3211		MACHINE EXCAVATE FOR SITE	12,024.0	CY	0.00	0.030	361	1.00	SRSX05 16.20	11,062	0	0	5,844	0	16,906
3212		HAND EXCAVATE FOR SITE	4,008.0	CY	0.00	4.000	16,032	1.00	SRSX04 11.80	0	0	0	189,178	0	189,178

12

FILE: APTCOOL
PROJECT NAME: PROJECT NAME

ENGINEERING & CONSTRUCTION SERVICES DIVISION
SITE PROJECT ESTIMATING
DETAIL LINE ITEMS

PAGE # 8
TIME: 08:35:58
DATE 09-Aug-1996
REPORT NAME: APT Detail WBS EXCEL FORMAT

PRICING: PRE 95 OR POST 94 RATES

WBS	TWC	DESCRIPTION	QUANTITY	UOM	UNIT MATL	UNIT MHRS	TTL HOURS	ADJ FACT CREW	\$/MH	CONST. EQUIP.	ENGR'D EQUIP.	MAT'L	CRAFT LABOR	CONTRACT SERVICES	TOTAL COST
GROUP : NO APT GROUP IDENTIFIED															
ACCOUNT CODE:															
WBS 1.2.1.07 SITE #8, COOLING OPTION #3															
3221		FURNISH & PLACE PIPE BEDDING SAND	1,629.0	CY	8.00	0.830	1,352	1.00	SRSX04 11.80	0	0	13,032	15,954	0	28,986
3221		TRENCH BACKFILL & COMPACTION	13,139.0	CY	0.00	0.060	788	1.00	SRSX05 16.20	10,774	0	0	12,771	0	23,545
3216		HAUL & DUMP (EXCESS)	3,360.0	CY	0.00	1.200	4,032	1.00	SRSX05 16.20	0	0	0	65,318	0	65,318
3720		6" DIA WELL CASING W/ PUMP [500 GPM @ 15 HP]	18.0	EA	0.00	0.000	0	1.00		0	0	0	0	900,000	900,000
		WELL FIELD TANK [23.5' DIA x 15.5' HIGH - 50000 GAL]	1.0	EA	0.00	0.000	0	1.00		0	0	0	0	55,000	55,000
		6" PIPE, STN STL	180.0	LF	32.00	0.390	70	1.00	SRSX25 17.60	0	0	5,760	1,236	0	6,996
		6" ELL, 90	36.0	EA	95.00	9.400	338	1.00	SRSX25 17.60	0	0	3,420	5,956	0	9,376
		6" FLANGE, WN	144.0	EA	167.00	9.200	1,325	1.00	SRSX25 17.60	0	0	24,048	23,316	0	47,364
		6" GATE VALVE, FLG	36.0	EA	3000.00	3.100	112	1.00	SRSX25 17.60	0	108,000	0	1,964	0	109,964
		6" CHECK VALVE, FLG	18.0	EA	2100.00	3.100	56	1.00	SRSX25 17.60	0	37,800	0	982	0	38,782
		6" CONTROL VALVE, FLG	18.0	EA	19000.00	6.000	108	1.00	SRSX25 17.60	0	342,000	0	1,901	0	343,901
		6" PIPE SUPPORT, STN STL	36.0	EA	75.00	16.000	576	1.00	SRSX25 17.60	0	0	2,700	10,138	0	12,838
		6" HYDROTEST	180.0	LF	0.00	0.250	45	1.00	SRSX25 17.60	0	0	0	792	0	792
		6" PIPE, PVC	1,800.0	LF	1.60	0.140	252	1.00	SRSX25 17.60	0	0	2,880	4,435	0	7,315
		6" HYDROTEST	1,800.0	LF	0.00	0.150	270	1.00	SRSX25 17.60	0	0	0	4,752	0	4,752
		10" PIPE, PVC	24,000.0	LF	12.20	0.150	3,600	1.00	SRSX25 17.60	0	0	292,800	63,360	0	356,160
		10" HYDROTEST	24,000.0	LF	0.00	0.310	7,440	1.00	SRSX25 17.60	0	0	0	130,944	0	130,944
		18" PIPE, PVC	6,000.0	LF	13.50	0.250	1,500	1.00	SRSX25 17.60	0	0	81,000	26,400	0	107,400
		18" HYDROTEST	6,000.0	LF	0.00	0.250	1,500	1.00	SRSX25 17.60	0	0	0	26,400	0	26,400
		14" PIPE, CS	10.0	LF	25.80	0.830	8	1.00	SRSX25 17.60	0	0	258	146	0	404
		14" TEE	1.0	EA	430.00	23.000	23	1.00	SRSX25 17.60	0	0	430	405	0	835
		14" ELL, 90	2.0	EA	280.00	15.000	30	1.00	SRSX25 17.60	0	0	560	528	0	1,088
		14" GATE VALVE, FLG	2.0	EA	7500.00	5.100	10	1.00	SRSX25 17.60	0	15,000	0	180	0	15,180
		14" CHECK VALVE, FLG	2.0	EA	4800.00	5.100	10	1.00	SRSX25 17.60	0	9,600	0	180	0	9,780
		14" FLANGE, WN	10.0	EA	220.00	6.200	62	1.00	SRSX25 17.60	0	0	2,200	1,091	0	3,291
		14" PIPE SUPPORT, CS	4.0	EA	40.00	12.000	48	1.00	SRSX25 17.60	0	0	160	845	0	1,005
		18" X 14" REDUCER	1.0	EA	260.00	17.000	17	1.00	SRSX25 17.60	0	0	260	299	0	559
		14" HYDROTEST	10.0	LF	0.00	0.380	4	1.00	SRSX25 17.60	0	0	0	67	0	67
		14" PIPE - PRIME & PAINT - 10 LF	40.0	SF	0.70	0.108	4	1.00	SRSX14 15.60	0	0	28	67	0	95
		16" PIPE, CS	10.0	LF	30.80	0.890	9	1.00	SRSX25 17.60	0	0	308	157	0	465
		16" TEE	1.0	EA	520.00	26.000	26	1.00	SRSX25 17.60	0	0	520	458	0	978
		16" ELL, 90	2.0	EA	380.00	18.000	36	1.00	SRSX25 17.60	0	0	760	634	0	1,394
		16" GATE VALVE, FLG	2.0	EA	10200.00	5.900	12	1.00	SRSX25 17.60	0	20,400	0	208	0	20,608
		16" FLANGE, WN	6.0	EA	350.00	6.900	41	1.00	SRSX25 17.60	0	0	2,100	729	0	2,829
		16" PIPE SUPPORT, CS	4.0	EA	50.00	15.000	60	1.00	SRSX25 17.60	0	0	200	1,056	0	1,256
		16" HYDROTEST	10.0	LF	0.00	0.440	4	1.00	SRSX25 17.60	0	0	0	77	0	77
		16" PIPE - PRIME & PAINT - 10 LF	40.0	SF	0.60	0.100	4	1.00	SRSX14 15.60	0	0	24	62	0	86
			0.0				0	1.00		0	0	0	0	0	0
8315		18" PIPE, CS, STD	20.0	LF	51.50	0.950	19	1.00	SRSX25 17.60	0	0	1,030	334	0	1,364
8315		18" FLANGE, WN, 150#	7.0	EA	480.00	12.700	89	1.00	SRSX25 17.60	0	0	3,360	1,565	0	4,925

13

FILE: APTCOOL
PROJECT NAME: PROJECT NAME

ENGINEERING & CONSTRUCTION SERVICES DIVISION
SITE PROJECT ESTIMATING
DETAIL LINE ITEMS

PAGE # 9
TIME: 08:35:58
DATE 09-Aug-1996
REPORT NAME: APT Detail WBS EXCEL FORMAT

PRICING: PRE 95 OR POST 94 RATES

WBS	TWC	DESCRIPTION	QUANTITY	UOM	UNIT MATL	UNIT MHR	TTL HOURS	ADJ FACT CREW	\$/MH	CONST. EQUIP.	ENGR'D EQUIP.	MAT'L	CRAFT LABOR	CONTRACT SERVICES	TOTAL COST
GROUP : NO APT GROUP IDENTIFIED															
ACCOUNT CODE:															
WBS 1.2.1.07 SITE #8, COOLING OPTION #3															
8315	18"	ELL, 90	2.0	EA	490.00	20.500	41	1.00	SRSX25 17.60	0	0	980	722	0	1,702
8714	18"	GATE VALVE, FLG, CS	2.0	EA	12400.00	6.700	13	1.00	SRSX25 17.60	0	0	24,800	236	0	25,036
8714	18"	FLOW CONTROL VALVE, FLG, CS	1.0	EA	30000.00	15.000	15	1.00	SRSX25 17.60	0	0	30,000	264	0	30,264
8313	18"	BOLT-UP W/ B&G SET	7.0	EA	68.00	6.600	46	1.00	SRSX25 17.60	0	0	476	813	0	1,289
WBS1.2.1.07 SITE #8, COOLING OPTION #3 SUBTOTAL							40,390	14.92	21,836	532,800	494,094	602,762	955,000		2,606,492
WBS 1.2.1.08 SITE #8, COOLING OPTION #4															
1310		COOLING WATER PUMPS [50000GPM @ 2250 HP]	4.0	EA	400000.00	720.000	2,880	1.00	SRSX01 17.60	0	1,600,000	0	50,688	0	1,650,688
1400		ADJUSTMENT FOR COOLING EQUIPMENT (DELETE CT)	(10.0)	EA			0	1.00		0	(5,620,000)	0	0	0	(5,620,000)
8673	84"	ID CONCRETE PIPE	90,300.0	LF	245.00	1.400	126,420	1.00	SRSX25 17.60	0	22,123,500	0	2,224,992	0	24,348,492
8673	84"	ID PIPE JOINT [GROUT & GASKET- 8.25' OD @ 25.9 LF]	2,258.0	EA	0.00	42.000	94,836	1.00	SRSX25 17.60	0	0	0	1,669,114	0	1,669,114
3940	84"	CONCRETE PIPE, D&R 8" THK CONCRETE [84" TIE-IN]	2.0	EA	1180.00	180.000	360	1.00	SRSX26 17.10	0	360	2,000	6,156	0	8,516
8673	84"	ID FLANGE ADAPTERS	18.0	EA	8000.00	54.000	972	1.00	SRSX25 17.60	0	144,000	0	17,107	0	161,107
8714	84"	ID GATE VALVE, FLG [ALLOWANCE]	9.0	EA	28000.00	56.000	504	1.00	SRSX25 17.60	0	252,000	0	8,870	0	260,870
3940	84"	CONCRETE PIPE D & R	48.0	LF	0.00	2.600	125	1.00	SRSX25 17.60	0	0	0	2,196	0	2,196
8673	84"	CONCRETE PIPE CAP	8.0	EA	8800.00	42.000	336	1.00	SRSX25 17.60	0	70,400	0	5,914	0	76,314
8912	84"	ID PNEUMATIC PIPE JOINT TEST	2,258.0	EA	0.00	1.800	4,064	1.00	SRSX25 17.60	0	0	0	71,533	0	71,533
8673	78"	ID CONCRETE PIPE	600.0	LF	233.00	1.400	840	1.00	SRSX25 17.60	0	139,800	0	14,784	0	154,584
8673	78"	ID PIPE JOINT [GROUT & GASKET- 7.5' @ 23.6 LF]	15.0	EA	0.00	39.000	585	1.00	SRSX25 17.60	0	0	0	10,296	0	10,296
8673	78"	ID CONCRETE TIE-IN	4.0	EA	950.00	170.000	680	1.00	SRSX25 17.60	0	3,800	0	11,968	0	15,768
8912	78"	ID PNEUMATIC PIPE JOINT TEST	15.0	EA	1.60	1.600	24	1.00	SRSX25 17.60	0	24	0	422	0	446
8317	42"	CS PIPE, SCH 10	120.0	LF	102.00	1.600	192	1.00	SRSX25 17.60	0	12,240	0	3,379	0	15,619
8317	42"	TEE	3.0	EA	2200.00	68.000	204	1.00	SRSX25 17.60	0	6,600	0	3,590	0	10,190
8317	42"	ELL, 90	4.0	EA	1300.00	48.000	192	1.00	SRSX25 17.60	0	5,200	0	3,379	0	8,579
8317	42"	FLANGE, WN	12.0	EA	1000.00	26.000	312	1.00	SRSX25 17.60	0	12,000	0	5,491	0	17,491
8714	42"	GATE VALVE, FLG	4.0	EA	37000.00	48.000	192	1.00	SRSX25 17.60	0	148,000	0	3,379	0	151,379
8520	42"	PIPE SUPPORT [ALLOWANCE]	8.0	EA	100.00	30.000	240	1.00	SRSX25 17.60	0	0	800	4,224	0	5,024
4569	42"	PIPE - PRIME & PAINT - 120 LF	1,320.0	SF	0.60	0.100	132	1.00	SRSX14 15.60	0	0	792	2,059	0	2,851
8912	42"	PIPE HYDROTEST	120.0	LF	0.00	0.600	72	1.00	SRSX25 17.60	0	0	0	1,267	0	1,267
8317	36"	CS PIPE, SCH 10	1,300.0	LF	95.00	1.500	1,950	1.00	SRSX25 17.60	0	123,500	0	34,320	0	157,820
8317	36"	TEE	120.0	EA	2100.00	59.000	7,080	1.00	SRSX25 17.60	0	252,000	0	124,608	0	376,608
8317	36"	ELL, 90	6.0	EA	1200.00	42.000	252	1.00	SRSX25 17.60	0	7,200	0	4,435	0	11,635
8317	36"	FLANGE, WN	252.0	EA	940.00	24.000	6,048	1.00	SRSX25 17.60	0	236,880	0	106,445	0	343,325
8714	36"	GATE VALVE, FLG	124.0	EA	35000.00	34.000	4,216	1.00	SRSX25 17.60	0	4,340,000	0	74,202	0	4,414,202
8714	36"	CHECK VALVE, FLG	4.0	EA	30000.00	34.000	136	1.00	SRSX25 17.60	0	120,000	0	2,394	0	122,394

71

FILE: APTCOOL
PROJECT NAME: PROJECT NAME

ENGINEERING & CONSTRUCTION SERVICES DIVISION
SITE PROJECT ESTIMATING
DETAIL LINE ITEMS

PAGE # 10
TIME: 08:35:58
DATE 09-Aug-1996
REPORT NAME: APT Detail WBS EXCEL FORMAT

PRICING: PRE 95 OR POST 94 RATES

WBS	TWC	DESCRIPTION	QUANTITY	UOM	UNIT MATL	UNIT MHRS	TTL HOURS	ADJ FACT CREW	\$/MH	CONST. EQUIP.	ENGR'D EQUIP.	MAT'L	CRAFT LABOR	CONTRACT SERVICES	TOTAL COST
GROUP : NO APT GROUP IDENTIFIED															
ACCOUNT CODE:															
WBS1.2.1.08 SITE #8, COOLING OPTION #4															
	8520	36" PIPE SUPPORT (ALLOWANCE)	44.0	EA	75.00	25.000	1,100	1.00	SRSX25 17.60	0	0	3,300	19,360	0	22,660
	4569	36" PIPE - PRIME & PAINT - 1300 LF	12,200.0	SF	0.60	0.100	1,220	1.00	SRSX14 15.60	0	0	7,320	19,032	0	26,352
	8912	36" PIPE HYDROTEST	1,300.0	LF	0.00	0.368	478	1.00	SRSX25 17.60	0	0	0	8,420	0	8,420
	3211	MACHINE EXCAVATE FOR SITE	403,887.0	CY	0.00	0.030	12,117	1.00	SRSX05 16.20	371,576	0	0	196,289	0	567,865
	3212	HAND EXCAVATE FOR SITE	4,600.0	CY	0.00	4.000	18,400	1.00	SRSX04 11.80	0	0	0	217,120	0	217,120
	3221	FURNISH & PLACE PIPE BEDDING SAND	17,167.0	CY	8.00	0.830	14,249	1.00	SRSX04 11.80	0	0	137,336	168,134	0	305,470
	3221	TRENCH BACKFILL & COMPACTION	211,554.0	CY	0.00	0.060	12,693	1.00	SRSX05 16.20	173,474	0	0	205,630	0	379,105
	3216	HAUL & DUMP (EXCESS)	230,473.0	CY	0.00	1.200	276,568	1.00	SRSX05 16.20	0	0	0	4,480,395	0	4,480,395
	4160	CONCRETE PUMP PADS	20.0	CY	60.00	2.500	50	1.00	SRSX10 12.20	0	0	1,200	610	0	1,810
	4140	REBAR FOR PUMP PADS	1.0	TON	600.00	20.000	20	1.00	SRSX08 17.30	0	0	600	346	0	946
	4120	FORMWORK FOR PUMP PADS	164.0	SFCA	0.75	0.500	82	1.00	SRSX07 14.60	0	0	123	1,197	0	1,320
	4140	FURNISH FAB & PLACE COVER/ GRATING	800.0	SF	8.35	0.093	74	1.00	SRSX12 17.50	1,296	0	6,680	1,302	0	9,278
WBS1.2.1.08 SITE #8, COOLING OPTION #4 SUBTOTAL							590,895		16.56	546,346	23,977,504	160,151	9,785,049	0	34,469,051
=====															
WBS1.2.2.1 CASE 10 - OPTION #1															
1.06.05.04.01	1420	COOLING TOWER, 3 CELL @ 150 HP FAN - 56MW	1.0	EA	0.00	0.000	0	1.00		0	0	0	0	562,000	562,000
1.06.05.04.01	1310	CW SUPPLY PUMP, 12000 GPM @ 400 HP	3.0	EA	180000.00	180.000	540	1.00	SRSX01 17.60	0	540,000	0	9,504	0	549,504
1.06.05.04.01	8313	36" PIPE CS, STD	950.0	LF	99.75	1.500	1,425	1.00	SRSX25 17.60	0	0	94,763	25,080	0	119,843
1.06.05.04.01	8313	36" TEE	10.0	EA	2205.00	59.000	590	1.00	SRSX25 17.60	0	0	22,050	10,384	0	32,434
1.06.05.04.01	8313	36" ELL, 90	20.0	EA	1260.00	42.000	840	1.00	SRSX25 17.60	0	0	25,200	14,784	0	39,984
1.06.05.04.01	8313	36" FLANGE, WN	26.0	EA	987.00	24.000	624	1.00	SRSX25 17.60	0	0	25,662	10,982	0	36,644
1.06.05.04.01	8313	36" VALVES, FLG	10.0	EA	36750.00	34.000	340	1.00	SRSX25 17.60	0	0	367,500	5,984	0	373,484
1.06.05.04.01	8313	18" PIPE, CS, STD	3,100.0	LF	51.50	0.950	2,945	1.00	SRSX25 17.60	0	0	159,650	51,832	0	211,482
1.06.05.04.01	8313	18" TEE	8.0	EA	850.00	29.200	234	1.00	SRSX25 17.60	0	0	6,800	4,111	0	10,911
1.06.05.04.01	8313	18" ELL, 90	15.0	EA	490.00	20.500	308	1.00	SRSX25 17.60	0	0	7,350	5,412	0	12,762
1.06.05.04.01	8313	18" FLANGE, WN	20.0	EA	480.00	12.700	254	1.00	SRSX25 17.60	0	0	9,600	4,470	0	14,070
1.06.05.04.01	8313	18" VALVES, FLG	6.0	EA	12400.00	6.600	40	1.00	SRSX25 17.60	0	0	74,400	697	0	75,097
1.06.05.04.01	8912	HYDROTEST	4,050.0	LF	0.00	0.480	1,944	1.00	SRSX25 17.60	0	0	0	34,214	0	34,214
1.05.03.04.03.01	4140	BUILDING FOR HOUSING EQT.	12,000.0	SF	35.00	1.000	12,000	1.00	SRSX29 15.10	0	0	420,000	181,200	0	601,200
1.05.03.04.03.01	4120	FORMWORK FOR HOUSING EQT	1,200.0	SF	0.75	1.000	1,200	1.00	SRSX07 14.60	0	0	900	17,520	0	18,420
1.05.03.04.03.01	4140	REBAR FOR HOUSING EQT	22.0	TN	600.00	20.000	440	1.00	SRSX08 17.30	0	0	13,200	7,612	0	20,812
1.05.03.04.03.01	4160	CONCRETE FOR HOUSING EQT	444.0	CY	62.00	1.500	666	1.00	SRSX10 12.20	0	0	27,528	8,125	0	35,653
1.05.03.04.03.01	4120	FORMWK /EQT FOUND. & HEAT EXCH.	2,040.0	SF	0.75	1.000	2,040	1.00	SRSX07 14.60	0	0	1,530	29,784	0	31,314
1.05.03.04.03.01	4140	REBAR / EQT FOUNDATION & HEAT EXCH.	15.0	TN	600.00	20.000	300	1.00	SRSX08 17.30	0	0	9,000	5,190	0	14,190

FILE: APTCOOI
PROJECT NAME PROJECT NAME

ENGINEERING & CONSTRUCTION SERVICES DIVISION
SITE PROJECT ESTIMATING
DETAIL LINE ITEMS

PAGE # 11
TIME: 08:35:58
DATE 09-Aug-1996
REPORT NAME: APT Detail WBS EXCEL FORMAT

PRICING: PRE 95 OR POST 94 RATES

WBS	TWC	DESCRIPTION	QUANTITY	UOM	UNIT MATL	UNIT MHR	TTL HOURS	ADJ FACT CREW	\$/MH	CONST. EQUIP.	ENGR'D EQUIP.	MAT'L	CRAFT LABOR	CONTRACT SERVICES	TOTAL COST
GROUP : NO APT GROUP IDENTIFIED															
ACCOUNT CODE:															
WBS1.2.2.1 CASE 10 - OPTION #1															
1.05.03.04.03.01	4160	CONCRETE/ EQT FOUNDATION & HEAT EXH	444.0	CY	62.00	1.500	666	1.00	SRSX10 12.20	0	0	27,528	8,125	0	35,653
1.05.03.04.03.01	4160	SHIELDING WALLS	175.0	CY	300.00	12.000	2,100	1.00	SRSX13 16.20	0	0	52,500	34,020	0	86,520
1.05.03.04.03.01	3211	EXCAVATE FOR SLAB COOLING TOWER & PUMP PADS	500.0	CY	0.00	0.100	50	1.00	SRSX05 16.20	0	0	0	810	0	810
1.05.03.04.03.01	3212	FORMWORK FOR COOLING TOWER & PUMP PADS	540.0	CY	0.75	1.000	540	1.00	SRSX07 14.60	0	0	405	7,884	0	8,289
1.05.03.04.03.01	4140	REBAR/CHILLER COOLING TOWER & PUMP PADS	26.0	TN	600.00	20.000	520	1.00	SRSX08 17.30	0	0	15,600	8,996	0	24,596
1.05.03.04.03.01	4160	CONCRETE FOR COOLING TOWER & PUMP PADS	520.0	CY	62.00	1.500	780	1.00	SRSX10 12.20	0	0	32,240	9,516	0	41,756
WBS1.2.2.1 CASE 10 - OPTION #1 SUBTOTAL							31,385	15.81	0	540,000	1,393,406	496,238	562,000	2,991,643	=====
WBS1.2.2.2 CASE 10 - OPTION #2															
		CHILLER, 1000 TON CAPACITY	2.0	EA	0.00	0.000	0	1.00	0	0	0	0	0	400,000	400,000
		CW HEAT EXCHANGERS	6.0	EA	2100000.00	72.000	432	1.00	SRSX01 17.60	0	12,600,000	0	7,603	0	12,607,603
		36" PIPE CS, STD	950.0	LF	99.75	1.500	1,425	1.00	SRSX25 17.60	0	0	94,763	25,080	0	119,843
		36" TEE	10.0	EA	2205.00	59.000	590	1.00	SRSX25 17.60	0	0	22,050	10,384	0	32,434
		36" ELL, 90	20.0	EA	1260.00	42.000	840	1.00	SRSX25 17.60	0	0	25,200	14,784	0	39,984
		36" FLANGE, WN	0.0				0	1.00	SRSX25	0	0	0	0	0	0
		36" VALVES, FLG	0.0				0	1.00	SRSX25	0	0	0	0	0	0
		18" PIPE, CS, STD	4,150.0	LF	51.50	0.950	3,943	1.00	SRSX25 17.60	0	0	213,725	69,388	0	283,113
		18" TEE	10.0	EA	850.00	29.200	292	1.00	SRSX25 17.60	0	0	8,500	5,139	0	13,639
		18" ELL, 90	20.0	EA	490.00	20.500	410	1.00	SRSX25 17.60	0	0	9,800	7,216	0	17,016
		18" FLANGE, WN	26.0	EA	480.00	12.700	330	1.00	SRSX25 17.60	0	0	12,480	5,812	0	18,292
		18" VALVES, FLG	10.0	EA	12400.00	6.600	66	1.00	SRSX25 17.60	0	0	124,000	1,162	0	125,162
		HYDROTEST	5,100.0	LF	0.00	0.480	2,448	1.00	SRSX25 17.60	0	0	0	43,085	0	43,085
		BUILDING FOR CHILLERS	21,500.0	SF	35.00	1.000	21,500	1.00	SRSX29 15.10	0	0	752,500	324,650	0	1,077,150
		FORM WORK CHILL	1,975.0	SF	0.75	1.000	1,975	1.00	SRSX07 14.60	0	0	1,481	28,835	0	30,316
		REBAR CHILL	40.0	TN	600.00	20.000	800	1.00	SRSX08 17.30	0	0	24,000	13,840	0	37,840
		CONCRETE FOR CHILLERS	800.0	CY	62.00	1.500	1,200	1.00	SRSX10 12.20	0	0	49,600	14,640	0	64,240
		FORMWK /EQT FOUND. CHILLER & HEAT EXCH.	23,880.0	SF	0.75	1.000	23,880	1.00	SRSX07 14.60	0	0	17,910	348,648	0	366,558
		REBAR / EQT FOUNDATION CHILL. & HEAT EXCH.	32.0	TN	600.00	20.000	640	1.00	SRSX08 17.30	0	0	19,200	11,072	0	30,272
		CONCRETE/ EQT FOUNDATION FOR CHILL.& HEAT EXH	978.0	CY	62.00	1.500	1,467	1.00	SRSX10 12.20	0	0	60,636	17,897	0	78,533
		SHIELDING WALLS	342.0	CY	300.00	12.000	4,104	1.00	SRSX13 16.20	0	0	102,600	66,485	0	169,085
WBS1.2.2.2 CASE 10 - OPTION #2 SUBTOTAL							66,342	15.31	0	12,600,000	1,538,445	1,015,720	400,000	15,554,164	=====
WBS1.2.2.3 CASE 10 - OPTION #3															
		BUILDING FOR CHILLERS	12,000.0	SF	35.00	1.000	12,000	1.00	SRSX29 15.10	0	0	420,000	181,200	0	601,200
		FORM WORK CHILL	1,200.0	SF	0.75	1.000	1,200	1.00	SRSX07 14.60	0	0	900	17,520	0	18,420

76

FILE: APTCOOL

PROJECT NAME: PROJECT NAME

PRICING: PRE 95 OR POST 94 RATES

ENGINEERING & CONSTRUCTION SERVICES DIVISION

SITE PROJECT ESTIMATING

DETAIL LINE ITEMS

PAGE # 12

TIME: 08:35:58

DATE 09-Aug-1996

REPORT NAME: APT Detail WBS EXCEL FORMAT

WBS	TWC	DESCRIPTION	QUANTITY	UOM	UNIT MATL	UNIT MHRS	TTL HOURS	ADJ FACT	CREW	\$/MH	CONST. EQUIP.	ENGR'D EQUIP.	MAT'L	CRAFT LABOR	CONTRACT SERVICES	TOTAL COST
GROUP : NO APT GROUP IDENTIFIED																
ACCOUNT CODE:																
WBS1.2.2.3 CASE 10 - OPTION #3																
		REBAR CHIILL	22.0	TN	600.00	20.000	440	1.00	SRSX08	17.30	0	0	13,200	7,612	0	20,812
		CONCRETE FOR CHILLERS	444.0	CY	62.00	1.500	666	1.00	SRSX10	12.20	0	0	27,528	8,125	0	35,653
		FORMWK/EQT FOUND.	2,040.0	SF	0.75	1.000	2,040	1.00	SRSX07	14.60	0	0	1,530	29,784	0	31,314
		CHILLER & HEAT EXCH.														
		REBAR / EQT FOUNDATION	15.0	TN	600.00	20.000	300	1.00	SRSX08	17.30	0	0	9,000	5,190	0	14,190
		CHILL & HEAT EXCH.														
		CONCRETE/ EQT	444.0	CY	62.00	1.500	666	1.00	SRSX10	12.20	0	0	27,528	8,125	0	35,653
		FOUNDATION FOR CHILL & HEAT EXH														
		SHIELDING WALLS	175.0	CY	300.00	12.000	2,100	1.00	SRSX13	16.20	0	0	52,500	34,020	0	86,520
		COOLING TOWER, 3 CELL @	1.0	EA	0.00	0.000	0	1.00			0	0	0	0	562,000	562,000
		150 HP FAN - 56MW														
		CHILLER, 1000 TON CAPACITY	2.0	EA	0.00	0.000	0	1.00			0	0	0	0	400,000	400,000
		CW SUPPLY PUMP, 12000	3.0	EA	180000.00	180.000	540	1.00	SRSX01	17.60	0	540,000	0	9,504	0	549,504
		GPM @ 400 HP														
		CW HEAT EXCHANGERS	2.0	EA	2100000.00	72.000	144	1.00	SRSX01	17.60	0	4,200,000	0	2,534	0	4,202,534
		36" PIPE CS, STD	950.0	LF	99.75	1.500	1,425	1.00	SRSX25	17.60	0	0	94,763	25,080	0	119,843
		36" TEE	10.0	EA	2205.00	59.000	590	1.00	SRSX25	17.60	0	0	22,050	10,384	0	32,434
		36" ELL, 90	20.0	EA	1260.00	42.000	840	1.00	SRSX25	17.60	0	0	25,200	14,784	0	39,984
		36" FLANGE, WN	0.0				0	1.00	SRSX25		0	0	0	0	0	0
		36" VALVES, FLG	0.0				0	1.00	SRSX25		0	0	0	0	0	0
		18" PIPE, CS, STD	4,150.0	LF	51.50	0.950	3,943	1.00	SRSX25	17.60	0	0	213,725	69,388	0	283,113
		18" TEE	10.0	EA	850.00	29.200	292	1.00	SRSX25	17.60	0	0	8,500	5,139	0	13,639
		18" ELL, 90	20.0	EA	490.00	20.500	410	1.00	SRSX25	17.60	0	0	9,800	7,216	0	17,016
		18" FLANGE, WN	26.0	EA	480.00	12.700	330	1.00	SRSX25	17.60	0	0	12,480	5,812	0	18,292
		18" VALVES, FLG	10.0	EA	12400.00	6.600	66	1.00	SRSX25	17.60	0	0	124,000	1,162	0	125,162
		HYDROTEST	5,100.0	LF	0.00	0.480	2,448	1.00	SRSX25	17.60	0	0	0	43,085	0	43,085
		EXCAVATE FOR SLAB	500.0	CY	0.00	0.100	50	1.00	SRSX05	16.20	0	0	0	810	0	810
		COOLING TOWER														
		FORMWORK FOR COOLING TOWER	540.0	CY	0.75	1.000	540	1.00	SRSX07	14.60	0	0	405	7,884	0	8,289
		REBAR/CHILLER COOLING TOWER	26.0	TN	600.00	20.000	520	1.00	SRSX08	17.30	0	0	15,600	8,996	0	24,596
		CONCRETE FOR COOLING TOWER	520.0	CY	62.00	1.500	780	1.00	SRSX10	12.20	0	0	32,240	9,516	0	41,756

WBS1.2.2.3 CASE 10 - OPTION #3 SUBTOTAL 32,330 15.86 0 4,740,000 1,110,949 512,870 962,000 7,325,818

WBS1.2.2.4 CASE 10 - OPTION #4																
		CHILLER, 1000 TON CAPACITY	2.0	EA	0.00	0.000	0	1.00			0	0	0	0	400,000	400,000
		CW HEAT EXCHANGERS	6.0	EA	2100000.00	72.000	432	1.00	SRSX01	17.60	0	12,600,000	0	7,603	0	12,607,603
		36" PIPE CS, STD	950.0	LF	99.75	1.500	1,425	1.00	SRSX25	17.60	0	0	94,763	25,080	0	119,843
		36" TEE	10.0	EA	2205.00	59.000	590	1.00	SRSX25	17.60	0	0	22,050	10,384	0	32,434
		36" ELL, 90	20.0	EA	1260.00	42.000	840	1.00	SRSX25	17.60	0	0	25,200	14,784	0	39,984
		36" FLANGE, WN	0.0				0	1.00	SRSX25		0	0	0	0	0	0
		36" VALVES, FLG	0.0				0	1.00	SRSX25		0	0	0	0	0	0
		18" PIPE, CS, STD	4,150.0	LF	51.50	0.950	3,943	1.00	SRSX25	17.60	0	0	213,725	69,388	0	283,113

17

FILE: APTCOOL
PROJECT NAME: PROJECT NAME

ENGINEERING & CONSTRUCTION SERVICES DIVISION
SITE PROJECT ESTIMATING
DETAIL LINE ITEMS

PAGE # 13
TIME: 08:35:58
DATE 09-Aug-1996
REPORT NAME: APT Detail WBS EXCEL FORMAT

PRICING: PRE 95 OR POST 94 RATES

WBS	TWC	DESCRIPTION	QUANTITY	UOM	UNIT MATL	UNIT MHRS	TTL HOURS	ADJ FACT CREW	\$/MH	CONST. EQUIP.	ENGR'D EQUIP.	MAT'L	CRAFT LABOR	CONTRACT SERVICES	TOTAL COST
GROUP : NO APT GROUP IDENTIFIED															
ACCOUNT CODE:															
WBS1.2.2.4 CASE 10 - OPTION #4															
		18" TEE	10.0	EA	850.00	29.200	292	1.00	SRSX25 17.60	0	0	8,500	5,139	0	13,639
		18" ELL, 90	20.0	EA	490.00	20.500	410	1.00	SRSX25 17.60	0	0	9,800	7,216	0	17,016
		18" FLANGE, WN	26.0	EA	480.00	12.700	330	1.00	SRSX25 17.60	0	0	12,480	5,812	0	18,292
		18" VALVES, FLG	10.0	EA	12400.00	6.600	66	1.00	SRSX25 17.60	0	0	124,000	1,162	0	125,162
		HYDROTEST	5,100.0	LF	0.00	0.480	2,448	1.00	SRSX25 17.60	0	0	0	43,085	0	43,085
		BUILDING FOR CHILLERS	21,500.0	SF	35.00	1.000	21,500	1.00	SRSX29 15.10	0	0	752,500	324,650	0	1,077,150
		FORM WORK CHILL	1,975.0	SF	0.75	1.000	1,975	1.00	SRSX07 14.60	0	0	1,481	28,835	0	30,316
		REBAR CHILL	40.0	TN	600.00	20.000	800	1.00	SRSX08 17.30	0	0	24,000	13,840	0	37,840
		CONCRETE FOR CHILLERS	800.0	CY	62.00	1.500	1,200	1.00	SRSX10 12.20	0	0	49,600	14,640	0	64,240
		FORMWK/EQT FOUND.	23,880.0	SF	0.75	1.000	23,880	1.00	SRSX07 14.60	0	0	17,910	348,648	0	366,558
		CHILLER & HEAT EXCH.													
		REBAR / EQT FOUNDATION	32.0	TN	600.00	20.000	640	1.00	SRSX08 17.30	0	0	19,200	11,072	0	30,272
		CHILL. & HEAT EXCH.													
		CONCRETE/ EQT	978.0	CY	62.00	1.500	1,467	1.00	SRSX10 12.20	0	0	60,636	17,897	0	78,533
		FOUNDATION FOR CHILL.& HEAT EXH													
		SHIELDING WALLS	342.0	CY	300.00	12.000	4,104	1.00	SRSX13 16.20	0	0	102,600	66,485	0	169,085
WBS1.2.2.4 CASE 10 - OPTION #4 SUBTOTAL							66,342	15.31	0	12,600,000	1,538,445	1,015,720	400,000		15,554,164
WBS1.2.2.5 STATION 11															
1.06.05.04.02	1420	COOLING TOWER, 3 CELL @ 150 HP FAN - 56MW	2.0	EA	0.00	0.000	0	1.00		0	0	0	0	1,696,000	1,696,000
1.06.05.04.02	1310	CW SUPPLY PUMP, 12000 GPM @ 400 HP	6.0	EA	180000.00	180.000	1,080	1.00	SRSX01 17.60	0	1,080,000	0	19,008	0	1,099,008
1.06.05.04.02	8313	CW HEAT EXCHANGERS	4.0	EA	800000.00	72.000	288	1.00	SRSX01 17.60	0	3,200,000	0	5,069	0	3,205,069
1.06.05.04.02	8313	36" PIPE CS, STD	1,420.0	LF	99.75	1.500	2,130	1.00	SRSX25 17.60	0	0	141,645	37,488	0	179,133
1.06.05.04.02	8313	36" TEE	20.0	EA	2205.00	59.000	1,180	1.00	SRSX25 17.60	0	0	44,100	20,768	0	64,868
1.06.05.04.02	8313	36" ELL, 90	40.0	EA	1260.00	42.000	1,680	1.00	SRSX25 17.60	0	0	50,400	29,568	0	79,968
1.06.05.04.02	8313	36" FLANGE, WN	52.0	EA	987.00	24.000	1,248	1.00	SRSX25 17.60	0	0	51,324	21,965	0	73,289
1.06.05.04.02	8313	36" VALVES, FLG	20.0	EA	36750.00	34.000	680	1.00	SRSX25 17.60	0	0	735,000	11,968	0	746,968
1.06.05.04.02	8313	18" PIPE, CS, STD	2,650.0	LF	51.50	0.950	2,518	1.00	SRSX25 17.60	0	0	136,475	44,308	0	180,783
1.06.05.04.02	8313	18" TEE	16.0	EA	850.00	29.200	467	1.00	SRSX25 17.60	0	0	13,600	8,223	0	21,823
1.06.05.04.02	8313	18" ELL, 90	30.0	EA	490.00	20.500	615	1.00	SRSX25 17.60	0	0	14,700	10,824	0	25,524
1.06.05.04.02	8313	18" FLANGE, WN	40.0	EA	480.00	12.700	508	1.00	SRSX25 17.60	0	0	19,200	8,941	0	28,141
1.06.05.04.02	8912	18" VALVES, FLG	12.0	EA	12400.00	6.600	79	1.00	SRSX25 17.60	0	0	148,800	1,394	0	150,194
1.06.05.04.02	8912	HYDROTEST	6,070.0	LF	0.00	0.480	2,914	1.00	SRSX25 17.60	0	0	0	51,279	0	51,279
1.05.03.04.03.02	4140	BUILDING FOR HOUSING EQT.	24,000.0	SF	35.00	1.000	24,000	1.00	SRSX29 15.10	0	0	840,000	362,400	0	1,202,400
1.05.03.04.03.02	4120	FORMWORK FOR HOUSING EQT.	2,400.0	SF	0.75	1.000	2,400	1.00	SRSX07 14.60	0	0	1,800	35,040	0	36,840
1.05.03.04.03.02	4140	REBAR FOR HOUSING EQT.	44.0	TN	600.00	20.000	880	1.00	SRSX08 17.30	0	0	26,400	15,224	0	41,624
1.05.03.04.03.02	4160	CONCRETE FOR HOUSING EQT.	888.0	CY	62.00	1.500	1,332	1.00	SRSX10 12.20	0	0	55,056	16,250	0	71,306
1.05.03.04.03.02	4120	FORMWK /EQT FOUND. & HEAT EXCH.	2,040.0	SF	0.75	1.000	2,040	1.00	SRSX07 14.60	0	0	1,530	29,784	0	31,314
1.05.03.04.03.02	4140	REBAR / EQT FOUNDATION & HEAT EXCH.	15.0	TN	600.00	20.000	300	1.00	SRSX08 17.30	0	0	9,000	5,190	0	14,190

FILE: APTCOOL
PROJECT NAME: PROJECT NAME

ENGINEERING & CONSTRUCTION SERVICES DIVISION
SITE PROJECT ESTIMATING
DETAIL LINE ITEMS

PAGE # 14
TIME: 08:35:58
DATE 09-Aug-1996
REPORT NAME: APT Detail WBS EXCEL FORMAT

PRICING: PRE 95 OR POST 94 RATES

WBS	TWC	DESCRIPTION	QUANTITY	UOM	UNIT MATL	UNIT MHRS	TTL HOURS	ADJ FACT CREW	\$/MH	CONST. EQUIP.	ENGR'D EQUIP.	MAT'L	CRAFT LABOR	CONTRACT SERVICES	TOTAL COST
GROUP : NO APT GROUP IDENTIFIED															
ACCOUNT CODE:															
WBS1.2.2.5 STATION 11															
1.05.03.04.03.02	4160	CONCRETE/ EQT FOUNDATION .& HEAT EXH	444.0	CY	62.00	1.500	666	1.00	SRSX10 12.20	0	0	27,528	8,125	0	35,653
1.05.03.04.03.02	4160	SHIELDING WALLS	175.0	CY	300.00	12.000	2,100	1.00	SRSX13 16.20	0	0	52,500	34,020	0	86,520
1.05.03.04.03.02	3211	EXCAVATE FOR SLAB COOLING TOWER/ PUMP PADS	800.0	CY	0.00	0.100	80	1.00	SRSX05 16.20	0	0	0	1,296	0	1,296
1.05.03.04.03.02	3212	FORMWORK FOR COOLING TOWER / PUMP PADS	950.0	CY	0.75	1.000	950	1.00	SRSX07 14.60	0	0	713	13,870	0	14,583
1.05.03.04.03.02	4140	REBAR/CHILLER COOLING TOWER / PUMP PADS	50.0	TN	600.00	20.000	1,000	1.00	SRSX08 17.30	0	0	30,000	17,300	0	47,300
1.05.03.04.03.02	4160	CONCRETE FOR COOLING TOWER / PUMP PADS	900.0	CY	62.00	1.500	1,350	1.00	SRSX10 12.20	0	0	55,800	16,470	0	72,270
WBS1.2.2.5 STATION 11 SUBTOTAL							52,485	15.73	0	4,280,000	2,455,571	825,772	1,696,000		9,257,342
WBS1.2.5.1 ADDED SITE EXCAVATION															
		EXCAVATE HAZARDOUS DIRT BY MACHINE	225,000.0	CY	0.00	0.048	10,800	1.60	SRSX05 16.20	207,000	0	0	174,960	0	381,960
		HAUL & DUMP	225,000.0	CY	0.00	0.037	8,280	1.60	SRSX05 16.20	1,012,500	0	0	134,136	0	1,146,636
		ASSUME THAT 50% OF HAZARDOUS DIRT IS TREATED	112,500.0	CY	0.00	0.000	0	1.00		0	0	0	*,***,***		33,750,000
		ASSUME THAT 50% OF HAZARDOUS DIRT IS DISPOSED	112,500.0	CY	0.00	0.000	0	1.00		0	0	0	*,***,***		16,875,000
		PURCHASE & INSTALL CLEAN FILL COMMON BORROW	225,000.0	CY	3.64	0.023	5,175	1.00	SRSX05 16.20	321,750	0	819,000	83,835	0	1,224,585
		COMPACT COMMON BORROW	225,000.0	CY	0.00	0.007	1,575	1.00	SRSX05 16.20	45,000	0	0	25,515	0	70,515
WBS1.2.5.1 ADDED SITE EXCAVATION SUBTOTAL							25,830	16.20	1,586,250	0	819,000	418,446	50,625,000		53,448,696
SUBTOTAL							2,183,049	16.47	\$3,448,300	\$128,149,488	\$12,172,940	\$35,959,148	\$*,***,***		\$230,664,876
NO APT GROUP IDENTIFIED GROUP SUBTOTAL							2,183,049	16.47	3,448,300	128,149,488	12,172,940	35,959,148	50,935,000		230,664,876

GROUP : BALANCE OF PLANT
ACCOUNT CODE: B02110 STRUCTURES AND IMPROVEMENTS

WBS1.2.1.01 SITE #2, COOLING OPTION #1															
3211	MACHINE EXCAVATE FOR SITE 2 OPTION 1	17,174.0	CY	0.00	0.030	515	1.00	SRSX05 16.20	15,800	0	0	8,347	0		24,147
3212	HAND EXCAVATE FOR SITE 2 OPTION 1	5,725.0	CY	0.00	4.000	22,900	1.00	SRSX04 11.80	0	0	0	270,220	0		270,220
3221	FURNISH & PLACE PIPE BEDDING SAND	2,425.0	CY	8.00	0.830	2,013	1.00	SRSX04 11.80	0	0	19,400	23,750	0		43,150
3221	TRENCH BACKFILL & COMPACTION	18,497.0	CY	0.00	0.060	1,110	1.00	SRSX05 16.20	15,168	0	0	17,979	0		33,147

19

FILE: APTCOOI

PROJECT NAME: PROJECT NAME

ENGINEERING & CONSTRUCTION SERVICES DIVISION
SITE PROJECT ESTIMATING
DETAIL LINE ITEMS

PAGE # 15

TIME: 08:35:58

DATE 09-Aug-1996

REPORT NAME: APT Detail WBS EXCEL FORMAT

PRICING: PRE 95 OR POST 94 RATES

WBS	TWC	DESCRIPTION	QUANTITY	UOM	UNIT MATL	UNIT MHRS	TTL HOURS	ADJ FACT CREW	\$/MH	CONST. EQUIP.	ENGR'D EQUIP.	MAT'L	CRAFT LABOR	CONTRACT SERVICES	TOTAL COST
GROUP : BALANCE OF PLANT															
ACCOUNT CODE: BO2110 STRUCTURES AND IMPROVEMENTS															
WBS1.2.1.01 SITE #2, COOLING OPTION #1															
3216	HAUL & DUMP (EXCESS)		5,091.0	CY	0.00	1.200	6,109	1.00	SRSX05 16.20	0	0	0	98,969	0	98,969
WBS1.2.1.01	SITE #2, COOLING OPTION #1 SUBTOTAL						32,647		12.84	30,968	0	19,400	419,265	0	469,633
=====															
WBS1.2.1.05 SITE #8, COOLING OPTION #1															
3211	MACHINE EXCAVATE FOR SITE 8 OPTION 1		30,174.0	CY	0.00	0.030	905	1.00	SRSX05 16.20	27,760	0	0	14,665	0	42,425
3212	HAND EXCAVATE FOR SITE 8 OPTION 1		10,059.0	CY	0.00	4.000	40,236	1.00	SRSX04 11.80	0	0	0	474,785	0	474,785
3221	FURNISH & PLACE PIPE BEDDING SAND		3,792.0	CY	8.00	0.830	3,147	1.00	SRSX04 11.80	0	0	30,336	37,139	0	67,475
3221	TRENCH BACKFILL & COMPACTION		32,245.0	CY	0.00	0.060	1,935	1.00	SRSX05 16.20	26,441	0	0	31,342	0	57,783
3216	HAUL & DUMP (EXCESS)		10,661.0	CY	0.00	1.200	12,793	1.00	SRSX05 16.20	0	0	0	207,250	0	207,250
WBS1.2.1.05	SITE #8, COOLING OPTION #1 SUBTOTAL						59,016		12.97	54,201	0	30,336	765,180	0	849,717
=====															
BO2110 STRUCTURES AND IMPROVEMENTS SUBTOTAL							91,663		12.92	\$85,169	\$0	\$49,736	\$1,184,445	\$0	\$1,319,350
=====															
BALANCE OF PLANT		GROUP SUBTOTAL					91,663		12.92	85,169	0	49,736	1,184,445	0	1,319,350

20

PTCOOL
PROJECT NAME: PROJECT NAME

ENGINEERING & CONSTRUCTION SERVICES DIVISION
SITE PROJECT ESTIMATING
DETAIL LINE ITEMS

PAGE # 16
TIME: 08:35:58
DATE 09-Aug-1996
REPORT NAME: APT Detail WBS EXCEL FORMAT

PRICING: PRE 95 OR POST 94 RATES

WBS	TWC	DESCRIPTION	QUANTITY	UOM	UNIT MATL	UNIT MHRS	TTL HOURS	ADJ FACT CREW	\$/MH	CONST. EQUIP.	ENGR'D EQUIP.	MAT'L	CRAFT LABOR	CONTRACT SERVICES	TOTAL COST
=====															
PROJECT SUBTOTAL							2,274,712	16.33		\$3,533,469	\$128,149,488	\$12,222,676	\$37,143,594	\$*,***,***	\$231,984,226
PROJECT ESCALATION										\$0	\$0	\$0	\$0	\$0	\$0
=====															
PROJECT SUBTOTAL INCLUDING ESCALATION							2,274,712	16.33		\$3,533,469	\$128,149,488	\$12,222,676	\$37,143,594	\$50,935,000	\$231,984,226
=====															
SUBTOTAL INCLUDING ESCALATION							2,274,712	16.33		\$3,533,469	\$128,149,488	\$12,222,676	\$37,143,594	\$50,935,000	\$231,984,226
=====															
MANAGEMENT RESERVE @ 0.00 %															\$0
CONTINGENCY @ 0.00 %															\$0
CONTINGENCY NOTE 1															
CONTINGENCY NOTE 2															
PROJECT TOTAL COST															=====
															\$231,984,000
															=====

21